

**HYDRANT FLOW TEST REPORT**

BLACK FIRE PROTECTION
11093 MERIDIAN DRIVE NORTH
PARKLAND, FL 33076
PHONE #: 954-741-4548
FAX #: 772-333-2587
EMAIL@BLACKFIREPROTECTION.COM
WWW.BLACKFIREPROTECTION.COM

BILL TO:	FLYNN ENGINEERING SERVICES, P.A.	BLDG. INSPECTED:	1600 SOUTH FEDERAL HWY
STREET ADDRESS:	241 COMMERCIAL BLVD	BLDG. ADDRESS:	1600 SOUTH FEDERAL HWY
CITY, STATE & ZIP:	LAUDERDALE-BY-THE-SEA, FL 33308	CITY, STATE & ZIP:	POMPANO BEACH, FL
POINT OF CONTACT:	BLAKE KIDWELL/YURI KHARITONENKO	POINT OF CONTACT:	YURI KHARITONENKOV
PHONE NUMBER:	954--522-1004	PHONE NUMBER:	-
FAX NUMBER:	-	FAX NUMBER:	-
EMAIL ADDRESS:	bkidwell@flynnengineering.com	EMAIL ADDRESS:	YURY@VERA.FUND
JOB NUMBER:	IM25-676	TESTER'S NAME:	Paul Meighan
CONTRACTOR LIC. #:	FPC11-000068		

HYDRANT LOCATION:	PW-HYD-66-1407	HYDRANT MAKE:	Mueller
NUMBER OF HYDRANTS:	1	HYDRANT MODEL:	Not Ledgeable

WATER SUPPLIED BY:	City of Pompano Beach	PURPOSE OF TEST:	
--------------------	-----------------------	------------------	--

FLOW HYDRANT	#1		
Size opening	<u>2@2"</u>		
Pitot reading	<u>2@ 11Psi</u>		
GPM	1034		

STATIC READING:	74	RESIDUAL READING:	60
-----------------	----	-------------------	----

RESULTS: Total of 1034 Gpm

REMARKS

FLOWED (2) OUTLETS FROM 2" HOSE MONSTER.

C. INSPECTION AND SUGGESTED IMPROVEMENTS WERE DISCUSSED WITH THE UNDERSIGNED

X	YURI KHARITONENKOV	X		X	-
	OWNER OR OWNER'S REPRESENTATIVE (PRINT)		AUTHORIZED SIGNATURE		DATE

D. I CERTIFY THAT THE INFORMATION ON THIS FORM IS CORRECT AT THE TIME AND PLACE OF MY INSPECTION AND THAT ALL EQUIPMENT TESTED AT THIS TIME WAS LEFT IN OPERATIONAL CONDITION UPON COMPLETION OF THIS INSPECTION EXCEPT AS NOTED ABOVE IN COMMENTS.

X Paul Meighan
PZ24- 12000027
11/19/2025
INSPECTOR (PRINT)

X
PZ24- 12000027
12/17/2025
SIGNATURE

X
PZ24- 12000027
06/24/2026
DATE