





Revisions			Comments
Rev	Date		
..	.....		.....
..	.....		.....
..	.....		.....
..	.....		.....

Project Name:	<b>Pompano Multifamily LVL 1</b>
Project ID Number:	<b>2024-550</b>
Date:	<b>07/25/2024</b>



Calculation Values - DB Lighting Consultation							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
Building Front	Illuminance	Fc	3.08	10.8	0.1	30.80	108.00
Parking	Illuminance	Fc	6.16	16.2	1.6	3.85	10.13

Luminaire Data - DB Lighting Consultation								
Label	Qty	Symbol	[MANUFAC]	Description	LLF	Watts	Lumens	Mtg Hgt
W3	7		LSI	MRS-LED-06L-SIL-3-40-70CRI	0.850	39	6239	10, 12
SL4	2		LSI	MRS-LED-18L-SIL-FT-30-70CRI-IH	0.850	135	12427	20
GA	14		LSI	EG3-4-LED-04L-DA-S-50-80	0.850	32	4508	8

DB Lighting Consultation (DBLC) assumes no responsibility for any errors in the IES files, background images, or other information provided to DBLC to be used in these calculations. Actual or measured results may vary due to manufacturer tolerances, component malfunctions, obstructions, varying surface reflectance's and other field conditions. The owner assumes all responsibility for compliance with federal, state and/or local codes and regulations.