



TABLE OF SIDEWALK JOINTS	
TYPE	LOCATION
'A'	P.C. AND P.T. OF CURVES
'B'	5'-0" C/C ON SIDEWALKS

- NOTES:**
1. CONCRETE TO BE CLASS-1, 3000 P.S.I.
  2. THE USE OF REINFORCEMENT WILL NOT BE PERMITTED.
  3. SIDEWALK SLOPES SHALL MEET THE REQUIREMENTS OF THE "AMERICAN WITH DISABILITIES ACT"
  4. SIDEWALK ELEVATION AT THE RIGHT-OF-WAY SHALL MATCH THE EXISTING CENTERLINE ELEVATION OF THE ADJACENT STREET.

- CURBING GENERAL NOTES:

1. LIMEROCK BASE SHALL BE COMPACTED TO NOT LESS THAN 98% OF MAXIMUM DENSITY AS DETERMINED BY AASHTO T-180 WITH MINIMUM LBR 100 AND MAXIMUM OF 6" LIFTS.
2. SUB GRADE SHALL BE COMPACTED TO NOT LESS THAN 98% OF MAXIMUM DENSITY AS DETERMINED BY AASHTO T-180 WITH MINIMUM LBR 40 AND A MAXIMUM OF 6" LIFTS.
3. DENSITY TESTS SHALL BE REQUIRED AT A MINIMUM OF ONE PER 5,000 SQUARE FEET, AND PERFORMED BY AN APPROVED INDEPENDENT LABORATORY AT THE CONTRACTOR'S EXPENSE.
4. EXTRUDED CURB SHALL BE POURED MONOLITHICALLY. ALL CURBS SHALL BE CONSTRUCTED IN ACCORDANCE WITH THIS DETAIL SHEET.
5. CONTROL JOINTS SHALL BE TOOLED OR CUT EVERY TEN (10) FEET.
6. ALL AREAS BEHIND CURBS SHALL BE BACKFILLED WITHIN 72 HOURS OF PLACEMENT.

**PAVING NOTES:**  
 All wearing surfaces shall be 1" thick asphaltic concrete Type S-1 over tack coat, over prime and sand seal. All base course shall be 6" limerock grade compacted in accordance w/ A.A.S.H.T.O. T-180 to 98% min. density. Subgrade to 12" below base course shall be compacted in accordance w/ A.A.S.H.T.O. T-180 to 98% density. The entire R/W shall be stabilized as per City specifications. All fill shall be compacted to 95% of min density per A.A.S.H.T.O. T-180.

REVISIONS:

A

**DON ARPIN**  
D.E. 00707

**APPROVED SEAL/SIGNATURE**

DON ARPIN MSPE PE #28585  
ASSOCIATED GENERAL KINETICS, LLC  
COA #26073

4920 NORTH DIXIE HIGHWAY  
FORT LAUDERDALE, FL 33334  
OFFICE (954) 772-8345 FAX: (954) 772-7478

THE NEW AUTO TOY STORE

929 & 941 S.W. 8TH STREET  
POMPANO BEACH, FLORIDA 33069

DRAWN:

DATE:  
7/29/2025

PROJECT NUMBER:

SHEET NUMBER:

SP-2

TO THE BEST OF MY KNOWLEDGE, THE PLANS AND SPECIFICATIONS COMPLY WITH THE APPLICABLE MINIMUM BUILDING CODES AND THE APPLICABLE FIRE-SAFETY STANDARDS AS DETERMINED BY THE LOCAL AUTHORITY IN ACCORDANCE WITH THIS SECTION AND CHAPTER 633, FLORIDA STATUTES.