

Memo

To: Zoning Board of Appeals
From: Pete McGinnis Fire Marshal & James Galloway, Fire Inspector
Date: November 7, 2022
Re: Zoning Board of Appeal 22-17000013

Due to the fact the petitioner is able to meet all of the Fire Department requirements at this time we have no objections to the request for a Special Exception. However, the petitioner shall maintain all proper fire department access as per chapter 18 of NFPA 1 as amended from time to time.

- **This may be a Change of Use to New Assembly as per NFPA 101 Life Safety.**
- **Building permits will be required for the change of use following NFPA 101 Chapter 43 Rehabilitation and Chapter 12 New Assembly.**
- **Additional fire protection and life safety systems may be required with submittal of building plan review.**

*Additional comments may follow throughout the remainder of the permitting process. The building shall be in compliance with All NFPA Standards prior to receiving Fire Department approval.

CC: Pete McGinnis, Fire Marshal