

FIRE DEPARTMENT COMMENT RESPONSE SHEET

Plan Reviewer: Jim Galloway | jim.galloway@copbfl.com

Status: Review complete. Resubmittal required.

(1) Submit site/civil plans showing location of existing or proposed water mains (including size) and fire hydrants in area. Refer to NFPA 1 2018ed Chapter 18 for required fire flow, minimum number of hydrants and spacing.

R. On site plan is showed (2) new fire hydrant will add to civil plan, required fire flow & data will be provided by Subcontractor from nearest existing Hydrant

(2) Provide a Hydrant Flow Test to determine the available water supply to this project. This test must be performed by a qualified company of the builder’s choice. In addition, the static pressure at the water main shall be determined by a recorded method (ie. water wheel) for a minimum twenty-four (24) hour period. The actual flow test must be witnessed by, and recorded data sent to City of Pompano Beach Fire Prevention.

R. Flow test has been ordered and will be uploaded to eplan once completed.

(3) Provide Required Fire Flow Data for each proposed structure: Fire flow calculations are determined from square footage and construction type of structure. Refer to NFPA 1 chapter 18 for required fire flow, number/spacing of fire hydrants. Depending on the hydrant flow test results additional fire protection systems or change in construction type maybe required for project (NFPA 1 2018ed chapter 18). This information must be provided at DRC to evaluate current water supply conditions. City of Pompano requires a minimum of 2 fire hydrants. Maximum distance to secondary fire hydrant is 400ft of any future building. Distance is measured by fire apparatus travel on access roadways. (COPFL ORD. 95.09 (C)) Complete attached form “Water Supply Fire Flow”

R. See proposed (2) fire Hydrant on site plan at 180Ft distance <400 ft required all other data will be provided by Qualified company /Subcontractor and submitted before DCR committee

(4) Documentation of purchase for fire service backflow and meter assemblies must be provided to City of Pompano Utilities and Fire Prevention before underground inspections of water mains. Installation of assembly as per backflow/meter specifications and following standards: NFPA 13 Standards of Installation of Fire Sprinklers, NFPA 25 Standards for Inspection, Testing, and Maintenance of Water Based Fire Protection Systems. All control valves on backflow and meter assemblies, total of four (4), for fire protection systems must have fire alarm supervision (tamper switches).


R. To be submitted

(5) Provide fire department apparatus access to within 50ft of front entry door required. (NFPA 1 2018ed Chapter 18 section 18.2.3.2)

R. Lot Size, dimensions and site conditions doesn’t allow a fire apparatus access to the property, we are providing a Fire Sprinklers System (Protected Building Category) with less than 150 Ft (140Ft Max distance to farthest Unit door) from the Street, a second access by the NE 27 Way (Dead end way) has a very low traffic allowing a fire truck parking for emergencies.

(6) Provide a fire truck turning circle, incorporating the approved road widths (minimum 20ft wide) and turning radius, minimum turning radius 10ft inside and 50ft outside. Provide both arcs and center point that arcs are measured from.

R. Lot Size, dimensions and site conditions doesn’t allow a fire apparatus access to the property. This is a Protected Building with fire sprinklers System



DRC

PZ21-12000034

DRC

PZ21-12000034
4/6/2022

3/2/2022

PZ21-12000034
2/2/2022

(7) Fire department access roads shall have an unobstructed vertical clearance of not less than 13ft 6 in. (NFPA 1 2018ed chapter 18 section 18.2.3.5.1.2) City of Pompano Beach Page 4 of 27
Printed on 12/8/2021 powered by Legistar™ File #: LN-201

R. . Lot Size, dimensions and site conditions doesn't allow a fire apparatus access to the property.

(8) Exits for all units shown discharging under the building into a higher hazard area. Exit discharge must be free and clear of building to a public right of way. NFPA 101 chapter 7.

R. The discharge will be into open space, common area for swimming pool and landscaping also connected with minimum 10 ft exterior landscape to streets and the maximum travel distance proposed fore dwelling units is 108 ft to public right of way located at NE 14 Street which is less than 200 Ft chapter (NFPA 101 30.2.6.3.2) for a Fire Sprinklers Protected Building See LS-1 & 2 plans revised

DRC
PZ21-12000034
4/6/2022

DRC
PZ21-12000034
3/2/2022

DRC
PZ21-12000034
2/2/2022