

DRCPZ26- 12000001
04/01/2026**DRC**PZ26- 12000001
05/20/2026**AMERICAN EAGLE FIRE PROTECTION, INC.**

4711 North Dixie Highway – Boca Raton, FL 33431

Telephone: 561-750-3698 – Fax: 561-750-8496

LIC # 33490800012003

FLOW TEST

STATIC PRESSURE (psi)	RESIDUAL PRESSURE (psi)	PITOT PRESSURE (psi)	PITOT FLOW (gpm)	OUTLET SIZE
82	78	38	1031	2"

Address: MLK (NW 3rd) and Dixie Hwy**Flow Test Date:** Wednesday, January 14th, 2026 at 8:00 a.m. – Thursday, January 15th, 2026 at 8:00 a.m.Sketch of Test Location

Please note this test was performed using "The Little Hose Monster". The co-efficient and flow data are based on manufactures UL Listed specific specs designed for use of the 2 inch pitotless nozzle.

X Adam Summers
AEFP Technician

Date: 01/16/2026