

ALL ELECTRICAL WORK AS PER
FBC 2023 AND 20234 NEC
PROVIDE INTERSYSTEM BONDING
NEC 250.94

S Dixie Highway



50A OUTLET PANEL

ELECTRICAL RATING AC 125/250V 50A

MOUNT AT LEAST 24 INCHES ABOVE GROUND LEVEL

TYPE OF ENCLOSURE


RAINPROOF

ITEM NO.

9001POPS0

RECEPTACLE

RECEPTACLE



USE 60/75°C CU-AL WIRE

TIGHTENING TORQUE POUND-INCHES

SIZE OF CONDUCTOR	#14-10	#8	#6-4
LINE/NEUTRAL TERMINAL	75	45	45
GROUND TERMINAL	75	45	45

WARNING

AVOID OR ELECTRICAL SHOCK OR BURN
TURN OFF POWER SUPPLYING THIS EQUIPMENT
BEFORE WORKING INSIDE

Read Owner's Manual for instructions on use.
Check for updates on our website or contact our
technical support.

MADE IN CHINA