



Add Turbidity Barrier as per 152.06 City Ordinance

DESIGN WINDLOAD INFORMATION

CODE: FBCR 2020 7th
 ASCE 7-16
 Wind Speed: 175 MPH, 3 Second Gust
 Exposure "D"
 Importance Factor: 1.0
 Internal Pressure Coeff.: 0.00
 Height 6 ft Mean

OLEANDER CANAL
 100' (W.B.W.)

SITE PLAN
 SCALE 1"=10'

ALUMINUM DOCK LADDER ATTACHED TO WOOD DOCK USING (4) 1/2 x 6" LONG S.S. BOLTS WITH NUTS AND WASHERS
 NOTE:
 LADDER LOCATION MY BE DETERMINED AT SITE

THE WORK SPECIFIED HEREIN HAS BEEN DESIGNED & ALL WORK SHALL BE IN ACCORDANCE WITH STRUCTURAL PROVISIONS OF THE 7th EDITION 2020 FLORIDA BUILDING CODE. BEST MANAGEMENT PRACTICES: FLOATING TURBIDITY CURTAIN EXTENDING WITHIN 1' OF BOTTOM TO BE INSTALLED DURING PILING INSTALLATION.



B&B Consulting Engineers
 2237 Woods Edge Circle
 Orlando Florida 32817
 (772) 828-2263 (772) 708-7785

RONALD J STAUFFER
 2800 NE 9 CT POMPANO
 BEACH FL, 33062

PAGE	Date:
4 OF 6	03/14/2022
Revisions:	Date:
A	04/7/2022

THE DOCK EXPERTS

 NEW SEAWALL CAP & WOOD DOCK