

DESIGNED	DRAWN	CHECKED
NH	NH	JY

#### EGRESS LEGEND

- 105'-6" TRAVEL DISTANCE  
EGRESS PATH OF TRAVEL  
COMMON PATH DISTANCE  
105'-6" COMMON PATH OF TRAVEL
- LED EXIT SIGN WITH BATTERY PACK, WALL MOUNT  
LED EXIT SIGN WITH BATTERY PACK, CEILING MOUNT  
EXIT SIGN DIRECTIONAL ARROWS  
EXIT SIGN LIGHT DIRECTION
- FEC SURFACE MOUNTED TYPE ABC FIRE EXTINGUISHER  
& CABINET EXTINGUISHERS SHALL BE CURRENTLY  
DATED AND TAGGED BY LICENSED FIRE  
EQUIPMENT COMPANY, AND LOCATED NOT  
FURTHER THAN 75 FEET OF TRAVEL DISTANCE TO  
AN EXTINGUISHER
- FE SURFACE MOUNTED TYPE ABC FIRE  
EXTINGUISHER INSTALLED ON SUPPLIED  
BRACKET. EXTINGUISHERS SHALL BE  
CURRENTLY DATED AND TAGGED BY LICENSED  
FIRE EQUIPMENT COMPANY, AND LOCATED  
NOT FURTHER THAN 75 FEET OF TRAVEL  
DISTANCE TO AN EXTINGUISHER

#### EGRESS NOTES

- COORDINATE FIRE ALARM DEVICES AND PANELS WITH ELECTRICAL DRAWINGS
- REFER TO FIRE PROTECTION DRAWINGS FOR SPRINKLER HEAD LOCATIONS
- REFER TO ELECTRICAL DRAWINGS FOR FIRE ALARM DEVICE LOCATIONS
- REFER TO ELECTRICAL DRAWINGS FOR EMERGENCY LIGHT LOCATIONS
- ORDINARY HAZARD OF CONTENTS (NFPA 38.1.5.1)
- A FACTOR OF 0.2 INCHES OF WIDTH PER OCCUPANT HAS BEEN USED TO CALCULATE MINIMUM DOOR AND CORRIDOR EGRESS CAPACITY
- A FACTOR OF 3 INCHES OF WIDTH PER OCCUPANT HAS BEEN USED TO CALCULATE MINIMUM CLEAR WIDTH OF STAIRWAY EGRESS CAPACITY

AUTOMATIC EXTERNAL DEFIBRILLATORS (AED) AND STOP THE BLEED KITS (STBK) SHALL BE INSTALLED AS DEFINED IN NFPA 101, LIFE SAFETY CODE. ON EVERY OTHER FLOOR BEGINNING ON THE FIRST FLOOR, THE AED AND STBK SHALL BE PLACED NEAR THE ELEVATOR(S) BEGINNING IN THE FIRST-FLOOR LOBBY (FIRST FLOOR, THIRD FLOOR, FIFTH FLOOR, ETC.) REFER TO BROWARD FIRE CODE AMENDMENTS SECTION F-121 FOR ADDITIONAL INFORMATION FOR LOCATION, MOUNTING, INVENTORY, TRAINING, AND INSPECTION OF REQUIRED EQUIPMENT.

#### POOLDECK FLOOR OCCUPANT LOADS

POOL + TUB	857 SF @ 50 SF/OCC = 18 OCCUPANTS
POOLDECK	
(FBC)	2,660 SF @ 15 SF/OCC = 178 OCCUPANTS
(NFPA)	2,660 SF @ 30 SF/OCC = 89 OCCUPANTS
BAR	2,070 SF @ 15 SF/OCC = 138 OCCUPANTS
TERRACE	854 SF @ 15 SF/OCC = 57 OCCUPANTS
ELEV. LOBBY	945 SF @ 150 SF/OCC = 6 OCCUPANTS
OFFICES	827 SF @ 150 SF/OCC = 4 OCCUPANTS
BOH	348 SF @ 300 SF/OCC = 2 OCCUPANTS
<b>TOTAL</b>	<b>(NFPA) 314 OCCUPANTS</b>
	<b>(FBC) 403 OCCUPANTS</b>
	<b>(NFPA) 314 * 0.3 = 94.2" / 2 = (2) STAIRS @ 47.1" CLR WIDTH REQ'</b>
	<b>(FBC) 403 * 0.2 = 80.6" / 2 = (2) STAIRS @ 40.3" CLR WIDTH REQ'</b>
	<b>(2) STAIRS @ 50" CLR WIDTH PROVIDED</b>

1 LEVEL 15 - POOLDECK  
AR-106 Scale: 3/32" = 1'-0"

#### REVISIONS

DATE: 04.05.2024  
COMM: 23008

POMPANO HOTEL

101 S. OCEAN BLVD  
POMPANO BEACH, FL 33062

Digitally signed  
by Jiro Yates  
Date:  
2024.04.05  
10:40:46-04'00'

POOLDECK LEVEL

DRC SET

AR-106

AAC

PZ23-12000042

05/07/2024

4/5/2024 10:04:21 AM