

Memo

To: Zoning Board of Appeals
From: James Galloway, Fire Inspector
Date: March 12, 2025
Re: Zoning Board of Appeal 25-15000001

Due to the fact the petitioner is able to meet all of the Fire Department requirements at this time we have no objections to the request for a Temporary Use Permit. However, the petitioner shall maintain all proper fire department access as per chapter 18 of NFPA 1 as amended from time to time.

Petitioner is to submit to Fire Prevention for review and approval a site plan layout of the outdoor storage area, fire department access and water supply to the site before area use.

*Additional comments may follow throughout the remainder of the permitting process. The building shall be in compliance with **All** NFPA Standards prior to receiving Fire Department approval.

CC: Pete McGinnis, Fire Marshal