


8 0 8 16



SCALE: 1/8" = 1'-0"

## LIFE SAFETY NOTES

<p>A. ALL INTERIOR FINISHES SHALL COMPLY WITH THE APPLICABLE CHAPTER(S) AND SECTION(S) OF NFPA 101 (LSC).</p> <p>B. ALL PENETRATIONS IN RATED PARTITIONS SHALL BE PROTECTED PER FBC. 2020 SECTION 712. PENETRATIONS FOR CABLES, CABLE TRAYS, CONDUITS, PIPES, TUBES, COMBUSTION VENTS AND EXHAUST VENTS, WIRES AND SIMILAR ITEMS TO ACCOMMODATE ELECTRICAL, MECHANICAL, PLUMBING, AND COMMUNICATION SYSTEMS THAT PASS THROUGH A WALL, FLOOR, OR FLOOR / CEILING ASSEMBLY CONSTRUCTED AS A FIRE BARRIER SHALL BE PROTECTED BY A FIRE STOP SYSTEM OR DEVICE.</p> <p>C. FIRE ALARM SYSTEM IS REQUIRED THROUGHOUT. TIE INTO EXISTING.</p> <p>D. PROVIDE ONE FIRE EXTINGUISHER FOR 3,000 S.F.      6,335 SF S.F./3,000 S.F. = 2 UNITS REQUIRED &amp; 3 PROVIDED.</p> <p>E. INSTALL 3D TRIANGLE PROJECTION SIGN ABOVE EACH FIRE EXTINGUISHER 4" TO 6" FROM CEILING GRID.</p> <p>F. ALL PENETRATIONS IN RATED PARTITIONS SHALL BE PROTECTED PER F.B.C SECTION 710.6, HILTI PRODUCTS OR EQUAL TO BE USED IN ALL RATED WALL PENETRATIONS.</p> <p>G. EMERGENCY AND EXIT LIGHT TO COMPLY WITH NFPA 101 38.2.8 AND 38.2.9.1</p> <p>H. GC SHALL MAINTAIN ALL EMERGENCY EGRESS AND PATHWAYS DURING DEMOLITION AND CONSTRUCTION UNTIL COMPLETION OF PROJECT.</p>
---

PROJECT DATA

APPLICABLE BUILDING CODE:

FLORIDA BUILDING CODE 7th EDITION 2020  
FLORIDA BUILDING CODE 7th EDITION 2020 - EXISTING BUILDING  
FLORIDA FIRE PREVENTION CODE 7TH EDITION  
NFPA 101 EDITION 2018

OCCUPANCY TYPE PER FBC:

"B" BUSINESS

TYPE OF CONSTRUCTION:

TYPE III-B (FBC)  
FULLY SPRINKLERED/ FIRE ALARM

BUILDING HEIGHT:

ALLOWABLE: 4 STORIES, 75 FT.  
PROVIDED: 1 STORY, 16' - 8"

BUILDING GROSS AREA:

ALLOWABLE: 92,000 SF  
PROVIDED: 6,335 SF

OCCUPANT LOAD PER FBC TABLE 1004.5/ NFPA 101 TABLE 7.3.1.2:

	NEW	EXISTING:
BUSINESS (6,335 SF):	150 Gross S.F./ Person = 6,335 / 150 = 42 OCCUPANTS	150 Gross S.F./ Person = 4,800 / 150 = 32 OCCUPANTS
	OCCUPANT LOAD: 42 OCCUPANTS	OCCUPANT LOAD: 32 OCCUPANTS

NUMBER OF MEANS OF EGRESS FOR BUSINESS OCC. - PER NFPA 101.38.2.4/ 101.7.4:

REQUIRED	PROVIDED
2	3

SCOPE OF WORK:

WORK CONSISTS OF THE DESIGN AND CONSTRUCTION ADMINISTRATION FOR A ONE STORY APPROXIMATELY 6,335 SF BUILDING ADDITION TO THE EXISTING ONE STORY APPROXIMATELY 4,800 SF ADMINISTRATION BUILDING CURRENTLY OCCUPIED BY THE BROWARD COUNTY PUBLIC WORKS DEPARTMENT, HIGHWAY AND BRIDGE MAINTENANCE DIVISION ("HBMD").

FIRE-RESISTANCE RATING REQUIREMENTS FOR BLDG. ELEMENTS:

BUILDING CODE INFORMATION

REQUIRED FIRE RESISTANT RATINGS, TABLE 601, FBC:

STRUCTURAL FRAME	0 HRS
EXTERIOR BEARING WALLS	0 HRS BASED ON DISTANCE SEPARATION
INTERIOR BEARING WALLS	0 HRS
NON-BEARING WALLS & PARTITIONS	0 HRS
FLOORS	0 HRS
ROOFS	0 HRS

CORRIDOR WALLS: 0 HRS -FIRE SPRINKLERS PER FBC TABLE 1018.1

DISTANCE SEPARATION TABLE 602, FBC FOR GROUP "B":

< 5 FT	: 3 HRS
> 5 FT, < 10 FT	: 2 HRS
> 10 FT, < 20 FT	: 2 HRS
> 20 FT, < 30 FT	: 1 HRS
OVER 30 FT	: 0 HRS

FLAME SPREAD:

WALLS AND CEILING FINISHES: CLASS "C" MINIMUM FOR ALL INTERIOR ROOMS/SPACES - F.B.C. 803.11 & NFPA 101 (LSC)  
INTERIOR FLOOR COVERING: COMPLY WITH THE REQUIREMENTS OF THE DOC-FF-1 "PILL TEST" IN ALL OCCUPANCIES

Project No.  
2022-104  
Drawn By :  
LE  
Checked By  
C W  
Date:  
06.26.2023  
REVISIONS

**DRC**  
PZ23-10000012  
08/16/2023