



Utility Field Operations

Wastewater Pumping
Wastewater Transmission
Stormwater
Water and Reuse Distribution
Phone # (954) 786-4082
Fax # (954) 786-4003

MEMORANDUM # 17-01

DATE: October 27, 2016
TO: Otis Thomas, General Services Director
VIA: A. Randolph Brown, Utilities Director
VIA: Ben Bray, Utilities Field Superintendent
FROM: Bobby Clayton, Wastewater Pumping Supervisor
SUBJECT: Piggyback the Broward County Contract with Trio Development

Issue:

The City's Utility Department recommends piggybacking the Broward County Contract with Trio Development for required repairs to Lift Station 132 (2857 Palm Aire Drive North).

Explanation:

Funding for these repairs are available in account # 420-7345-535-65-12, CIP # 08-968. The City's lift station was determined to have deteriorated discharging piping which conveys wastewater away from the community via force main to the Broward County Treatment Plant. As a result of this unforeseen corrosion it is imperative that repairs be made; thus avoiding environmental hazards associated with a Sanitary Sewer Overflow event, in addition to avoiding State and Regulatory compliance issues.

Recommendation:

The Utility Department recommends approving the use of Broward County Contract Y1180908B1 with Trio Development for the repair services for Lift Station 132.