

Memo

To: Zoning Board of Appeals
From: James Galloway, Fire Inspector
Date: April 28, 2025
Re: Zoning Board of Appeal 25-15000004

Additional Information required for Fire Department to approve proposed site plan for Temporary Use Permit for outdoor Food Truck Court. Site access and fire safety must meet the minimum requirements of NFPA 1 Fire Code; Chapter 18 Access and Chapter 34 Storage.

1. Provide scaled drawing of the proposed Site layout.
2. An operational plan with fire department will be required for this specific operation. How will food trucks be inspected and regulated for operations at this proposed site. Must meet minimum requirements of NFPA 1 Fire Code 2023 Edition Chapter 50 Section 50.8 Mobile and Temporary Cooking Operations and Broward County Local Fire Amendments.

*Additional comments may follow throughout the remainder of the permitting process. The building shall be in compliance with **All** NFPA Standards prior to receiving Fire Department approval.

*Additional comments may follow throughout the remainder of the permitting process. The building shall be in compliance with **All** NFPA Standards prior to receiving Fire Department approval.

CC: Pete McGinnis, Fire Marshal