

# AMERICAN EAGLE FIRE PROTECTION, INC.

4711 North Dixie Highway – Boca Raton, FL 33431

Telephone: 561-750-3698 – Fax: 561-750-8496

LIC # 33490800012003

## FLOW TEST

STATIC PRESSURE (psi)	RESIDUAL PRESSURE (psi)	PITOT PRESSURE (psi)	PITOT FLOW (gpm)	OUTLET SIZE
76	74	60	1298	2.5"

**Address:** 950 N. Powerline Road, Pompano Beach, FL

**Flow Test Date:** Monday, June 27, 2022 at 8:00 a.m – Tuesday, June 28, 2022 at 8:00 a.m

### Sketch of Test Location



*Adam Summers*

6-28-2022

Signature AEFP Representative

Date

**AAC**

PZ22-12000008

11/01/2022

Flow test : 950 N. Powerline Road. Pompano Beach  
Date: 6/27/2022-6/28/2022

