



Florida Department of Transportation

RON DESANTIS
GOVERNOR

3400 West Commercial Boulevard
Fort Lauderdale, FL 33309

JARED W. PERDUE, P.E.
SECRETARY

May 14, 2026

THIS PRE-APPLICATION LETTER IS VALID UNTIL – May 14, 2027
THIS LETTER IS NOT A PERMIT APPROVAL

Paola West
PLANW3ST
10152 Indiantown Road, #159 Jupiter, FL 33478

Dear Paola West:

RE: Pre-Application Review for **Category D Driveway**, Pre-Application Meeting Date: **2/6/2025, 2:00 PM**
Broward County - Pompano Beach; State Road (S.R.) 5; Sec. # 86020000; MP: 7.2; Access Class - 05;
Posted Speed - 45; SIS – N/A; FDOT Ref. Project: N/A

Request:

1. **Proposed ingress-only driveway along the east side of SR 5 located approximately 86 feet from the south property line.**
2. **Proposed right-out only driveway along the east side of SR 5 located approximately 130 feet from the north property line.**

SITE SPECIFIC INFORMATION

Project Name & Address: **Vera Plat, Site Plan – 1600 S Federal Highway Pompano Beach**
Property Owner: **1600 FEDERAL LLC**; Parcel Size: **2.4 Acres**
Development Size: **132 Multifamily Residential Dwelling Units; 85,000 SF Commercial**

REQUEST APPROVED

This decision is based on your presentation of the facts, site plan and survey - please see the conditions and comments below. You may choose to review this concept further with the District Access Management Review Committee (AMRC).

Conditions:

- **A minimum driveway length of 100 feet, as measured from the ultimate right-of-way line to the first conflict point shall be provided.**
- **If a gate is proposed, a minimum driveway length of 100 feet to the call box and/or gate house, and a turnaround area before the gate are required.**
- **Existing southbound left turn lane taper shall meet the standards of the Florida Design Manual (FDM).**
- **Driveways shall be a maximum of 16 feet wide with radial returns. The right-out only driveway shall be channelized.**

Comments:

- All driveways not approved in this letter must be fully removed and the area restored.
- Drainage mitigation is required for any stormwater impacts within FDOT right-of-way (i.e. increased runoff or reduction of existing storage.). The drainage mitigation shall meet all FDOT Drainage Manual criteria and will be reviewed/approved as part of an access permit.
- The applicant shall donate property to the Department if right-of-way dedication is required to implement the improvements.
- Dimensions between driveways are measured from the near edge of pavement to near edge of pavement and for median openings are measured from centerline to centerline unless otherwise indicated.

The purpose of this Pre-Application letter is to document the conceptual review of the approximate location of driveway(s) to the State Highway System and to note required improvements, if any. This letter shall be submitted with any further reviews and for permitting. The Department's personnel shall review permit plans for compliance with this letter as well as current Department standards and/or specifications. Final design must consider the existing roadway profile and any impacts to the existing drainage system. **Note, this letter does not guarantee permit approval.** The permit may be denied based on the review of the submitted engineering plans. Be aware that any approved median openings may be modified (or closed) in the future, at the sole discretion of the Department. For right-of-way dedication requirements go to: <https://osp.fdot.gov>; click on Statewide Permit News; Scroll down to District 4; Scroll down to Additional Information and Examples and choose Right-of-way Donations/Dedications.

Please contact the District Traffic Operations Access Manager - Tel. # 954-777-4363 or e-mail: D4AccessManagement@dot.state.fl.us with any questions regarding the Pre-Approval Letter.

Sincerely,

Roya Edwards, AICP
District Traffic Operations Access Manager

AAC

PZ24-12000027
06/02/2026

cc: Anthony Beecher
File: S:\Transportation Operations\Traffic Operations\Access Management\1. Pre-Apps and Variance\2025-02-06 & AMRC\Pre-App 02 MP 7.30 86020000 Vera Plat Site Plan\Letter Revision 2\Letter Ext\MP 7.30 86020000 SR 5 Vera Plat Site Plan-Rev2.docx

www.fdot.gov | www.d4fdot.com