



Fire Prevention Fire Hydrant Flow Test



City of Pompano Beach • Bureau of Fire Prevention
100 West Atlantic Boulevard, Room 220 Pompano Beach, FL 33060
Phone: (954) 786-4695

City of Pompano Beach Fire Prevention will WITNESS all fire hydrant flow test that are required for fire flow purposes.

- City of Pompano Beach Code of Ordinances Title IX Chapter 95 Section 95.14(G). Fire hydrant flow tests.
 - The Fire Department shall witness all hydrant flow tests as required for fire protection systems.
 - All fire flow tests shall be in accordance with NFPA 291 and Broward County Amendments F-122.
 - Broward County Amendments F-122(e) - The static pressure at the water main shall be determined by a recorded method for a minimum twenty-four (24) hour period.
 - Morning of fire Hydrant static/residue connection contractor to provide documents of test equipment certification.

Information:

Date:	4/5/19
Company Requesting Flow Test:	Summers Fire Sprinklers, Inc.
Contact Name:	Ryan McCallum / Patrick McCallum
Contact Phone Number:	561-393-6718
Email Address:	ryanm@summersfire.com
Associated Application Number:	
Associated Project Name:	BX42437

Proposed Date/Time for Fire Hydrant Flow Test: (8am – 9am)

- Request Hydrant Flow Test minimum 72 hours in advance.
- Connection of Fire Hydrant for 24 hour static/residual must be between 0730hrs and 0830hrs.

Requested Date:	4/15/19	Time:	9:00
Alternate Date:		Time:	

2
4/16/19 Flow

Fire Hydrant Flow Test Location: See Attached Location Sheet

Hydrant Location - Static/Residual:	1873 SW 3 rd St., Pompano Beach, FL 33069
Hydrant Location - Flow:	2103 SW 3 rd St., Pompano Beach, FL 33069

Fire Hydrant Flow Test Witness Fee:

There is a \$150.00 fee for performing each flow test. All tests will be completed within 5 business days. Please include map/sketch showing streets/cross streets & locations of flow and residual fire hydrants. Return flow test application to the Bureau of Fire Prevention with form of payment for \$150.00.

Make check and money orders payable to "CITY OF POMPANO BEACH"
If mailing in application with payment send to the addressed listed below.

Pompano Beach Fire Prevention
100 W. Atlantic Blvd. – Room 220
Pompano Beach, FL 33060
NOTE TO TREASURY: Post to 001-0000-367.30-00

	Yes	No		
Flow Test Equipment Certification:	✓		Date:	4/16/19

H#	Pitot	GPM	Static	Residual	Tip Size
2	50	1192	74	57	2 1/2
Total Hydrant Flow:					

- Fire Flow Data to be completed and entered on site.
- Fire flow data provided to Fire Prevention at a later date, must be signed/sealed by the Engineer of Record.

Ryan McCallum
Person Conducting Flow Test:

Ma
Fire Inspector Witnessing Flow Test:

DRC

DRC


DRC

PZ22-12000036
01/18/23

Google Maps

HYDRANT FLOW TEST #2

HYDRANT LOCATIONS




Imagery ©2019 Google, Map data ©2019 Google 100 ft

DRC

PZ22-12000036
11/02/22

WATER FLOW TEST SUMMARY SHEET

Date:		Time:		Cont. No.	
Cont. Name: ISLES CASINO					
Address: 1873 SW 3RD STREET					
Static Press: 74		psi		Flow @ 20 psi = 2223 gpm	



Flow - Gallons per Minute

MULTIPLY SCALE BY

PRESSURE (PSI)

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

24 HOUR STATIC DATA RECORDER RESULTS

Flow Test #2 for Isles of Casino

2203 SW 3rd Street

4/16/2019

Date	Time	PSI	Volts
4/15/2019	08:30:03	79.12	3.69
4/15/2019	08:31:03	76.77	3.69
4/15/2019	08:32:03	74.64	3.68
4/15/2019	08:33:03	76.32	3.68
4/15/2019	08:34:03	76.66	3.68
4/15/2019	08:35:03	76.88	3.68
4/15/2019	08:36:03	75.87	3.68
4/15/2019	08:37:03	75.76	3.68
4/15/2019	08:38:03	77.89	3.68
4/15/2019	08:39:03	75.42	3.67
4/15/2019	08:40:03	76.99	3.67
4/15/2019	08:41:03	73.07	3.67
4/15/2019	08:42:03	72.73	3.68
4/15/2019	08:43:03	74.41	3.67
4/15/2019	08:44:03	76.77	3.67
4/15/2019	08:45:03	76.77	3.67
4/15/2019	08:46:03	75.09	3.67
4/15/2019	08:47:03	76.77	3.67
4/15/2019	08:48:03	74.3	3.67
4/15/2019	08:49:03	74.86	3.67
4/15/2019	08:50:03	73.41	3.67
4/15/2019	08:51:03	74.97	3.67
4/15/2019	08:52:03	73.52	3.67
4/15/2019	08:53:03	73.74	3.67
4/15/2019	08:54:03	74.3	3.67
4/15/2019	08:55:03	73.41	3.67
4/15/2019	08:56:03	73.29	3.67
4/15/2019	08:57:03	73.29	3.67
4/15/2019	08:58:03	73.97	3.67
4/15/2019	08:59:03	74.08	3.67
4/15/2019	09:00:03	74.19	3.67
4/15/2019	09:01:03	74.41	3.67
4/15/2019	09:02:03	73.18	3.67
4/15/2019	09:03:03	72.62	3.67
4/15/2019	09:04:03	74.97	3.67
4/15/2019	09:05:03	74.41	3.67
4/15/2019	09:06:03	74.97	3.67
4/15/2019	09:07:03	72.51	3.67
4/15/2019	09:08:03	74.64	3.67
4/15/2019	09:09:03	74.3	3.67
4/15/2019	09:10:03	74.86	3.67
4/15/2019	09:11:03	74.19	3.67
4/15/2019	09:12:03	74.53	3.67
4/15/2019	09:13:03	75.54	3.67
4/15/2019	09:14:03	73.07	3.67
4/15/2019	09:15:03	73.97	3.67
4/15/2019	09:16:03	75.2	3.67
4/15/2019	09:17:03	78.11	3.67
4/15/2019	09:18:03	74.64	3.67
4/15/2019	09:19:03	75.42	3.67
4/15/2019	09:20:03	73.07	3.67
4/15/2019	09:21:03	75.2	3.67
4/15/2019	09:22:03	75.76	3.67
4/15/2019	09:23:03	76.77	3.67
4/15/2019	09:24:03	76.32	3.67
4/15/2019	09:25:03	74.53	3.67
4/15/2019	09:26:03	73.74	3.67
4/15/2019	09:27:03	75.76	3.67

DRC

PZ22-12000036

01/18/23

DRC

PZ22-12000036

11/02/22

4/15/2019	09:28:03	76.99	3.67
4/15/2019	09:29:03	74.64	3.67
4/15/2019	09:30:03	74.08	3.67
4/15/2019	09:31:03	73.74	3.67
4/15/2019	09:32:03	74.19	3.67
4/15/2019	09:33:03	73.41	3.67
4/15/2019	09:34:03	75.09	3.67
4/15/2019	09:35:03	75.54	3.68
4/15/2019	09:36:03	74.64	3.67
4/15/2019	09:37:03	75.09	3.68
4/15/2019	09:38:03	75.2	3.68
4/15/2019	09:39:03	75.2	3.67
4/15/2019	09:40:03	74.53	3.67
4/15/2019	09:41:03	73.97	3.68
4/15/2019	09:42:03	74.3	3.67
4/15/2019	09:43:03	73.74	3.68
4/15/2019	09:44:03	72.96	3.68
4/15/2019	09:45:03	74.3	3.68
4/15/2019	09:46:03	73.63	3.68
4/15/2019	09:47:03	76.43	3.68
4/15/2019	09:48:03	75.31	3.68
4/15/2019	09:49:03	75.42	3.68
4/15/2019	09:50:03	75.76	3.68
4/15/2019	09:51:03	71.39	3.68
4/15/2019	09:52:03	75.54	3.68
4/15/2019	09:53:03	74.64	3.68
4/15/2019	09:54:03	76.1	3.68
4/15/2019	09:55:03	75.09	3.68
4/15/2019	09:56:03	77.44	3.68
4/15/2019	09:57:03	76.77	3.68
4/15/2019	09:58:03	75.09	3.68
4/15/2019	09:59:03	75.31	3.68
4/15/2019	10:00:03	76.32	3.68
4/15/2019	10:01:03	75.76	3.68
4/15/2019	10:02:03	74.97	3.68
4/15/2019	10:03:03	76.88	3.68
4/15/2019	10:04:03	74.64	3.68
4/15/2019	10:05:03	73.52	3.68
4/15/2019	10:06:03	74.41	3.68
4/15/2019	10:07:03	75.09	3.68
4/15/2019	10:08:03	74.75	3.68
4/15/2019	10:09:03	74.08	3.68
4/15/2019	10:10:03	74.75	3.68
4/15/2019	10:11:03	75.2	3.68
4/15/2019	10:12:03	73.85	3.68
4/15/2019	10:13:03	74.19	3.68
4/15/2019	10:14:03	77.22	3.68
4/15/2019	10:15:03	74.64	3.68
4/15/2019	10:16:03	73.18	3.68
4/15/2019	10:17:03	75.42	3.68
4/15/2019	10:18:03	75.65	3.68
4/15/2019	10:19:03	74.97	3.68
4/15/2019	10:20:03	74.3	3.68
4/15/2019	10:21:03	73.18	3.68
4/15/2019	10:22:03	74.3	3.68
4/15/2019	10:23:03	76.77	3.68
4/15/2019	10:24:03	77.33	3.68
4/15/2019	10:25:03	76.66	3.68
4/15/2019	10:26:03	75.09	3.68
4/15/2019	10:27:03	75.31	3.68
4/15/2019	10:28:03	75.87	3.68
4/15/2019	10:29:03	74.75	3.68

DRC

PZ22-12000036

01/18/23

DRC

PZ22-12000036

11/02/22

4/15/2019	10:30:03	76.1	3.68
4/15/2019	10:31:03	75.31	3.68
4/15/2019	10:32:03	74.19	3.68
4/15/2019	10:33:03	74.64	3.69
4/15/2019	10:34:03	75.09	3.68
4/15/2019	10:35:03	75.76	3.69
4/15/2019	10:36:03	72.85	3.69
4/15/2019	10:37:03	74.19	3.68
4/15/2019	10:38:03	74.3	3.69
4/15/2019	10:39:03	74.53	3.69
4/15/2019	10:40:03	75.31	3.69
4/15/2019	10:41:03	73.41	3.69
4/15/2019	10:42:03	71.95	3.69
4/15/2019	10:43:03	75.31	3.69
4/15/2019	10:44:03	74.3	3.69
4/15/2019	10:45:03	74.41	3.69
4/15/2019	10:46:03	74.41	3.69
4/15/2019	10:47:03	73.74	3.69
4/15/2019	10:48:03	73.97	3.69
4/15/2019	10:49:03	73.29	3.69
4/15/2019	10:50:03	73.29	3.69
4/15/2019	10:51:03	73.29	3.69
4/15/2019	10:52:03	74.75	3.69
4/15/2019	10:53:03	73.97	3.69
4/15/2019	10:54:03	73.97	3.69
4/15/2019	10:55:03	74.3	3.69
4/15/2019	10:56:03	74.41	3.69
4/15/2019	10:57:03	73.97	3.69
4/15/2019	10:58:03	74.97	3.69
4/15/2019	10:59:03	75.98	3.69
4/15/2019	11:00:03	74.75	3.69
4/15/2019	11:01:03	74.3	3.69
4/15/2019	11:02:03	74.08	3.69
4/15/2019	11:03:03	76.88	3.69
4/15/2019	11:04:03	75.2	3.69
4/15/2019	11:05:03	76.1	3.69
4/15/2019	11:06:03	72.62	3.69
4/15/2019	11:07:03	73.29	3.69
4/15/2019	11:08:03	73.18	3.69
4/15/2019	11:09:03	75.2	3.69
4/15/2019	11:10:03	74.64	3.69
4/15/2019	11:11:03	73.29	3.69
4/15/2019	11:12:03	76.1	3.69
4/15/2019	11:13:03	75.65	3.69
4/15/2019	11:14:03	75.31	3.69
4/15/2019	11:15:03	75.65	3.69
4/15/2019	11:16:03	76.21	3.69
4/15/2019	11:17:03	75.31	3.69
4/15/2019	11:18:03	73.07	3.69
4/15/2019	11:19:03	73.41	3.69
4/15/2019	11:20:03	75.98	3.69
4/15/2019	11:21:03	73.18	3.69
4/15/2019	11:22:03	75.2	3.69
4/15/2019	11:23:03	74.08	3.69
4/15/2019	11:24:03	73.74	3.69
4/15/2019	11:25:03	73.85	3.69
4/15/2019	11:26:03	73.18	3.69
4/15/2019	11:27:03	74.64	3.69
4/15/2019	11:28:03	73.52	3.69
4/15/2019	11:29:03	74.53	3.69
4/15/2019	11:30:03	75.98	3.69
4/15/2019	11:31:03	74.3	3.69

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/15/2019	11:32:03	72.28	3.69
4/15/2019	11:33:03	73.74	3.69
4/15/2019	11:34:03	75.54	3.69
4/15/2019	11:35:03	72.85	3.69
4/15/2019	11:36:03	74.53	3.69
4/15/2019	11:37:03	72.62	3.69
4/15/2019	11:38:03	72.06	3.69
4/15/2019	11:39:03	74.41	3.69
4/15/2019	11:40:03	74.08	3.69
4/15/2019	11:41:03	73.52	3.69
4/15/2019	11:42:03	74.19	3.69
4/15/2019	11:43:03	74.08	3.69
4/15/2019	11:44:03	72.73	3.69
4/15/2019	11:45:03	75.87	3.69
4/15/2019	11:46:03	74.64	3.69
4/15/2019	11:47:03	74.97	3.69
4/15/2019	11:48:03	73.85	3.69
4/15/2019	11:49:03	74.19	3.69
4/15/2019	11:50:03	73.74	3.69
4/15/2019	11:51:03	74.19	3.69
4/15/2019	11:52:03	74.97	3.69
4/15/2019	11:53:03	75.76	3.69
4/15/2019	11:54:03	74.41	3.69
4/15/2019	11:55:03	73.74	3.69
4/15/2019	11:56:03	74.41	3.69
4/15/2019	11:57:03	74.3	3.69
4/15/2019	11:58:03	75.31	3.69
4/15/2019	11:59:03	76.21	3.69
4/15/2019	12:00:03	75.98	3.69
4/15/2019	12:01:03	74.75	3.69
4/15/2019	12:02:03	73.63	3.69
4/15/2019	12:03:03	75.09	3.69
4/15/2019	12:04:03	73.29	3.69
4/15/2019	12:05:03	76.21	3.69
4/15/2019	12:06:03	75.54	3.69
4/15/2019	12:07:03	72.73	3.69
4/15/2019	12:08:03	74.41	3.69
4/15/2019	12:09:03	77.22	3.69
4/15/2019	12:10:03	76.32	3.69
4/15/2019	12:11:03	75.54	3.69
4/15/2019	12:12:03	76.32	3.69
4/15/2019	12:13:03	73.97	3.69
4/15/2019	12:14:03	75.76	3.69
4/15/2019	12:15:03	76.32	3.69
4/15/2019	12:16:03	76.1	3.69
4/15/2019	12:17:03	77.33	3.69
4/15/2019	12:18:03	75.31	3.69
4/15/2019	12:19:03	75.09	3.69
4/15/2019	12:20:03	75.87	3.69
4/15/2019	12:21:03	76.88	3.69
4/15/2019	12:22:03	74.97	3.69
4/15/2019	12:23:03	76.88	3.69
4/15/2019	12:24:03	73.97	3.69
4/15/2019	12:25:03	75.09	3.69
4/15/2019	12:26:03	76.66	3.69
4/15/2019	12:27:03	75.65	3.69
4/15/2019	12:28:03	75.76	3.69
4/15/2019	12:29:03	76.43	3.69
4/15/2019	12:30:03	75.31	3.69
4/15/2019	12:31:03	73.41	3.69
4/15/2019	12:32:03	75.54	3.69
4/15/2019	12:33:03	75.76	3.69

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/15/2019 12:34:03	77.1	3.69
4/15/2019 12:35:03	74.41	3.69
4/15/2019 12:36:03	74.19	3.69
4/15/2019 12:37:03	76.77	3.69
4/15/2019 12:38:03	77.1	3.69
4/15/2019 12:39:03	76.88	3.69
4/15/2019 12:40:03	77.1	3.69
4/15/2019 12:41:03	77.22	3.69
4/15/2019 12:42:03	76.1	3.69
4/15/2019 12:43:03	76.1	3.69
4/15/2019 12:44:03	76.21	3.69
4/15/2019 12:45:03	76.1	3.69
4/15/2019 12:46:03	77.1	3.69
4/15/2019 12:47:03	76.21	3.69
4/15/2019 12:48:03	77.55	3.69
4/15/2019 12:49:03	77.1	3.69
4/15/2019 12:50:03	77.33	3.69
4/15/2019 12:51:03	76.88	3.69
4/15/2019 12:52:03	77.1	3.69
4/15/2019 12:53:03	75.87	3.69
4/15/2019 12:54:03	76.32	3.7
4/15/2019 12:55:03	75.98	3.69
4/15/2019 12:56:03	76.77	3.7
4/15/2019 12:57:03	76.1	3.69
4/15/2019 12:58:03	75.98	3.69
4/15/2019 12:59:03	75.76	3.69
4/15/2019 13:00:03	77.1	3.69
4/15/2019 13:01:03	78	3.69
4/15/2019 13:02:03	75.76	3.69
4/15/2019 13:03:03	76.54	3.7
4/15/2019 13:04:03	77.22	3.69
4/15/2019 13:05:03	77.44	3.69
4/15/2019 13:06:03	76.43	3.69
4/15/2019 13:07:03	76.21	3.69
4/15/2019 13:08:03	76.1	3.69
4/15/2019 13:09:03	77.22	3.69
4/15/2019 13:10:03	76.43	3.69
4/15/2019 13:11:03	77.1	3.69
4/15/2019 13:12:03	72.85	3.69
4/15/2019 13:13:03	76.88	3.69
4/15/2019 13:14:03	75.42	3.69
4/15/2019 13:15:03	75.65	3.69
4/15/2019 13:16:03	75.2	3.69
4/15/2019 13:17:03	74.97	3.69
4/15/2019 13:18:03	77.1	3.69
4/15/2019 13:19:03	77.67	3.7
4/15/2019 13:20:03	76.88	3.69
4/15/2019 13:21:03	77.1	3.69
4/15/2019 13:22:03	77.55	3.7
4/15/2019 13:23:03	75.54	3.7
4/15/2019 13:24:03	75.87	3.69
4/15/2019 13:25:03	75.2	3.69
4/15/2019 13:26:03	76.54	3.69
4/15/2019 13:27:03	76.88	3.69
4/15/2019 13:28:03	76.32	3.69
4/15/2019 13:29:03	77.33	3.69
4/15/2019 13:30:03	77.44	3.69
4/15/2019 13:31:03	77.1	3.69
4/15/2019 13:32:03	76.43	3.69
4/15/2019 13:33:03	75.31	3.69
4/15/2019 13:34:03	75.65	3.69
4/15/2019 13:35:03	76.77	3.69

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/15/2019 13:36:03	75.76	3.69
4/15/2019 13:37:03	77.44	3.69
4/15/2019 13:38:03	76.1	3.69
4/15/2019 13:39:03	76.54	3.7
4/15/2019 13:40:03	77.22	3.69
4/15/2019 13:41:03	76.88	3.69
4/15/2019 13:42:03	72.4	3.69
4/15/2019 13:43:03	75.2	3.69
4/15/2019 13:44:03	75.76	3.69
4/15/2019 13:45:03	76.1	3.69
4/15/2019 13:46:03	77.55	3.69
4/15/2019 13:47:03	77.22	3.69
4/15/2019 13:48:03	77.55	3.69
4/15/2019 13:49:03	77.44	3.69
4/15/2019 13:50:03	77.1	3.69
4/15/2019 13:51:03	77.55	3.69
4/15/2019 13:52:03	75.98	3.69
4/15/2019 13:53:03	76.77	3.69
4/15/2019 13:54:03	75.98	3.69
4/15/2019 13:55:03	76.77	3.69
4/15/2019 13:56:03	76.66	3.7
4/15/2019 13:57:03	77.67	3.7
4/15/2019 13:58:03	76.43	3.69
4/15/2019 13:59:03	75.2	3.7
4/15/2019 14:00:03	76.77	3.7
4/15/2019 14:01:03	76.54	3.69
4/15/2019 14:02:03	76.43	3.69
4/15/2019 14:03:03	74.41	3.7
4/15/2019 14:04:03	77.89	3.69
4/15/2019 14:05:03	76.99	3.7
4/15/2019 14:06:03	76.32	3.69
4/15/2019 14:07:03	77.22	3.7
4/15/2019 14:08:03	77.33	3.69
4/15/2019 14:09:03	77.78	3.69
4/15/2019 14:10:03	76.99	3.69
4/15/2019 14:11:03	77.22	3.69
4/15/2019 14:12:03	74.86	3.7
4/15/2019 14:13:03	75.65	3.7
4/15/2019 14:14:03	75.87	3.7
4/15/2019 14:15:03	77.78	3.69
4/15/2019 14:16:03	76.88	3.69
4/15/2019 14:17:03	76.43	3.69
4/15/2019 14:18:03	72.85	3.7
4/15/2019 14:19:03	74.75	3.69
4/15/2019 14:20:03	75.31	3.69
4/15/2019 14:21:03	77.55	3.69
4/15/2019 14:22:03	77.1	3.69
4/15/2019 14:23:03	76.32	3.69
4/15/2019 14:24:03	75.65	3.69
4/15/2019 14:25:03	76.99	3.69
4/15/2019 14:26:03	75.76	3.69
4/15/2019 14:27:03	78	3.69
4/15/2019 14:28:03	76.32	3.69
4/15/2019 14:29:03	75.42	3.69
4/15/2019 14:30:03	77.44	3.7
4/15/2019 14:31:03	77.44	3.69
4/15/2019 14:32:03	77.1	3.69
4/15/2019 14:33:03	76.21	3.69
4/15/2019 14:34:03	77.55	3.7
4/15/2019 14:35:03	75.76	3.69
4/15/2019 14:36:03	77.22	3.69
4/15/2019 14:37:03	76.77	3.69

DRC

PZ22-12000036

01/18/23

DRC

PZ22-12000036

11/02/22

4/15/2019	14:38:03	77.78	3.69
4/15/2019	14:39:03	75.98	3.69
4/15/2019	14:40:03	76.32	3.69
4/15/2019	14:41:03	76.43	3.7
4/15/2019	14:42:03	76.32	3.69
4/15/2019	14:43:03	76.88	3.69
4/15/2019	14:44:03	76.43	3.7
4/15/2019	14:45:03	76.43	3.69
4/15/2019	14:46:03	77.22	3.69
4/15/2019	14:47:03	76.88	3.69
4/15/2019	14:48:03	75.54	3.7
4/15/2019	14:49:03	75.65	3.7
4/15/2019	14:50:03	77.1	3.7
4/15/2019	14:51:03	77.33	3.69
4/15/2019	14:52:03	77.44	3.7
4/15/2019	14:53:03	76.21	3.69
4/15/2019	14:54:03	77.33	3.7
4/15/2019	14:55:03	76.88	3.7
4/15/2019	14:56:03	77.1	3.7
4/15/2019	14:57:03	76.21	3.7
4/15/2019	14:58:03	76.77	3.7
4/15/2019	14:59:03	76.77	3.7
4/15/2019	15:00:03	77.44	3.7
4/15/2019	15:01:03	77.67	3.7
4/15/2019	15:02:03	77.44	3.7
4/15/2019	15:03:03	77.1	3.7
4/15/2019	15:04:03	77.44	3.7
4/15/2019	15:05:03	77.67	3.7
4/15/2019	15:06:03	76.1	3.7
4/15/2019	15:07:03	76.99	3.7
4/15/2019	15:08:03	76.54	3.7
4/15/2019	15:09:03	76.77	3.7
4/15/2019	15:10:03	78.11	3.7
4/15/2019	15:11:03	76.88	3.7
4/15/2019	15:12:03	77.22	3.7
4/15/2019	15:13:03	76.1	3.7
4/15/2019	15:14:03	75.42	3.7
4/15/2019	15:15:03	76.66	3.7
4/15/2019	15:16:03	76.21	3.7
4/15/2019	15:17:03	75.31	3.7
4/15/2019	15:18:03	76.21	3.7
4/15/2019	15:19:03	75.87	3.7
4/15/2019	15:20:03	76.88	3.7
4/15/2019	15:21:03	77.55	3.7
4/15/2019	15:22:03	77.33	3.7
4/15/2019	15:23:03	76.54	3.7
4/15/2019	15:24:03	76.43	3.7
4/15/2019	15:25:03	75.54	3.7
4/15/2019	15:26:03	76.99	3.7
4/15/2019	15:27:03	77.22	3.7
4/15/2019	15:28:03	76.99	3.7
4/15/2019	15:29:03	76.1	3.7
4/15/2019	15:30:03	76.66	3.7
4/15/2019	15:31:03	76.77	3.7
4/15/2019	15:32:03	76.88	3.7
4/15/2019	15:33:03	77.1	3.7
4/15/2019	15:34:03	76.66	3.7
4/15/2019	15:35:03	76.43	3.7
4/15/2019	15:36:03	77.22	3.7
4/15/2019	15:37:03	76.88	3.7
4/15/2019	15:38:03	76.21	3.7
4/15/2019	15:39:03	77.1	3.7

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/15/2019	15:40:03	76.99	3.7
4/15/2019	15:41:03	74.3	3.7
4/15/2019	15:42:03	76.32	3.7
4/15/2019	15:43:03	77.33	3.7
4/15/2019	15:44:03	77.67	3.7
4/15/2019	15:45:03	75.2	3.7
4/15/2019	15:46:03	76.99	3.7
4/15/2019	15:47:03	77.22	3.7
4/15/2019	15:48:03	77.33	3.7
4/15/2019	15:49:03	76.32	3.7
4/15/2019	15:50:03	74.41	3.7
4/15/2019	15:51:03	75.98	3.7
4/15/2019	15:52:03	76.32	3.7
4/15/2019	15:53:03	76.1	3.7
4/15/2019	15:54:03	77.44	3.7
4/15/2019	15:55:03	74.19	3.7
4/15/2019	15:56:03	77.1	3.7
4/15/2019	15:57:03	76.32	3.7
4/15/2019	15:58:03	77.55	3.7
4/15/2019	15:59:03	76.77	3.7
4/15/2019	16:00:03	77.22	3.7
4/15/2019	16:01:03	77.33	3.7
4/15/2019	16:02:03	76.88	3.7
4/15/2019	16:03:03	76.88	3.7
4/15/2019	16:04:03	76.21	3.7
4/15/2019	16:05:03	76.43	3.7
4/15/2019	16:06:03	77.1	3.7
4/15/2019	16:07:03	77.22	3.7
4/15/2019	16:08:03	76.88	3.7
4/15/2019	16:09:03	75.98	3.7
4/15/2019	16:10:03	77.78	3.7
4/15/2019	16:11:03	77.22	3.7
4/15/2019	16:12:03	77.1	3.7
4/15/2019	16:13:03	77.44	3.7
4/15/2019	16:14:03	74.97	3.7
4/15/2019	16:15:03	76.88	3.7
4/15/2019	16:16:03	74.3	3.7
4/15/2019	16:17:03	76.66	3.7
4/15/2019	16:18:03	77.1	3.7
4/15/2019	16:19:03	76.32	3.7
4/15/2019	16:20:03	76.54	3.7
4/15/2019	16:21:03	74.64	3.7
4/15/2019	16:22:03	75.87	3.7
4/15/2019	16:23:03	76.99	3.7
4/15/2019	16:24:03	76.1	3.7
4/15/2019	16:25:03	75.31	3.7
4/15/2019	16:26:03	73.29	3.7
4/15/2019	16:27:03	76.32	3.7
4/15/2019	16:28:03	76.77	3.7
4/15/2019	16:29:03	76.21	3.7
4/15/2019	16:30:03	76.88	3.7
4/15/2019	16:31:03	76.99	3.7
4/15/2019	16:32:03	77.33	3.7
4/15/2019	16:33:03	76.88	3.7
4/15/2019	16:34:03	74.86	3.7
4/15/2019	16:35:03	76.54	3.7
4/15/2019	16:36:03	76.21	3.7
4/15/2019	16:37:03	76.66	3.7
4/15/2019	16:38:03	76.43	3.7
4/15/2019	16:39:03	77.67	3.7
4/15/2019	16:40:03	77.55	3.7
4/15/2019	16:41:03	76.21	3.7

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/15/2019	16:42:03	76.21	3.7
4/15/2019	16:43:03	77.1	3.7
4/15/2019	16:44:03	76.43	3.7
4/15/2019	16:45:03	77.55	3.7
4/15/2019	16:46:03	76.77	3.7
4/15/2019	16:47:03	76.54	3.7
4/15/2019	16:48:03	76.43	3.7
4/15/2019	16:49:03	76.54	3.7
4/15/2019	16:50:03	76.88	3.7
4/15/2019	16:51:03	76.99	3.7
4/15/2019	16:52:03	74.3	3.7
4/15/2019	16:53:03	77.67	3.7
4/15/2019	16:54:03	77.22	3.7
4/15/2019	16:55:03	75.09	3.7
4/15/2019	16:56:03	77.78	3.7
4/15/2019	16:57:03	75.87	3.7
4/15/2019	16:58:03	77.22	3.7
4/15/2019	16:59:03	76.32	3.7
4/15/2019	17:00:03	76.21	3.7
4/15/2019	17:01:03	76.21	3.7
4/15/2019	17:02:03	76.88	3.7
4/15/2019	17:03:03	76.66	3.7
4/15/2019	17:04:03	76.88	3.7
4/15/2019	17:05:03	75.98	3.7
4/15/2019	17:06:03	75.09	3.7
4/15/2019	17:07:03	76.1	3.7
4/15/2019	17:08:03	75.87	3.7
4/15/2019	17:09:03	76.32	3.7
4/15/2019	17:10:03	76.43	3.7
4/15/2019	17:11:03	76.99	3.7
4/15/2019	17:12:03	76.32	3.7
4/15/2019	17:13:03	75.42	3.7
4/15/2019	17:14:03	76.21	3.7
4/15/2019	17:15:03	75.87	3.7
4/15/2019	17:16:03	76.21	3.7
4/15/2019	17:17:03	76.88	3.7
4/15/2019	17:18:03	74.97	3.7
4/15/2019	17:19:03	75.09	3.7
4/15/2019	17:20:03	73.97	3.7
4/15/2019	17:21:03	73.85	3.7
4/15/2019	17:22:03	75.54	3.7
4/15/2019	17:23:03	74.41	3.7
4/15/2019	17:24:03	75.87	3.7
4/15/2019	17:25:03	74.97	3.7
4/15/2019	17:26:03	75.87	3.7
4/15/2019	17:27:03	76.32	3.7
4/15/2019	17:28:03	76.32	3.7
4/15/2019	17:29:03	75.87	3.7
4/15/2019	17:30:03	75.87	3.7
4/15/2019	17:31:03	72.73	3.7
4/15/2019	17:32:03	73.29	3.7
4/15/2019	17:33:03	76.54	3.7
4/15/2019	17:34:03	75.76	3.7
4/15/2019	17:35:03	76.99	3.7
4/15/2019	17:36:03	74.75	3.7
4/15/2019	17:37:03	76.21	3.7
4/15/2019	17:38:03	76.88	3.7
4/15/2019	17:39:03	76.99	3.7
4/15/2019	17:40:03	76.32	3.7
4/15/2019	17:41:03	76.88	3.7
4/15/2019	17:42:03	76.77	3.7
4/15/2019	17:43:03	75.98	3.7

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/15/2019 17:44:03	77.89	3.7
4/15/2019 17:45:03	75.42	3.7
4/15/2019 17:46:03	74.75	3.7
4/15/2019 17:47:03	76.32	3.7
4/15/2019 17:48:03	76.99	3.7
4/15/2019 17:49:03	75.2	3.7
4/15/2019 17:50:03	77.1	3.7
4/15/2019 17:51:03	76.99	3.7
4/15/2019 17:52:03	75.98	3.7
4/15/2019 17:53:03	76.32	3.7
4/15/2019 17:54:03	76.1	3.7
4/15/2019 17:55:03	76.54	3.7
4/15/2019 17:56:03	76.66	3.7
4/15/2019 17:57:03	74.19	3.7
4/15/2019 17:58:03	76.21	3.7
4/15/2019 17:59:03	75.09	3.7
4/15/2019 18:00:03	75.42	3.7
4/15/2019 18:01:03	75.2	3.7
4/15/2019 18:02:03	74.75	3.69
4/15/2019 18:03:03	75.54	3.7
4/15/2019 18:04:03	76.88	3.7
4/15/2019 18:05:03	76.88	3.7
4/15/2019 18:06:03	77.44	3.7
4/15/2019 18:07:03	75.54	3.7
4/15/2019 18:08:03	75.54	3.7
4/15/2019 18:09:03	76.54	3.7
4/15/2019 18:10:03	75.65	3.7
4/15/2019 18:11:03	74.64	3.7
4/15/2019 18:12:03	72.73	3.7
4/15/2019 18:13:03	77.67	3.69
4/15/2019 18:14:03	76.32	3.7
4/15/2019 18:15:03	76.32	3.69
4/15/2019 18:16:03	75.09	3.69
4/15/2019 18:17:03	73.41	3.69
4/15/2019 18:18:03	76.1	3.69
4/15/2019 18:19:03	76.88	3.69
4/15/2019 18:20:03	75.98	3.69
4/15/2019 18:21:03	74.86	3.69
4/15/2019 18:22:03	76.99	3.7
4/15/2019 18:23:03	72.28	3.69
4/15/2019 18:24:03	74.3	3.69
4/15/2019 18:25:03	74.97	3.69
4/15/2019 18:26:03	74.75	3.69
4/15/2019 18:27:03	76.88	3.69
4/15/2019 18:28:03	75.09	3.69
4/15/2019 18:29:03	72.85	3.69
4/15/2019 18:30:03	75.98	3.69
4/15/2019 18:31:03	75.31	3.69
4/15/2019 18:32:03	75.65	3.69
4/15/2019 18:33:03	72.85	3.69
4/15/2019 18:34:03	76.1	3.69
4/15/2019 18:35:03	75.76	3.69
4/15/2019 18:36:03	75.76	3.69
4/15/2019 18:37:03	76.1	3.69
4/15/2019 18:38:03	76.21	3.69
4/15/2019 18:39:03	77.1	3.69
4/15/2019 18:40:03	77.33	3.69
4/15/2019 18:41:03	76.99	3.69
4/15/2019 18:42:03	75.42	3.69
4/15/2019 18:43:03	76.43	3.69
4/15/2019 18:44:03	76.21	3.69
4/15/2019 18:45:03	76.21	3.69

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/15/2019	18:46:03	76.88	3.69
4/15/2019	18:47:03	75.76	3.69
4/15/2019	18:48:03	76.54	3.69
4/15/2019	18:49:03	75.65	3.69
4/15/2019	18:50:03	76.54	3.69
4/15/2019	18:51:03	77.22	3.69
4/15/2019	18:52:03	77.89	3.69
4/15/2019	18:53:03	77.55	3.69
4/15/2019	18:54:03	76.88	3.69
4/15/2019	18:55:03	77.67	3.69
4/15/2019	18:56:03	75.09	3.69
4/15/2019	18:57:03	76.1	3.69
4/15/2019	18:58:03	74.41	3.69
4/15/2019	18:59:03	76.32	3.69
4/15/2019	19:00:03	76.99	3.69
4/15/2019	19:01:03	76.32	3.69
4/15/2019	19:02:03	77.22	3.69
4/15/2019	19:03:03	75.87	3.69
4/15/2019	19:04:03	75.87	3.69
4/15/2019	19:05:03	77.22	3.69
4/15/2019	19:06:03	76.1	3.69
4/15/2019	19:07:03	75.87	3.69
4/15/2019	19:08:03	76.43	3.69
4/15/2019	19:09:03	76.1	3.69
4/15/2019	19:10:03	76.43	3.69
4/15/2019	19:11:03	75.65	3.69
4/15/2019	19:12:03	75.87	3.69
4/15/2019	19:13:03	77.22	3.69
4/15/2019	19:14:03	75.98	3.69
4/15/2019	19:15:03	76.43	3.69
4/15/2019	19:16:03	75.87	3.69
4/15/2019	19:17:03	76.43	3.69
4/15/2019	19:18:03	77.44	3.69
4/15/2019	19:19:03	76.54	3.69
4/15/2019	19:20:03	76.66	3.69
4/15/2019	19:21:03	76.54	3.69
4/15/2019	19:22:03	76.21	3.69
4/15/2019	19:23:03	76.43	3.69
4/15/2019	19:24:03	75.65	3.69
4/15/2019	19:25:03	75.54	3.69
4/15/2019	19:26:03	76.88	3.69
4/15/2019	19:27:03	77.33	3.69
4/15/2019	19:28:03	76.66	3.69
4/15/2019	19:29:03	76.43	3.69
4/15/2019	19:30:03	75.31	3.69
4/15/2019	19:31:03	75.87	3.69
4/15/2019	19:32:03	75.65	3.69
4/15/2019	19:33:03	74.19	3.69
4/15/2019	19:34:03	77.78	3.69
4/15/2019	19:35:03	77.67	3.69
4/15/2019	19:36:03	77.55	3.69
4/15/2019	19:37:03	76.21	3.69
4/15/2019	19:38:03	77.55	3.69
4/15/2019	19:39:03	76.66	3.69
4/15/2019	19:40:03	75.87	3.69
4/15/2019	19:41:03	76.32	3.69
4/15/2019	19:42:03	76.54	3.69
4/15/2019	19:43:03	77.44	3.69
4/15/2019	19:44:03	75.87	3.69
4/15/2019	19:45:03	75.2	3.69
4/15/2019	19:46:03	76.99	3.69
4/15/2019	19:47:03	75.76	3.69

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/15/2019	19:48:03	75.09	3.69
4/15/2019	19:49:03	76.32	3.69
4/15/2019	19:50:03	75.98	3.69
4/15/2019	19:51:03	77.55	3.69
4/15/2019	19:52:03	77.44	3.69
4/15/2019	19:53:03	77.1	3.69
4/15/2019	19:54:03	75.98	3.69
4/15/2019	19:55:03	78.34	3.69
4/15/2019	19:56:03	77.33	3.69
4/15/2019	19:57:03	77.44	3.69
4/15/2019	19:58:03	76.77	3.69
4/15/2019	19:59:03	77.44	3.69
4/15/2019	20:00:03	76.88	3.69
4/15/2019	20:01:03	76.66	3.69
4/15/2019	20:02:03	76.43	3.69
4/15/2019	20:03:03	75.98	3.69
4/15/2019	20:04:03	76.77	3.69
4/15/2019	20:05:03	74.3	3.69
4/15/2019	20:06:03	77.89	3.69
4/15/2019	20:07:03	77.89	3.69
4/15/2019	20:08:03	75.2	3.69
4/15/2019	20:09:03	77.78	3.69
4/15/2019	20:10:03	77.44	3.69
4/15/2019	20:11:03	77.67	3.69
4/15/2019	20:12:03	75.09	3.69
4/15/2019	20:13:03	77.78	3.69
4/15/2019	20:14:03	77.89	3.69
4/15/2019	20:15:03	77.1	3.69
4/15/2019	20:16:03	77.89	3.69
4/15/2019	20:17:03	75.76	3.69
4/15/2019	20:18:03	76.54	3.69
4/15/2019	20:19:03	76.88	3.69
4/15/2019	20:20:03	77.33	3.69
4/15/2019	20:21:03	75.65	3.69
4/15/2019	20:22:03	73.63	3.69
4/15/2019	20:23:03	76.88	3.69
4/15/2019	20:24:03	76.99	3.69
4/15/2019	20:25:03	77.44	3.69
4/15/2019	20:26:03	76.43	3.68
4/15/2019	20:27:03	76.43	3.69
4/15/2019	20:28:03	77.1	3.69
4/15/2019	20:29:03	77.1	3.68
4/15/2019	20:30:03	78.34	3.68
4/15/2019	20:31:03	77.78	3.69
4/15/2019	20:32:03	77.44	3.68
4/15/2019	20:33:03	76.88	3.68
4/15/2019	20:34:03	76.32	3.69
4/15/2019	20:35:03	76.1	3.69
4/15/2019	20:36:03	77.22	3.68
4/15/2019	20:37:03	77.1	3.69
4/15/2019	20:38:03	77.44	3.68
4/15/2019	20:39:03	76.99	3.68
4/15/2019	20:40:03	78.34	3.68
4/15/2019	20:41:03	78.23	3.68
4/15/2019	20:42:03	77.33	3.68
4/15/2019	20:43:03	78	3.68
4/15/2019	20:44:03	77.44	3.68
4/15/2019	20:45:03	78.11	3.68
4/15/2019	20:46:03	75.98	3.68
4/15/2019	20:47:03	76.88	3.68
4/15/2019	20:48:03	75.31	3.68
4/15/2019	20:49:03	75.65	3.68

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/15/2019	20:50:03	75.65	3.68
4/15/2019	20:51:03	76.21	3.68
4/15/2019	20:52:03	76.32	3.68
4/15/2019	20:53:03	76.1	3.68
4/15/2019	20:54:03	78.34	3.68
4/15/2019	20:55:03	76.77	3.68
4/15/2019	20:56:03	74.97	3.68
4/15/2019	20:57:03	75.98	3.68
4/15/2019	20:58:03	78.11	3.68
4/15/2019	20:59:03	78.67	3.68
4/15/2019	21:00:03	77.55	3.68
4/15/2019	21:01:03	77.89	3.68
4/15/2019	21:02:03	73.97	3.68
4/15/2019	21:03:03	76.43	3.68
4/15/2019	21:04:03	76.77	3.68
4/15/2019	21:05:03	77.44	3.68
4/15/2019	21:06:03	76.54	3.68
4/15/2019	21:07:03	77.1	3.68
4/15/2019	21:08:03	75.42	3.68
4/15/2019	21:09:03	77.55	3.68
4/15/2019	21:10:03	77.55	3.68
4/15/2019	21:11:03	78.23	3.68
4/15/2019	21:12:03	78.45	3.68
4/15/2019	21:13:03	77.1	3.68
4/15/2019	21:14:03	78.56	3.68
4/15/2019	21:15:03	77.22	3.68
4/15/2019	21:16:03	77.89	3.68
4/15/2019	21:17:03	78.23	3.68
4/15/2019	21:18:03	77.44	3.68
4/15/2019	21:19:03	76.66	3.68
4/15/2019	21:20:03	77.78	3.68
4/15/2019	21:21:03	79.57	3.68
4/15/2019	21:22:03	78	3.68
4/15/2019	21:23:03	77.89	3.68
4/15/2019	21:24:03	73.74	3.68
4/15/2019	21:25:03	79.12	3.68
4/15/2019	21:26:03	76.99	3.68
4/15/2019	21:27:03	77.78	3.68
4/15/2019	21:28:03	77.1	3.68
4/15/2019	21:29:03	75.65	3.68
4/15/2019	21:30:03	77.44	3.68
4/15/2019	21:31:03	76.99	3.68
4/15/2019	21:32:03	77.67	3.68
4/15/2019	21:33:03	77.55	3.68
4/15/2019	21:34:03	77.22	3.68
4/15/2019	21:35:03	77.55	3.68
4/15/2019	21:36:03	77.78	3.68
4/15/2019	21:37:03	76.88	3.68
4/15/2019	21:38:03	78.45	3.68
4/15/2019	21:39:03	77.55	3.68
4/15/2019	21:40:03	78.56	3.68
4/15/2019	21:41:03	77.67	3.68
4/15/2019	21:42:03	78.9	3.68
4/15/2019	21:43:03	79.01	3.68
4/15/2019	21:44:03	79.01	3.68
4/15/2019	21:45:03	77.89	3.68
4/15/2019	21:46:03	77.33	3.68
4/15/2019	21:47:03	77.55	3.68
4/15/2019	21:48:03	77.22	3.68
4/15/2019	21:49:03	76.88	3.68
4/15/2019	21:50:03	76.77	3.68
4/15/2019	21:51:03	76.21	3.68

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/15/2019	21:52:03	77.67	3.68
4/15/2019	21:53:03	77.22	3.68
4/15/2019	21:54:03	77.55	3.68
4/15/2019	21:55:03	77.44	3.68
4/15/2019	21:56:03	74.64	3.68
4/15/2019	21:57:03	77.55	3.68
4/15/2019	21:58:03	77.78	3.68
4/15/2019	21:59:03	78.23	3.68
4/15/2019	22:00:03	76.66	3.68
4/15/2019	22:01:03	77.89	3.68
4/15/2019	22:02:03	75.42	3.68
4/15/2019	22:03:03	78	3.68
4/15/2019	22:04:03	78.56	3.68
4/15/2019	22:05:03	77.22	3.68
4/15/2019	22:06:03	77.78	3.68
4/15/2019	22:07:03	77.78	3.68
4/15/2019	22:08:03	77.67	3.68
4/15/2019	22:09:03	78.11	3.68
4/15/2019	22:10:03	76.32	3.68
4/15/2019	22:11:03	77.44	3.68
4/15/2019	22:12:03	77.1	3.68
4/15/2019	22:13:03	78.45	3.68
4/15/2019	22:14:03	78.34	3.68
4/15/2019	22:15:03	78.34	3.68
4/15/2019	22:16:03	78.34	3.68
4/15/2019	22:17:03	77.89	3.68
4/15/2019	22:18:03	79.01	3.68
4/15/2019	22:19:03	77.22	3.68
4/15/2019	22:20:03	78.45	3.68
4/15/2019	22:21:03	77.67	3.68
4/15/2019	22:22:03	76.21	3.68
4/15/2019	22:23:03	76.77	3.68
4/15/2019	22:24:03	77.44	3.68
4/15/2019	22:25:03	77.67	3.68
4/15/2019	22:26:03	77.78	3.68
4/15/2019	22:27:03	77.1	3.68
4/15/2019	22:28:03	78	3.68
4/15/2019	22:29:03	78.56	3.68
4/15/2019	22:30:03	78	3.68
4/15/2019	22:31:03	78	3.68
4/15/2019	22:32:03	79.01	3.68
4/15/2019	22:33:03	76.21	3.68
4/15/2019	22:34:03	77.55	3.68
4/15/2019	22:35:03	76.43	3.68
4/15/2019	22:36:03	77.44	3.68
4/15/2019	22:37:03	78.11	3.68
4/15/2019	22:38:03	77.89	3.68
4/15/2019	22:39:03	77.44	3.68
4/15/2019	22:40:03	78.11	3.68
4/15/2019	22:41:03	78.11	3.68
4/15/2019	22:42:03	77.22	3.68
4/15/2019	22:43:03	77.33	3.68
4/15/2019	22:44:03	77.78	3.68
4/15/2019	22:45:03	77.67	3.68
4/15/2019	22:46:03	78.45	3.68
4/15/2019	22:47:03	77.89	3.68
4/15/2019	22:48:03	78	3.68
4/15/2019	22:49:03	78.34	3.68
4/15/2019	22:50:03	76.88	3.68
4/15/2019	22:51:03	78.11	3.68
4/15/2019	22:52:03	78.34	3.68
4/15/2019	22:53:03	78.45	3.68

DRC

PZ22-12000036

01/18/23

DRC

PZ22-12000036

11/02/22

4/15/2019 22:54:03	77.78	3.68
4/15/2019 22:55:03	78.56	3.68
4/15/2019 22:56:03	77.78	3.68
4/15/2019 22:57:03	75.09	3.68
4/15/2019 22:58:03	78	3.68
4/15/2019 22:59:03	76.88	3.68
4/15/2019 23:00:03	77.33	3.68
4/15/2019 23:01:03	77.33	3.68
4/15/2019 23:02:03	77.33	3.68
4/15/2019 23:03:03	78	3.68
4/15/2019 23:04:03	78.11	3.68
4/15/2019 23:05:03	79.12	3.68
4/15/2019 23:06:03	78.23	3.68
4/15/2019 23:07:03	76.99	3.68
4/15/2019 23:08:03	74.64	3.68
4/15/2019 23:09:03	77.89	3.68
4/15/2019 23:10:03	77.67	3.68
4/15/2019 23:11:03	76.88	3.68
4/15/2019 23:12:03	77.22	3.68
4/15/2019 23:13:03	77.22	3.68
4/15/2019 23:14:03	78.45	3.68
4/15/2019 23:15:03	77.89	3.68
4/15/2019 23:16:03	77.78	3.68
4/15/2019 23:17:03	78.23	3.68
4/15/2019 23:18:03	76.99	3.68
4/15/2019 23:19:03	78.11	3.68
4/15/2019 23:20:03	77.67	3.68
4/15/2019 23:21:03	75.54	3.68
4/15/2019 23:22:03	75.54	3.68
4/15/2019 23:23:03	77.89	3.68
4/15/2019 23:24:03	77.78	3.68
4/15/2019 23:25:03	77.67	3.68
4/15/2019 23:26:03	77.55	3.68
4/15/2019 23:27:03	76.1	3.68
4/15/2019 23:28:03	78.34	3.68
4/15/2019 23:29:03	77.89	3.68
4/15/2019 23:30:03	77.78	3.68
4/15/2019 23:31:03	75.65	3.68
4/15/2019 23:32:03	77.78	3.68
4/15/2019 23:33:03	78	3.68
4/15/2019 23:34:03	76.88	3.68
4/15/2019 23:35:03	79.12	3.68
4/15/2019 23:36:03	77.22	3.68
4/15/2019 23:37:03	78	3.68
4/15/2019 23:38:03	79.35	3.68
4/15/2019 23:39:03	78.56	3.68
4/15/2019 23:40:03	77.67	3.68
4/15/2019 23:41:03	78.67	3.68
4/15/2019 23:42:03	78.79	3.68
4/15/2019 23:43:03	78	3.68
4/15/2019 23:44:03	78.23	3.68
4/15/2019 23:45:03	78.23	3.68
4/15/2019 23:46:03	76.77	3.68
4/15/2019 23:47:03	77.67	3.68
4/15/2019 23:48:03	78.23	3.68
4/15/2019 23:49:03	78.79	3.68
4/15/2019 23:50:03	79.01	3.68
4/15/2019 23:51:03	78	3.68
4/15/2019 23:52:03	78.79	3.68
4/15/2019 23:53:03	78.56	3.68
4/15/2019 23:54:03	78.34	3.68
4/15/2019 23:55:03	77.67	3.68

DRC

PZ22-12000036

01/18/23

DRC

PZ22-12000036

11/02/22

4/15/2019	23:56:03	78.45	3.68
4/15/2019	23:57:03	77.33	3.68
4/15/2019	23:58:03	77.44	3.68
4/15/2019	23:59:03	77.1	3.68
4/15/2019	00:00:03	77.78	3.68
4/15/2019	00:01:03	76.88	3.68
4/15/2019	00:02:03	77.78	3.68
4/15/2019	00:03:03	77.89	3.68
4/15/2019	00:04:03	75.42	3.68
4/15/2019	00:05:03	75.76	3.68
4/16/2019	00:06:03	75.87	3.68
4/16/2019	00:07:03	77.89	3.68
4/16/2019	00:08:03	78	3.68
4/16/2019	00:09:03	76.21	3.68
4/16/2019	00:10:03	78.45	3.68
4/16/2019	00:11:03	77.22	3.68
4/16/2019	00:12:03	78.11	3.68
4/16/2019	00:13:03	77.1	3.68
4/16/2019	00:14:03	77.78	3.68
4/16/2019	00:15:03	77.78	3.68
4/16/2019	00:16:03	77.1	3.68
4/16/2019	00:17:03	76.21	3.68
4/16/2019	00:18:03	78.11	3.68
4/16/2019	00:19:03	77.67	3.68
4/16/2019	00:20:03	78.23	3.68
4/16/2019	00:21:03	77.44	3.68
4/16/2019	00:22:03	78.23	3.68
4/16/2019	00:23:03	78.56	3.68
4/16/2019	00:24:03	78.9	3.68
4/16/2019	00:25:03	78.23	3.68
4/16/2019	00:26:03	78.9	3.68
4/16/2019	00:27:03	77.67	3.68
4/16/2019	00:28:03	78.67	3.68
4/16/2019	00:29:03	78.9	3.68
4/16/2019	00:30:03	78.23	3.68
4/16/2019	00:31:03	77.44	3.68
4/16/2019	00:32:03	77.78	3.68
4/16/2019	00:33:03	76.99	3.68
4/16/2019	00:34:03	83.38	3.68
4/16/2019	00:35:03	78.34	3.68
4/16/2019	00:36:03	79.12	3.68
4/16/2019	00:37:03	78.34	3.68
4/16/2019	00:38:03	78.9	3.68
4/16/2019	00:39:03	78.67	3.68
4/16/2019	00:40:03	79.35	3.68
4/16/2019	00:41:03	79.12	3.68
4/16/2019	00:42:03	78.45	3.68
4/16/2019	00:43:03	77.67	3.68
4/16/2019	00:44:03	78.56	3.68
4/16/2019	00:45:03	78.45	3.68
4/16/2019	00:46:03	78.79	3.68
4/16/2019	00:47:03	78.56	3.68
4/16/2019	00:48:03	79.01	3.68
4/16/2019	00:49:03	78.67	3.68
4/16/2019	00:50:03	78.34	3.68
4/16/2019	00:51:03	77.78	3.68
4/16/2019	00:52:03	77.78	3.68
4/16/2019	00:53:03	78.79	3.68
4/16/2019	00:54:03	78.56	3.68
4/16/2019	00:55:03	78.79	3.68
4/16/2019	00:56:03	77.44	3.68
4/16/2019	00:57:03	78.67	3.68

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/16/2019 00:58:03	78.79	3.68
4/16/2019 00:59:03	79.01	3.68
4/16/2019 01:00:03	78.23	3.68
4/16/2019 01:01:03	78.23	3.68
4/16/2019 01:02:03	78.23	3.68
4/16/2019 01:03:03	78.45	3.68
4/16/2019 01:04:03	78.23	3.68
4/16/2019 01:05:03	78	3.68
4/16/2019 01:06:03	78.34	3.68
4/16/2019 01:07:03	78.11	3.68
4/16/2019 01:08:03	78.34	3.68
4/16/2019 01:09:03	78.11	3.68
4/16/2019 01:10:03	79.23	3.68
4/16/2019 01:11:03	78.56	3.68
4/16/2019 01:12:03	78.79	3.68
4/16/2019 01:13:03	77.89	3.68
4/16/2019 01:14:03	78.67	3.68
4/16/2019 01:15:03	78.45	3.68
4/16/2019 01:16:03	77.89	3.68
4/16/2019 01:17:03	78.9	3.68
4/16/2019 01:18:03	78.79	3.68
4/16/2019 01:19:03	79.12	3.68
4/16/2019 01:20:03	78.67	3.68
4/16/2019 01:21:03	78.11	3.68
4/16/2019 01:22:03	79.01	3.68
4/16/2019 01:23:03	78	3.68
4/16/2019 01:24:03	78.56	3.68
4/16/2019 01:25:03	79.12	3.68
4/16/2019 01:26:03	78.34	3.68
4/16/2019 01:27:03	78.67	3.68
4/16/2019 01:28:03	78	3.68
4/16/2019 01:29:03	78.23	3.68
4/16/2019 01:30:03	78.34	3.68
4/16/2019 01:31:03	76.99	3.68
4/16/2019 01:32:03	79.12	3.68
4/16/2019 01:33:03	78.34	3.68
4/16/2019 01:34:03	78.79	3.68
4/16/2019 01:35:03	77.89	3.68
4/16/2019 01:36:03	78.67	3.68
4/16/2019 01:37:03	78.34	3.68
4/16/2019 01:38:03	77.78	3.68
4/16/2019 01:39:03	78	3.68
4/16/2019 01:40:03	78.45	3.68
4/16/2019 01:41:03	78.67	3.68
4/16/2019 01:42:03	78.11	3.68
4/16/2019 01:43:03	78.11	3.68
4/16/2019 01:44:03	78.45	3.68
4/16/2019 01:45:03	78.56	3.68
4/16/2019 01:46:03	78.34	3.68
4/16/2019 01:47:03	77.89	3.68
4/16/2019 01:48:03	78.56	3.68
4/16/2019 01:49:03	78.67	3.68
4/16/2019 01:50:03	78.34	3.68
4/16/2019 01:51:03	78.23	3.68
4/16/2019 01:52:03	78.45	3.68
4/16/2019 01:53:03	78	3.68
4/16/2019 01:54:03	78.23	3.68
4/16/2019 01:55:03	78.56	3.68
4/16/2019 01:56:03	78	3.68
4/16/2019 01:57:03	78.11	3.68
4/16/2019 01:58:03	78	3.68
4/16/2019 01:59:03	78.11	3.68

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/16/2019	02:00:03	77.89	3.68
4/16/2019	02:01:03	78.56	3.68
4/16/2019	02:02:03	78.34	3.68
4/16/2019	02:03:03	77.44	3.68
4/16/2019	02:04:03	77.78	3.68
4/16/2019	02:05:03	76.88	3.68
4/16/2019	02:06:03	78	3.68
4/16/2019	02:07:03	78.34	3.68
4/16/2019	02:08:03	77.22	3.68
4/16/2019	02:09:03	77.55	3.68
4/16/2019	02:10:03	78	3.68
4/16/2019	02:11:03	78	3.68
4/16/2019	02:12:03	77.55	3.68
4/16/2019	02:13:03	77.44	3.68
4/16/2019	02:14:03	77.89	3.68
4/16/2019	02:15:03	78.11	3.68
4/16/2019	02:16:03	77.33	3.68
4/16/2019	02:17:03	78	3.68
4/16/2019	02:18:03	76.88	3.68
4/16/2019	02:19:03	77.22	3.68
4/16/2019	02:20:03	77.78	3.68
4/16/2019	02:21:03	78	3.68
4/16/2019	02:22:03	77.89	3.68
4/16/2019	02:23:03	78.11	3.68
4/16/2019	02:24:03	78	3.68
4/16/2019	02:25:03	77.55	3.68
4/16/2019	02:26:03	78.11	3.68
4/16/2019	02:27:03	78.79	3.68
4/16/2019	02:28:03	78	3.68
4/16/2019	02:29:03	78.56	3.68
4/16/2019	02:30:03	77.67	3.68
4/16/2019	02:31:03	78.45	3.68
4/16/2019	02:32:03	78.67	3.68
4/16/2019	02:33:03	78	3.68
4/16/2019	02:34:03	78.67	3.68
4/16/2019	02:35:03	77.78	3.68
4/16/2019	02:36:03	77.89	3.68
4/16/2019	02:37:03	78.67	3.68
4/16/2019	02:38:03	78.45	3.68
4/16/2019	02:39:03	78.56	3.68
4/16/2019	02:40:03	78.56	3.68
4/16/2019	02:41:03	78.56	3.68
4/16/2019	02:42:03	78.79	3.68
4/16/2019	02:43:03	78	3.68
4/16/2019	02:44:03	78.23	3.68
4/16/2019	02:45:03	78	3.68
4/16/2019	02:46:03	78.23	3.68
4/16/2019	02:47:03	78.56	3.68
4/16/2019	02:48:03	79.12	3.68
4/16/2019	02:49:03	78.56	3.68
4/16/2019	02:50:03	78.45	3.68
4/16/2019	02:51:03	77.67	3.68
4/16/2019	02:52:03	77.89	3.68
4/16/2019	02:53:03	78.34	3.68
4/16/2019	02:54:03	78	3.68
4/16/2019	02:55:03	77.33	3.68
4/16/2019	02:56:03	77.44	3.68
4/16/2019	02:57:03	78.34	3.68
4/16/2019	02:58:03	77.1	3.68
4/16/2019	02:59:03	76.43	3.68
4/16/2019	03:00:03	77.22	3.68
4/16/2019	03:01:03	77.67	3.68

DRC

PZ22-12000036

01/18/23

DRC

PZ22-12000036

11/02/22

4/16/2019	03:02:03	77.44	3.68
4/16/2019	03:03:03	76.99	3.68
4/16/2019	03:04:03	76.88	3.68
4/16/2019	03:05:03	75.76	3.68
4/16/2019	03:06:03	76.88	3.68
4/16/2019	03:07:03	76.66	3.68
4/16/2019	03:08:03	77.22	3.68
4/16/2019	03:09:03	77.55	3.68
4/16/2019	03:10:03	76.88	3.68
4/16/2019	03:11:03	76.54	3.68
4/16/2019	03:12:03	76.77	3.68
4/16/2019	03:13:03	76.99	3.68
4/16/2019	03:14:03	77.1	3.68
4/16/2019	03:15:03	77.44	3.68
4/16/2019	03:16:03	77.55	3.68
4/16/2019	03:17:03	76.99	3.68
4/16/2019	03:18:03	77.67	3.68
4/16/2019	03:19:03	78.45	3.68
4/16/2019	03:20:03	77.89	3.68
4/16/2019	03:21:03	78.9	3.68
4/16/2019	03:22:03	78	3.68
4/16/2019	03:23:03	78.34	3.68
4/16/2019	03:24:03	78.11	3.68
4/16/2019	03:25:03	77.44	3.68
4/16/2019	03:26:03	78.67	3.68
4/16/2019	03:27:03	77.89	3.68
4/16/2019	03:28:03	78	3.68
4/16/2019	03:29:03	78.34	3.68
4/16/2019	03:30:03	78	3.68
4/16/2019	03:31:03	78	3.68
4/16/2019	03:32:03	78.11	3.68
4/16/2019	03:33:03	77.33	3.68
4/16/2019	03:34:03	76.88	3.68
4/16/2019	03:35:03	76.66	3.68
4/16/2019	03:36:03	76.43	3.68
4/16/2019	03:37:03	77.44	3.68
4/16/2019	03:38:03	77.22	3.68
4/16/2019	03:39:03	77.78	3.68
4/16/2019	03:40:03	77.1	3.68
4/16/2019	03:41:03	77.22	3.68
4/16/2019	03:42:03	77.22	3.68
4/16/2019	03:43:03	77.67	3.68
4/16/2019	03:44:03	77.44	3.68
4/16/2019	03:45:03	79.57	3.68
4/16/2019	03:46:03	76.21	3.68
4/16/2019	03:47:03	77.33	3.68
4/16/2019	03:48:03	77.55	3.68
4/16/2019	03:49:03	78	3.68
4/16/2019	03:50:03	77.44	3.68
4/16/2019	03:51:03	77.44	3.68
4/16/2019	03:52:03	77.67	3.68
4/16/2019	03:53:03	77.89	3.68
4/16/2019	03:54:03	77.55	3.68
4/16/2019	03:55:03	77.33	3.68
4/16/2019	03:56:03	77.78	3.68
4/16/2019	03:57:03	77.44	3.68
4/16/2019	03:58:03	76.77	3.68
4/16/2019	03:59:03	77.33	3.68
4/16/2019	04:00:03	76.43	3.68
4/16/2019	04:01:03	76.21	3.68
4/16/2019	04:02:03	75.76	3.68
4/16/2019	04:03:03	76.21	3.68

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/16/2019	04:04:03	75.31	3.68
4/16/2019	04:05:03	75.98	3.68
4/16/2019	04:06:03	75.76	3.68
4/16/2019	04:07:03	76.43	3.68
4/16/2019	04:08:03	76.54	3.68
4/16/2019	04:09:03	76.1	3.68
4/16/2019	04:10:03	75.09	3.68
4/16/2019	04:11:03	76.32	3.68
4/16/2019	04:12:03	75.54	3.68
4/16/2019	04:13:03	76.99	3.68
4/16/2019	04:14:03	76.54	3.68
4/16/2019	04:15:03	76.88	3.68
4/16/2019	04:16:03	76.54	3.68
4/16/2019	04:17:03	76.21	3.68
4/16/2019	04:18:03	75.87	3.68
4/16/2019	04:19:03	76.54	3.68
4/16/2019	04:20:03	76.66	3.68
4/16/2019	04:21:03	76.21	3.68
4/16/2019	04:22:03	76.77	3.68
4/16/2019	04:23:03	76.43	3.68
4/16/2019	04:24:03	77.22	3.68
4/16/2019	04:25:03	76.32	3.68
4/16/2019	04:26:03	76.99	3.68
4/16/2019	04:27:03	76.54	3.68
4/16/2019	04:28:03	75.98	3.68
4/16/2019	04:29:03	76.21	3.68
4/16/2019	04:30:03	75.2	3.68
4/16/2019	04:31:03	74.53	3.68
4/16/2019	04:32:03	74.19	3.68
4/16/2019	04:33:03	76.54	3.68
4/16/2019	04:34:03	76.54	3.68
4/16/2019	04:35:03	75.98	3.68
4/16/2019	04:36:03	76.54	3.68
4/16/2019	04:37:03	73.41	3.68
4/16/2019	04:38:03	75.76	3.68
4/16/2019	04:39:03	76.43	3.68
4/16/2019	04:40:03	76.1	3.68
4/16/2019	04:41:03	76.54	3.68
4/16/2019	04:42:03	75.98	3.68
4/16/2019	04:43:03	76.21	3.68
4/16/2019	04:44:03	76.1	3.68
4/16/2019	04:45:03	75.76	3.68
4/16/2019	04:46:03	75.98	3.68
4/16/2019	04:47:03	76.21	3.68
4/16/2019	04:48:03	75.87	3.68
4/16/2019	04:49:03	76.32	3.68
4/16/2019	04:50:03	77.67	3.68
4/16/2019	04:51:03	77.67	3.68
4/16/2019	04:52:03	77.22	3.68
4/16/2019	04:53:03	77.22	3.68
4/16/2019	04:54:03	76.66	3.68
4/16/2019	04:55:03	77.67	3.68
4/16/2019	04:56:03	77.67	3.68
4/16/2019	04:57:03	77.33	3.68
4/16/2019	04:58:03	78.34	3.68
4/16/2019	04:59:03	76.88	3.68
4/16/2019	05:00:03	77.55	3.68
4/16/2019	05:01:03	74.19	3.68
4/16/2019	05:02:03	79.91	3.68
4/16/2019	05:03:03	76.77	3.68
4/16/2019	05:04:03	76.54	3.68
4/16/2019	05:05:03	76.77	3.68

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/16/2019	05:06:03	77.1	3.68
4/16/2019	05:07:03	77.55	3.68
4/16/2019	05:08:03	77.22	3.68
4/16/2019	05:09:03	76.66	3.68
4/16/2019	05:10:03	76.1	3.68
4/16/2019	05:11:03	77.1	3.68
4/16/2019	05:12:03	77.67	3.68
4/16/2019	05:13:03	77.44	3.68
4/16/2019	05:14:03	77.67	3.68
4/16/2019	05:15:03	77.78	3.68
4/16/2019	05:16:03	76.77	3.68
4/16/2019	05:17:03	77.89	3.68
4/16/2019	05:18:03	77.22	3.68
4/16/2019	05:19:03	77.1	3.68
4/16/2019	05:20:03	77.33	3.68
4/16/2019	05:21:03	76.99	3.68
4/16/2019	05:22:03	76.77	3.68
4/16/2019	05:23:03	77.33	3.68
4/16/2019	05:24:03	77.67	3.67
4/16/2019	05:25:03	76.66	3.68
4/16/2019	05:26:03	76.88	3.68
4/16/2019	05:27:03	76.88	3.68
4/16/2019	05:28:03	76.99	3.68
4/16/2019	05:29:03	76.99	3.68
4/16/2019	05:30:03	76.77	3.68
4/16/2019	05:31:03	77.1	3.68
4/16/2019	05:32:03	77.22	3.68
4/16/2019	05:33:03	77.78	3.68
4/16/2019	05:34:03	77.1	3.68
4/16/2019	05:35:03	76.1	3.68
4/16/2019	05:36:03	76.43	3.68
4/16/2019	05:37:03	77.44	3.68
4/16/2019	05:38:03	76.77	3.68
4/16/2019	05:39:03	77.55	3.68
4/16/2019	05:40:03	76.99	3.68
4/16/2019	05:41:03	77.44	3.68
4/16/2019	05:42:03	77.33	3.68
4/16/2019	05:43:03	76.88	3.68
4/16/2019	05:44:03	76.66	3.68
4/16/2019	05:45:03	77.1	3.68
4/16/2019	05:46:03	77.67	3.68
4/16/2019	05:47:03	77.55	3.68
4/16/2019	05:48:03	76.88	3.68
4/16/2019	05:49:03	75.98	3.68
4/16/2019	05:50:03	77.78	3.68
4/16/2019	05:51:03	77.44	3.68
4/16/2019	05:52:03	77.1	3.68
4/16/2019	05:53:03	76.77	3.68
4/16/2019	05:54:03	77.67	3.68
4/16/2019	05:55:03	77.78	3.68
4/16/2019	05:56:03	76.99	3.68
4/16/2019	05:57:03	77.89	3.68
4/16/2019	05:58:03	76.21	3.68
4/16/2019	05:59:03	77.1	3.68
4/16/2019	06:00:03	76.99	3.68
4/16/2019	06:01:03	77.1	3.68
4/16/2019	06:02:03	76.54	3.68
4/16/2019	06:03:03	75.87	3.68
4/16/2019	06:04:03	76.43	3.68
4/16/2019	06:05:03	76.77	3.68
4/16/2019	06:06:03	76.32	3.68
4/16/2019	06:07:03	75.98	3.68

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/16/2019	06:08:03	76.1	3.68
4/16/2019	06:09:03	75.98	3.68
4/16/2019	06:10:03	76.43	3.68
4/16/2019	06:11:03	76.77	3.68
4/16/2019	06:12:03	76.88	3.68
4/16/2019	06:13:03	76.77	3.68
4/16/2019	06:14:03	76.88	3.68
4/16/2019	06:15:03	76.99	3.68
4/16/2019	06:16:03	76.54	3.68
4/16/2019	06:17:03	76.99	3.68
4/16/2019	06:18:03	76.77	3.68
4/16/2019	06:19:03	77.33	3.68
4/16/2019	06:20:03	77.1	3.68
4/16/2019	06:21:03	76.99	3.68
4/16/2019	06:22:03	76.66	3.68
4/16/2019	06:23:03	76.99	3.68
4/16/2019	06:24:03	77.44	3.68
4/16/2019	06:25:03	77.44	3.67
4/16/2019	06:26:03	76.43	3.68
4/16/2019	06:27:03	76.66	3.67
4/16/2019	06:28:03	76.99	3.67
4/16/2019	06:29:03	76.54	3.68
4/16/2019	06:30:03	76.66	3.68
4/16/2019	06:31:03	76.32	3.68
4/16/2019	06:32:03	75.42	3.68
4/16/2019	06:33:03	76.66	3.68
4/16/2019	06:34:03	75.76	3.67
4/16/2019	06:35:03	77.33	3.68
4/16/2019	06:36:03	76.21	3.68
4/16/2019	06:37:03	76.1	3.67
4/16/2019	06:38:03	75.31	3.67
4/16/2019	06:39:03	76.21	3.68
4/16/2019	06:40:03	75.65	3.67
4/16/2019	06:41:03	76.21	3.67
4/16/2019	06:42:03	75.98	3.68
4/16/2019	06:43:03	76.88	3.67
4/16/2019	06:44:03	76.99	3.68
4/16/2019	06:45:03	76.54	3.67
4/16/2019	06:46:03	76.54	3.68
4/16/2019	06:47:03	74.86	3.67
4/16/2019	06:48:03	75.87	3.67
4/16/2019	06:49:03	76.77	3.68
4/16/2019	06:50:03	75.98	3.67
4/16/2019	06:51:03	76.1	3.68
4/16/2019	06:52:03	75.65	3.68
4/16/2019	06:53:03	76.88	3.67
4/16/2019	06:54:03	75.76	3.68
4/16/2019	06:55:03	76.21	3.67
4/16/2019	06:56:03	76.32	3.67
4/16/2019	06:57:03	76.66	3.67
4/16/2019	06:58:03	77.78	3.67
4/16/2019	06:59:03	75.42	3.67
4/16/2019	07:00:03	76.1	3.67
4/16/2019	07:01:03	76.99	3.68
4/16/2019	07:02:03	75.31	3.68
4/16/2019	07:03:03	75.54	3.68
4/16/2019	07:04:03	75.98	3.67
4/16/2019	07:05:03	74.64	3.68
4/16/2019	07:06:03	75.42	3.67
4/16/2019	07:07:03	75.42	3.68
4/16/2019	07:08:03	75.42	3.67
4/16/2019	07:09:03	75.76	3.68

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/16/2019 07:10:03	76.88	3.67
4/16/2019 07:11:03	75.31	3.67
4/16/2019 07:12:03	76.21	3.68
4/16/2019 07:13:03	76.1	3.68
4/16/2019 07:14:03	76.54	3.68
4/16/2019 07:15:03	75.98	3.68
4/16/2019 07:16:03	75.54	3.67
4/16/2019 07:17:03	72.4	3.68
4/16/2019 07:18:03	75.54	3.68
4/16/2019 07:19:03	75.98	3.67
4/16/2019 07:20:03	74.86	3.68
4/16/2019 07:21:03	75.2	3.67
4/16/2019 07:22:03	73.85	3.68
4/16/2019 07:23:03	75.87	3.68
4/16/2019 07:24:03	76.54	3.68
4/16/2019 07:25:03	74.86	3.68
4/16/2019 07:26:03	75.98	3.68
4/16/2019 07:27:03	74.86	3.68
4/16/2019 07:28:03	75.31	3.68
4/16/2019 07:29:03	76.54	3.67
4/16/2019 07:30:03	75.42	3.68
4/16/2019 07:31:03	76.21	3.68
4/16/2019 07:32:03	73.97	3.68
4/16/2019 07:33:03	74.86	3.68
4/16/2019 07:34:03	75.76	3.68
4/16/2019 07:35:03	76.43	3.68
4/16/2019 07:36:03	76.21	3.67
4/16/2019 07:37:03	74.3	3.68
4/16/2019 07:38:03	74.3	3.68
4/16/2019 07:39:03	76.43	3.68
4/16/2019 07:40:03	75.54	3.68
4/16/2019 07:41:03	74.86	3.68
4/16/2019 07:42:03	73.63	3.68
4/16/2019 07:43:03	75.87	3.68
4/16/2019 07:44:03	73.97	3.68
4/16/2019 07:45:03	74.3	3.68
4/16/2019 07:46:03	74.08	3.68
4/16/2019 07:47:03	75.65	3.68
4/16/2019 07:48:03	76.32	3.68
4/16/2019 07:49:03	74.53	3.68
4/16/2019 07:50:03	73.41	3.68
4/16/2019 07:51:03	74.97	3.68
4/16/2019 07:52:03	74.53	3.68
4/16/2019 07:53:03	74.08	3.68
4/16/2019 07:54:03	74.86	3.68
4/16/2019 07:55:03	75.09	3.68
4/16/2019 07:56:03	75.09	3.68
4/16/2019 07:57:03	77.33	3.68
4/16/2019 07:58:03	75.54	3.68
4/16/2019 07:59:03	75.42	3.68
4/16/2019 08:00:03	74.41	3.68
4/16/2019 08:01:03	74.86	3.68
4/16/2019 08:02:03	76.1	3.68
4/16/2019 08:03:03	76.21	3.68
4/16/2019 08:04:03	75.87	3.68
4/16/2019 08:05:03	76.43	3.68
4/16/2019 08:06:03	77.78	3.68
4/16/2019 08:07:03	74.08	3.68
4/16/2019 08:08:03	76.1	3.68
4/16/2019 08:09:03	76.88	3.68
4/16/2019 08:10:03	75.98	3.68
4/16/2019 08:11:03	74.97	3.68

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22

4/16/2019	08:12:03	74.64	3.68
4/16/2019	08:13:03	74.08	3.68
4/16/2019	08:14:03	75.98	3.68
4/16/2019	08:15:03	76.66	3.68
4/16/2019	08:16:03	76.21	3.68
4/16/2019	08:17:03	76.88	3.68
4/16/2019	08:18:03	75.76	3.68
4/16/2019	08:19:03	74.53	3.68
4/16/2019	08:20:03	59.28	3.68
4/16/2019	08:21:03	74.64	3.68
4/16/2019	08:22:03	71.72	3.68
4/16/2019	08:23:03	76.21	3.68
4/16/2019	08:24:03	75.42	3.68
4/16/2019	08:25:03	74.64	3.68
4/16/2019	08:26:03	74.3	3.68
4/16/2019	08:27:03	57.26	3.68
4/16/2019	08:28:03	83.16	3.68

DRC

PZ22-12000036
01/18/23

DRC

PZ22-12000036
11/02/22