



FOR:
PORTMAN HOLDINGS

COPYRIGHT © 2024 MSA ARCHITECTS, INC.
THE ARCHITECTURAL DESIGN AND DETAIL
DRAWINGS FOR THIS BUILDING AND/OR
OVERALL PROJECT ARE THE LEGAL
PROPERTY OF AND ALL RIGHTS ARE
RESERVED BY THE ARCHITECT, THEIR USE
FOR REPRODUCTION, CONSTRUCTION, OR
DISTRIBUTION IS PROHIBITED UNLESS
AUTHORIZED IN WRITING BY THE ARCHITECT.



Scale:

LEVEL 2
LIFE SAFETY PLAN

SHEET:

SCALE: 1" = 30'-0"



195'-4" TRAVEL DISTANCE
NOTE: MAX. 200'-0" FROM UNIT
CORRIDOR DOOR TO EXIT, PER
FFPC/NFPA 101 LIFE SAFETY CODE
(2021) SEC.30.2.6.3.2 (PROTECTED
BY AUTOMATIC SPRINKLER SYSTEM)

STAIR #1	
EGRESS CAPACITY FACTOR: 0.3	
41" STAIR	136 OCCUP.
STAIR #1 - DOOR	
EGRESS CAPACITY FACTOR: 0.2	
34" STAIR	170 OCCUP.

NOTE: MAX. 200'-0" FROM UNIT
CORRIDOR DOOR TO EXIT, PER
FFPC/NFPA 101 LIFE SAFETY CODE
(2021) SEC.30.2.6.3.2 (PROTECTED
BY AUTOMATIC SPRINKLER SYSTEM)

129'-11" TRAVEL DISTANCE
- NOTE: MAX. 200'-0" FROM UNIT
CORRIDOR DOOR TO EXIT, PER
FFPC/NFPA 101 LIFE SAFETY CODE
(2021) SEC.30.2.6.3.2 (PROTECTED
BY AUTOMATIC SPRINKLER SYSTEM)

199'-0" TRAVEL DISTANCE
NOTE: MAX. 200'-0" FROM UNIT
CORRIDOR DOOR TO EXIT, PER
FFPC/NFPA 101 LIFE SAFETY CODE
(2021) SEC.30.2.6.3.2 (PROTECTED
BY AUTOMATIC SPRINKLER SYSTEM)

21'-3" TRAVEL DISTANCE
NOTE: MAX. 200'-0" FROM UNIT
CORRIDOR DOOR TO EXIT, PER
FFPC/NFPA 101 LIFE SAFETY CODE
(2021) SEC.30.2.6.3.2 (PROTECTED
BY AUTOMATIC SPRINKLER SYSTEM)

69'-9" TRAVEL DISTANCE
NOTE: MAX. 200'-0" FROM UNIT
CORRIDOR DOOR TO EXIT, PER
FFPC/NFPA 101 LIFE SAFETY CODE
(2021) SEC.30.2.6.3.2 (PROTECTED
BY AUTOMATIC SPRINKLER SYSTEM)

STAIR #3	
GRESS CAPACITY FACTOR: 0.3	
41" STAIR	136 OCCUP.
STAIR #3 - DOOR	
GRESS CAPACITY FACTOR: 0.2	
36" STAIR	170 OCCUP.

STAIR #4	
GRESS CAPACITY FACTOR: 0.3	
41" STAIR	136 OCCUP.
STAIR #4 - DOOR	
GRESS CAPACITY FACTOR: 0.2	
34" STAIR	170 OCCUP.

52'-0" TRAVEL DISTANCE
NOTE: MAX. 200'-0" FROM UNIT
CORRIDOR DOOR TO EXIT, PER
FFPC/NFPA 101 LIFE SAFETY CODE
(2021) SEC.30.2.6.3.2 (PROTECTED
BY AUTOMATIC SPRINKLER SYSTEM)

STAIR #2	
EGRESS CAPACITY FACTOR: 0.2	
41" STAIR	156 OCCUP.
STAIR #2 - DOOR	
EGRESS CAPACITY FACTOR: 0.2	
34" STAIR	170 OCCUP.

RESIDENTIAL
R-2 OCCUPANCY
39,481 SQ. FT.
198 OCCUP. @ 202 SF

STAIR #6	
EGRESS CAPACITY FACTOR: 0.3	
41" STAIR	136 OCCUP.
STAIR #6 = DOOR	
EGRESS CAPACITY FACTOR: 0.3	
34" STAIR	170 OCCUP.

RESIDENTIAL
R-2 OCCUPANCY
10,000 SQ. FT.
50 OCCUP. @ 200 SF.

STAIR #5	
EGRESS CAPACITY FACTOR: 0.3	
41" STAIR	136 OCCUP.
STAIR #5 - DOOR	
EGRESS CAPACITY FACTOR: 0.3	
34" STAIR	170 OCCUP.

56'-0" TRAVEL DISTANCE
NOTE: MAX. 200'-0" FROM UNIT
CORRIDOR DOOR TO EXIT, PER
FFPC/NFPA 101 LIFE SAFETY CODE
(2021) SEC.30.2.6.3.2 (PROTECTED
BY AUTOMATIC SPRINKLER SYSTEM)