

DRC

Botek Thurlow Engineering, Inc.

Civil Engineers

Celebrating 15 Years 2006-2021

PZ24-12000003
10/02/2024

DRC

PZ24-12000003

12/17/2025

PZ24-12000003
08/21/2024

November 21, 2022

RE: 580 Briny, Pompano Beach, FL

Required Fire Flow Calculation

The following equation was used to calculate the fire flow:

$$NFF = (C)(O)[1.0 + (X + P)]$$

NFF = the needed fire flow in gallons per minute (gpm)

C = a factor related to the type of construction (gpm) – Non Combustible = 0.75

O = a factor related to the type of occupancy

X = a factor related to the exposure buildings

P = a factor related to the communication between buildings

$$C = 18F(A)^{0.5}$$

F = 0.8 for Construction Class 3 (noncombustible construction)

A = effective area

The effective area is the sum of the square footage of the largest floor in the building and ½ the area of the other floors:

Level 01 = 8,702 sq. ft.

Level 02-09 = 45,064 sq. ft. (total)

Level 10-11 = 10,156 sq. ft. (total)

Effective Area = 63,922 sq. ft.

$$C = 18 F (A)^{0.5} = 18 \times 0.8 \times 63,922^{0.5} = 3640$$

$$NFF = (C)(O)[1.0 + (X + P)]$$

$$NFF = (3640)(0.75)[1.0 + 0.0]$$

$$NFF = 2730 \text{ GPM}$$

Sincerely,

BOTEK THURLOW ENGINEERING, INC.



Stephen F. Botek, P.E.
Fla. Registration #55335

3409 NW 9th Avenue • Suite 1102 • Fort Lauderdale, FL 33309 • p. 954-568-0888, f. 954-568-0755
bte@botekthurlow-eng.com

DRC

PZ24-12000003
10/01/2025

DRC

PZ24-12000003
05/15/2024