

PZ24-12000024

05/07/2025

**A**

3/31/2025 5:42:40 PM

**18.4.4.3.3**  
Required fire flow shall be reduced by 75 percent when the building is protected throughout by an approved automatic sprinkler system, which utilizes quick response sprinklers throughout. The resulting fire flow shall not be less than 600 gpm (2270 L/min).

**18.4.4.3.4** Required fire flow for buildings protected by an approved automatic sprinkler system shall not exceed 2000 gpm (7571 L/min) for 2 hours

**18.4.4.4**  
Required Fire Flow and Automatic Sprinkler System Demand.  
For a building with an approved fire sprinkler system, the fire flow demand and the fire sprinkler system demand shall not be required to be added together. The water supply shall be capable of delivering the larger of the individual demands

Autodesk Docs://AUS-00243675-Foundry Festival Flea Market/Foundry\_Festival Flea Mkt Bldg.rvt

SCALE CHECK	
-------------	--