

# Memo

**To:** Planning and Zoning Board  
**From:** Pete McGinnis Fire Marshal & James Galloway Fire Inspector  
**Date:** January 9, 2023  
**Re:** Planning and Zoning Board Appeal # 22-15000022

---

Due to the fact, the petitioner is currently able to meet all of the Fire Department requirements at this time we have no objections and approves the request at 1661 N Dixie Highway a Temporary Use in order to utilize the subject property for an Outdoor Vehicle Parking. However, the petitioner shall comply with NFPA 1 Chapter 18 Fire Department Access and Water Supply as amended from time to time.

**Petitioner is to submit to Fire Prevention for review and approval a site plan layout of the outdoor storage area, fire department access and water supply to the site before area use.**

\* Additional comments may follow throughout the remainder of the permitting process. The building and the site shall be in compliance with All NFPA Standards prior to receiving Fire Department approval.