

Backflow Prevention Assembly Test and Maintenance Report

PZ22-12000041

12/20/2023

Customer Information

Customer / Property Name: **2217-2233 ATLANTIC LLC**
Contact Name: **N/A**
Property Address: **2217 E Atlantic Blvd**
Pompano Beach, FL 33062

Assembly Information

Type: **RP** Model #: **975**
Size: **1"** Serial#: **466247**
Manufacturer: **Wilkins** Hazard: **Domestic**
Location: **In hall just west of Cafe Sportivo**
Reason for test: ☐ new ☒ existing ☐ replaced.

PASS

Assembly Test Information

Test Date: 2023-07-12

Initial Test		
Check Valve #1 9.4 (X) Closed Tight / Held () Leaked	Check Valve #2 2.0 (X) Closed Tight / Held () Leaked	Relief Valve 2.6 (X) Opened () Did not open
Final Test		
Check Valve #1 9.4 (X) Closed Tight / Held () Leaked	Check Valve #2 2.0 (X) Closed Tight / Held () Leaked	Relief Valve 2.6 (X) Opened () Did not open

As the tester of record, I affirm this test as: Passed ☒ Failed ☐ Repairs Made: No

Additional comments or repairs made / materials (parts) used:

(no comments)

Tester Information

Tester Name: **McEwen, Trent**
Tester License Expiration: **10-07-2024**
Certification#: **icc-bt-462**
Test Kit Serial #: **10151711**
Test Kit Date Tested for Accuracy: **09-05-2022**
Test Kit Mfr. & Mod. #: **Mid-West 845-5**
Testing Co Name: **A-1 Paradise Plumbing Inc.**
Phone: **(954) 563-0110**
Address: **260 SW 21 Terrace**
Fort Lauderdale, FL 33312

Custom Questions

Meter #

The above tester certifies that all information submitted for this report is true and accurate

The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters

Customer Information

Customer / Property Name: **2217-2233 ATLANTIC LLC**
Contact Name: **N/A**
Property Address: **2217 E Atlantic Blvd**
Pompano Beach, FL 33062

Assembly Information

Type: **RP** Model #: **975**
Size: **1"** Serial#: **ABF3407**
Manufacturer: **Wilkins** Hazard: **Domestic**
Location: **right side of bldg**
Reason for test: ☐ new ☒ existing ☐ replaced.

PASS

Assembly Test Information

Test Date: 2023-07-12

Initial Test		
Check Valve #1 9.1 (X) Closed Tight / Held () Leaked	Check Valve #2 2.2 (X) Closed Tight / Held () Leaked	Relief Valve 3.0 (X) Opened () Did not open
Final Test		
Check Valve #1 9.1 (X) Closed Tight / Held () Leaked	Check Valve #2 2.2 (X) Closed Tight / Held () Leaked	Relief Valve 3.0 (X) Opened () Did not open

As the tester of record, I affirm this test as: Passed ☒ Failed ☐ **Repairs Made: No**

Additional comments or repairs made / materials (parts) used:

(no comments)

Tester Information

Tester Name: **McEwen, Trent**
Tester License Expiration: **10-07-2024**
Certification#: **icc-bt-462**
Test Kit Serial #: **10151711**
Test Kit Date Tested for Accuracy: **09-05-2022**
Test Kit Mfr. & Mod. #: **Mid-West 845-5**
Testing Co Name: **A-1 Paradise Plumbing Inc.**
Phone: **(954) 563-0110**
Address: **260 SW 21 Terrace**
Fort Lauderdale, FL 33312

Custom Questions

Meter #

The above tester certifies that all information submitted for this report is true and accurate
The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is
certified to be operating within acceptable parameters

Customer Information

Customer / Property Name: **2217-2233 ATLANTIC LLC**
Contact Name: **N/A**
Property Address: **2217 E Atlantic Blvd**
Pompano Beach, FL 33062

Assembly Information

Type: **RP** Model #: **975**
Size: **1"** Serial#: **190728**
Manufacturer: **Wilkins** Hazard: **Domestic**
Location: **NE Corner**
Reason for test: ☐ new ☒ existing ☐ replaced.

PASS

Assembly Test Information

Test Date: 2023-07-12

Initial Test		
Check Valve #1 8.2 (X) Closed Tight / Held () Leaked	Check Valve #2 1.7 (X) Closed Tight / Held () Leaked	Relief Valve 2.2 (X) Opened () Did not open
Final Test		
Check Valve #1 8.2 (X) Closed Tight / Held () Leaked	Check Valve #2 1.7 (X) Closed Tight / Held () Leaked	Relief Valve 2.2 (X) Opened () Did not open

As the tester of record, I affirm this test as: Passed ☒ Failed ☐ **Repairs Made: No**

Additional comments or repairs made / materials (parts) used:

(no comments)

Tester Information

Tester Name: **McEwen, Trent**
Tester License Expiration: **10-07-2024**
Certification#: **icc-bt-462**
Test Kit Serial #: **10151711**
Test Kit Date Tested for Accuracy: **09-05-2022**
Test Kit Mfr. & Mod. #: **Mid-West 845-5**
Testing Co Name: **A-1 Paradise Plumbing Inc.**
Phone: **(954) 563-0110**
Address: **260 SW 21 Terrace**
Fort Lauderdale, FL 33312

Custom Questions

Meter #

The above tester certifies that all information submitted for this report is true and accurate
The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is
certified to be operating within acceptable parameters