

NFPA LIFE SAFETY DATA	FLORIDA BUILDING CODE DATA
FLORIDA FIRE PREVENTION CODE, SEVENTH EDITION INCLUDING NFPA, 1 FIRE CODE AND NFPA 101, LIFE SAFETY CODE, 2018 EDITION	FLORIDA BUILDING CODE 2020- SEVENTH EDITION
NEW AIRCRAFT HANGAR STORAGE OCCUPANCY CHAPTER 42 ORDINARY HAZARD BUILDING IS NOT FULLY SPRINKLERED	USE AND OCCUPANCY S-1 AIRCRAFT STORAGE HANGAR CHAPTER 3
NFPA 42.6 SPECIAL PROVISIONS FOR AIRCRAFT HANGARS	SPECIAL DETAILED REQUIREMENTS BASED ON USE & OCCUPANCY CHAPTER 4- 412- AIRCRAFT RELATED SPECIAL REQUIREMENTS
2 MEANS OF EGRESS REQUIRED FROM ALL AIRCRAFT HANGAR AREAS.	[F] 412.4.6.1 HAZARDOUS OPERATIONS. ANY GROUP III AIRCRAFT HANGAR ACCORDING TO TABLE 412.4.6 THAT CONTAINS HAZARDOUS OPERATIONS INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING SHALL BE PROVIDED WITH A GROUP I OR II FIRE SUPPRESSION SYSTEM IN ACCORDANCE WITH NFPA 409 AS APPLICABLE.
EXITS FROM AIRCRAFT STORAGE AREAS SHALL BE AT INTERVALS NOT EXCEEDING 150 FT.	1. DOPING.
HORIZONTAL EXITS AT FIRE BARRIERS SHALL NOT EXCEED 100 FT. SPACING.	2. HOT WORK INCLUDING, BUT NOT LIMITED TO, WELDING, TORCH CUTTING AND TORCH SOLDERING
"SMASH DOORS" NOT APPLICABLE	3. FUEL TRANSFER.
MEZZANINES NOT APPLICABLE.	4. FUEL TANK REPAIR OR MAINTENANCE NOT INCLUDING DEFUELED TANKS IN ACCORDANCE WITH NFPA 409, INERTED TANKS OR TANKS THAT HAVE NEVER BEEN FUELED.
DEAD ENDS SHALL NOT EXCEED 50 FT. FOR NON HIGH HAZARD AREAS.	5. SPRAY FINISHING OPERATIONS.
MAXIMUM COMMON PATH OF TRAVEL- ORDINARY HAZARD, UN-SPRINKLERED = 50 FT	6. TOTAL RUL. CAPACITY OF ALL AIRCRAFT WITHIN THE UNSPRINKLERED SINGLE AREA IN EXCESS OF 1,500 GALLONS (6057 L).
DEAD END 50 FT. MAX.	7. TOTAL FUEL CAPACITY OF ALL AIRCRAFT WITHIN THE MAXIMUM SINGLE FIRE AREA IN EXCESS OF 7,500 GALLONS (28 390 L) FOR A HANGAR WITH AN AUTOMATIC SPRINKLER SYSTEM IN ACCORDANCE WITH SECTION 903.3.1.1.
MAXIMUM TRAVEL DISTANCE TO EXITS ORDINARY HAZARD, UNSPRINKLERED=200 FT MAX	GENERAL BUILDING HEIGHTS AND AREAS
UNPROTECTED VERTICAL OPENINGS NOT APPLICABLE	CHAPTER 5- ALLOWABLE HEIGHT TYPE IIIB N.S. 55 FT.
INTERIOR WALL AND CEILING FINISHES-PER REQUIREMENTS	STORIES ABOVE GRADE PLANE S-1, N.S. = 3 MAX
DETECTION ALARM & COMMUNICATION NOT REQUIRED	BUILDING AREA, S-1, N.S. = 17,500 SF
NFPA 409 STANDARD ON AIRCRAFT HANGARS	AREA MOD. FOR BUILDING D,E,F NOT REQUIRED
GROUP III HANGAR TYPE III(200) CONSTRUCTION TYPE PER NFPA 220	TYPE CONSTRUCTION: IIIB
HANGAR DOORS LESS THAN 28 FT. HIGH	CH 6 FIRE RATED EXTERIOR WALLS S-1 OCC , X IS GREATER THAN
MAXIMUM FIRE AREA LESS THAN 12,000 S.F.	OR EQUAL TO 30 FT ALLOW ZERO HOUR RATED EXT WALLS.
BUILDING UNSPRINKLERED AS ALLOWED AS ORDINARY HAZARD PER FBC 412.4.6.1	


EMERGENCY RADIO SIGNAL / BI-DIRECTIONAL AMPLIFICATION

ALL BUILDINGS SHALL BE TESTED FOR EMERGENCY RADIO SIGNAL STRENGTH

AFTER THE SHELL IS CONSTRUCTED. VERIFY WITH MUNICIPALITY FIRE DEPARTMENT FOR TESTING REQUIREMENTS PRIOR TO TESTING. IF THE BUILDING IS FOUND TO REQUIRE A B.D.A. (BI-DIRECTIONAL AMPLIFICATION SYSTEM) OWNER WILL ENGAGE A SPECIALTY ENGINEER TO DESIGN A BOOSTER SYTEM IN FULL ACCORDANCE WITH NFPA 72 AND LOCAL AUTHORITIES HAVING JURISDICTION.







DETAILS OF CONSTRUCTION SUCH AS LOCATION OF HEAD END EQUIPMENT AND CABLE

PATHWAYS VERTICALLY AND HORIZONTALLY SHALL BE SPECIFIED.



B4 BUILDING D,E,F, LIFE SAFETY PLAN

GENERAL NOTES:		LEGEND		EGRESS DATA FBC S-1 OCC		OCCUPANCY LOAD SUMMARY FBC CH 10		INTERIOR FINISH CLASSIFICATION LIMITATIONS													
UN-SPRINKLERED		<p>----- TRAVEL DISTANCE PATH</p> <p>- - - - - COMMON PATH</p> <p>--- DEAD-END CORRIDOR</p> <p>☒ CLC MTD. DIRECTIONAL EXIT SIGN</p> <p>☒ WALL MTD. EXIT SIGN</p> <p>☒ FIRE EXTINGUISHER - SEMI-RECESSED CABINET W/ 3A 4BC RING</p> <p>☒ FIRE EXTINGUISHER - WALL MOUNTED W/RACKET W/ 3A 4BC RING</p> <p>☒ F.D. KEY BOX LOCATION (VERIFY W/ F.D. MANUF. TYPE KNXK OR SUPRA)</p> <p>☒ EMERGENCY LIGHT</p>		<p>OCCUPANCY CLASSIFICATION: GROUP S-1</p> <p>CAPACITY PER F.B.C. 1004.5 AIRCRAFT HANGARS 1 PER 500 GROSS</p> <p>EACH HANGAR IS 5600 SF THEREFORE OCCUPANT LOAD IS 5600 / 1000 = 11.2 THEREFORE 13 PEOPLE EACH BAY.</p> <p>MAX. TRAVEL DISTANCE TO EXIT (FT) 200'</p> <p>MAX. DEAD END CORRIDOR 20'</p> <p>MIN. CORRIDOR WIDTH 44"</p> <p>MIN. CLEAR OPENING 32"</p> <p>MAX. COMMON PATH (FT) 50'</p>		<p>OCCUPANCY CLASSIFICATION: GROUP S-1</p> <p>CAPACITY PER F.B.C. 1004.5 AIRCRAFT HANGARS 1 PER 500 GROSS</p> <p>EACH HANGAR IS 5600 SF THEREFORE OCCUPANT LOAD IS 5600 / 1000 = 11.2 THEREFORE 13 PEOPLE EACH BAY.</p>		OCCUPANCY CLASSIFICATION: GROUP S-1		OCCUPANCY CLASSIFICATION: GROUP S-1											
FIRE RESISTANCE RATING LEGEND		PARTITION LABELS						OCCUPANCY S-1 UN-SPRINKLERED													
<p>① NOT USED</p> <p>② 90 MIN FIRE LABEL DOOR</p> <p>③ 120 MIN FIRE LABEL DOOR</p> <p>④ 15 MIN FIRE LABEL DOOR</p> <p>⑤ 30 MIN FIRE LABEL DOOR</p>		<p>① NOT USED</p> <p>② 90 MIN FIRE LABEL DOOR</p> <p>③ 120 MIN FIRE LABEL DOOR</p> <p>④ 15 MIN FIRE LABEL DOOR</p> <p>⑤ 30 MIN FIRE LABEL DOOR</p>						<table><tr><td>WALL AND CEILING</td><td>EXITS</td><td>CORRIDORS</td><td>OTHER SPACES</td></tr><tr><td colspan="2">B</td><td>B</td><td>C</td></tr></table>		WALL AND CEILING	EXITS	CORRIDORS	OTHER SPACES	B		B	C				
WALL AND CEILING	EXITS	CORRIDORS	OTHER SPACES																		
B		B	C																		
								<table><tr><td colspan="2">FLOORS</td><td colspan="2">CLASS I OR II ARE PERMITTED</td></tr><tr><td colspan="2">CLASS I: CRITICAL RADIANT FLUX NOT LESS THAN 0.15 W/m²</td><td colspan="2">CLASS I: CRITICAL RADIANT FLUX NOT LESS THAN 0.15 W/m²</td></tr><tr><td colspan="2">CLASS II: CRITICAL RADIANT FLUX NOT LESS THAN 0.22 W/m²</td><td colspan="2">CLASS II: CRITICAL RADIANT FLUX NOT LESS THAN 0.22 W/m²</td></tr></table>		FLOORS		CLASS I OR II ARE PERMITTED		CLASS I: CRITICAL RADIANT FLUX NOT LESS THAN 0.15 W/m²		CLASS I: CRITICAL RADIANT FLUX NOT LESS THAN 0.15 W/m²		CLASS II: CRITICAL RADIANT FLUX NOT LESS THAN 0.22 W/m²		CLASS II: CRITICAL RADIANT FLUX NOT LESS THAN 0.22 W/m²	
FLOORS		CLASS I OR II ARE PERMITTED																			
CLASS I: CRITICAL RADIANT FLUX NOT LESS THAN 0.15 W/m²		CLASS I: CRITICAL RADIANT FLUX NOT LESS THAN 0.15 W/m²																			
CLASS II: CRITICAL RADIANT FLUX NOT LESS THAN 0.22 W/m²		CLASS II: CRITICAL RADIANT FLUX NOT LESS THAN 0.22 W/m²																			

LIFE SAFETY SYMBOLS	
COMMON PATH OF TRAVEL	
DEAD END	
MAXIMUM TRAVEL DISTANCE	
EXIT SIGNS, WITH OR WITHOUT DIRECTION ARROWS	
EMERGENCY LIGHTS	
FIRE EXTINGUISHERS DISTRIBUTED PER REQUIREMENTS ON ALL LEVELS.	 FIRE EXTINGUISHER 2A-10B:C 5 LB.

GHA
GALLO HERBERT ARCHITECTS
1311 W NEWPORT CENTER DRIVE DEERFIELD BEACH FLORIDA 33442 PH.
954.794.0300 F.X. 954.794.0301
AA226001731
[SEAL]
☐ WILLIAM J. GALLO FL AR0008440
Brian Digitally signed by
Herbert Brian Herbert
ert Date:
2022.06.30
14:35:26
-04'00'
☐ BRIAN P. HERBERT FL AR00115474
[PROJECT]
POMPANO
C BEACH AIR
PARCEL Y
601 NE 10TH ST.
POMPANO BEACH
FL 33060
[OWNER]

[illegible]

PROJECT STATUS	
D.R.C.	
DATE	
2021-03-24	
PROJECT NUMBER	
83-2020	
SCALE	
AS SHOWN	
DRAWN BY	CHECKED BY
JET	JET
DRAWING TITLE	
BLDG. "D" & "F" LIFE SAFETY PLAN	
DRAWING NUMBER	
05-A-102	