



DUR-O-WALL CORNER DETAIL

N.T.S.  
PROVIDE GALVANIZED #9 GAGE, LADDER TYPE HORIZONTAL JOINT REINFORCING EVERY SECOND BLOCK COURSE (1'-4" O.C. VERTICALLY) LAPPED 7-1/2'.




WINDOW CONNECTION DETAIL

N.T.S.  
VERIFY ALL CONNECTIONS AND MASONRY OPENINGS WITH PRODUCT APPROVALS. SEPARATION BETWEEN THE WINDOW AND THE P.T. WOOD BUCKS ARE NOT TO BE MORE THAN 1/4"  
WATER PROFFING NOTE:  
WINDOW EXTERIOR TO BE CAULKED ALL AROUND WITH "PROSOCCO R-GUARD" FASTFLASH AS PER MANFOR SPECIFICATIONS.




FOUNDATION CORNER REINFORCING.

N.T.S.




EXTERIOR DOOR CONNECTION

N.T.S.  
REFER TO PRODUCT APPROVAL FOR DOOR TO BUCK CONNECTION




TYP. INTERIOR PTN.

SCALE 1/4"=1'-0"



ATTIC ACCESS DETAIL


NTS



OPENING FLASH DETAIL @ MASONRY WALL

NTS


NOTE:  
WATERPROOFING SHALL BE PROVIDED AT ALL EXTERIOR OPENINGS AND BE CONTINUOUS AROUND ENTIRE PERIMETER OF OPENING TYP.  
NOTE:  
CONTRACTOR SHALL PATCH/FILL AREA AROUND OPENINGS TO PROVIDE CLEAN SMOOTH SURFACE FOR WATERPROOFING TYP.



FIXTURE BACKING DETAIL

SCALE: N.T.S.


NOTE:  
1. ALL WALL HUNG FIXTURES TO BE CAPABLE OF WITHSTANDING 250 LBS POINT LOAD.  
2. USE MINERAL WOOL BATT AT 1-HOUR WALL.  
WALL HUNG FIXTURE NOTE:  
ALL WALL HUNG FIXTURES TO BE SUPPORTED AS PER F.B.C. 2318.1.15 OR 2517.5.1.1 STEEL STUDS SHALL BE DOUBLED OR NOT LESS THAN 20 GA W/ A MIN. EFFECTIVE MOMENT OF ENERTIA EQUAL TO 0.864 IN. 4. STUDS TO BE RIGIDLY CONNECTED TOP AND BOTTOM TO PREVENT SIGNIFICANT END ROTATION OR DISPLACEMENT. A HORIZONTAL MEMBER SECURELY FASTENED TO NOT LESS THAN TWO STUDS SHALL BE INSTALLED FOR THE ATTACHMENT OF EACH HUNG PLUMBING FIXTURE.



CONC. THICKENED EDGE SECTION

SCALE: 3/4" = 1'-0"

Digitally signed by Miguel F de Diego  
Date: 2023.11.13 15:34:25 -05'00'



ALL DESIGN, DRAWINGS, REPORTS, SPECIFICATIONS, COMPUTER FILES, FIELD DATA, NOTES AND ANY OTHER DOCUMENTS ARE THE PROPERTY OF THE ARCHITECT AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF THE ARCHITECT. THE ARCHITECT SHALL RETAIN ALL COMMON LAW COPYRIGHT AND OTHER RESERVED RIGHTS IN THIS DESIGN. DIMENSIONS SHALL HAVE PRECEDENCE OVER SCALE.

NEW RESIDENCE  
MODEL B  
PARCEL-4 351 NW 10th STREET  
POMPANO BEACH, FLORIDA  
CONTACT: JUAN F. WILKES (786) 838-8159  
PABLO FERNANDEZ (786) 838-7310

Miguel de Diego  
ARCHITECT P.A.  
AA-26001641  
1657 TYLER STREET SUITE 107 HOLLYWOOD, FLORIDA 33020  
PH. (954) 926-3358 FAX (954) 926-2021

CHECKED  
DRAWN  
DATE 10-4-22  
COMM. NO. 21-194

CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS, NOTES AND CONDITIONS PRIOR TO PROCEEDING WITH ANY WORK