


RESTRAINED VALVE AT TEE
(BRANCH)





RESTRAINED VALVE AT TEE
(IN LINE)

USE MEGALUGS AT ALL PIPE JOINTS

ALL D.I.P. TO BE PAINTED BLUE
ON THE TOP HALF OF PIPE.

ENGINEERING STANDARDS 2022

REVISIONS	ENGINEERING DIVISION	RESTRAINED VALVE AT TEE
BY DATE	CITY OF POMPANO BEACH	
S.S. JUNE 2005		
	SCALE: N.T.S.	DATE: MAY 2022 DWG. NO. 111-1



VALVE TYPES:

BALL VALVE--BALL
RESILIENT WEDGE GATE VALVE--RWGV
BUTTERFLY VALVE--BY
PLUG VALVE--PV


NOTES:

1. VALVE INFORMATION TO BE TRIPLE ENGRAVED INTO TOP SURFACE WITH 1/4" CAPITAL LETTERS.
2. ENTIRE MARKER TO BE COATED WITH CLEAR EPOXY TO PREVENT TARNISHING.
3. VALVE INFORMATION TO BE APPROVED BY CITY OF POMPANO BEACH UTILITIES DEPARTMENT.
4. MARKERS SHALL BE MANUFACTURED BY RG WRENCH, OR APPROVED EQUAL.

UNDERGROUND VALVE
IDENTIFICATION MARKER

ENGINEERING STANDARDS 2022

REVISIONS	ENGINEERING DIVISION	UNDERGROUND VALVE IDENTIFICATION MARKER
BY DATE	CITY OF POMPANO BEACH	
S.S. JUNE 2005		
T.W. 11-2007		
T.W. 02-2008		
S.S. 1-24-12	SCALE: N.T.S.	DATE: FEB. 2022 DWG. NO. 115-1



GENERAL NOTES:

1. VALUES IN TABLE ARE BASED ON 3" OF COVER, 100 PSI INTERNAL PRESSURE, FOR FORCE MAINS, 150 PSI REUSE WATER LINES, ANSI/AWWA C605 & C150/A21.50 LAYING CONDITION 3, ASTM D2487 SAND-SILT SP SOIL TYPE, AND SAFETY FACTOR OF 2.0. RESTRAINED LENGTHS WERE COMPUTED PER DIPRA "THRUST RESTRAINT DESIGN FOR DUCTILE IRON PIPE" AND "PVC PIPE THRUST RESTRAINT DESIGN HANDBOOK," EBAA IRON, INC.
2. CONFIRM THE EXACT LENGTH OF RESTRAINING REQUIRED FOR REDUCERS, PIPE ENCASED IN POLYETHYLENE AND ENCRORACHING RESTRAINED LENGTHS WITH THE DESIGN ENGINEER.
3. THE CONTRACTOR IS RESPONSIBLE FOR PROPER INSTALLATION OF THE RESTRAINED JOINTS TO PREVENT MOVEMENT OF THE PIPE & FITTINGS.
4. IN THE EVENT OF A CONFLICT BETWEEN RESTRAINED LENGTHS SHOWN ON THE TABLE AND RESTRAINED LENGTHS SHOWN ON THE DRAWINGS, THE LONGEST RESTRAINED LENGTH SHALL BE USED.

RESTRAINED JOINT INFORMATION

ENGINEERING STANDARDS 2022

REVISIONS	ENGINEERING DIVISION	RESTRAINED JOINT INFORMATION
BY DATE	CITY OF POMPANO BEACH	
		DATE: MAY 2022 DWG. NO. 118-1
	SCALE: N.T.S.	

PIPE SIZE (IN.)	RESTRAINED JOINT LENGTH L (MINIMUM DISTANCE IN FEET FROM FITTING - EACH WAY)				CROSS WITH PLUG DEAD END REZ/WYE
	90°	45°	22.5°	11.25°	
6	26	11	6	3	53
8	33	14	7	4	68
12	46	19	10	5	96

PVC VERTICAL DOWN BEND

PIPE SIZE (IN.)	RESTRAINED JOINT LENGTH L (MINIMUM DISTANCE IN FEET FROM FITTING - EACH WAY)			
	90°	45°	22.5°	11.25°
6	26	11	6	3
8	33	14	7	4
12	46	19	10	5

DIP HORIZONTAL BENDS AND VERTICAL UP BENDS

PIPE SIZE (IN.)	RESTRAINED JOINT LENGTH L (MINIMUM DISTANCE IN FEET FROM FITTING - EACH WAY)				CROSS WITH PLUG DEAD END REZ/WYE
	90°	45°	22.5°	11.25°	
12"	68	28	14	7	144
24"	119	49	24	12	258

DIP VERTICAL DOWN BEND

PIPE SIZE (IN.)	RESTRAINED JOINT LENGTH L (MINIMUM DISTANCE IN FEET FROM FITTING - EACH WAY)			
	90°	45°	22.5°	11.25°
12"	144	60	29	14
24"	258	107	51	25

RESTRAINED JOINT INFORMATION

ENGINEERING STANDARDS 2022

REVISIONS	ENGINEERING DIVISION	RESTRAINED JOINT INFORMATION
BY DATE	CITY OF POMPANO BEACH	
		DATE: MAY 2022 DWG. NO. 118-2
	SCALE: N.T.S.	


MIN. LENGTH OF PIPE (FEET) TO BE RESTRAINED																
(SOURCES: EBARA IRON RELEASE CALCULATION PROGRAM FOR PVC PIPE, RELEASE 3.1, AND DIPRA THRUST RESTRAINT FOR DUCTILE IRON PIPE, RELEASE 3.2)																
FITTING TYPE	PIPE SIZE												200psi			
	4"	6"	8"	10"	12"	16"	20"	24"	30"	36"	42"	48"				
90° HORIZ. BEND	14	20	25	30	35	45	54	62	98	112	124	135				
45° HORIZ. BEND	6	8	11	13	15	19	22	26	41	46	51	56				
22.5° HORIZ. BEND	2	4	5	6	7	9	11	12	19	22	25	27				
11.25° HORIZ. BEND	1	2	3	3	4	4	5	6	10	11	12	13				
90° VERT. OFFSET	UPPER BEND	29	41	53	64	74	95	115	134	214	246	276	304			
	LOWER BEND	7	10	13	16	19	25	30	35	57	66	74	83			
45° VERT. OFFSET	UPPER BEND	12	19	24	29	34	39	46	56	89	102	114	126			
	LOWER BEND	3	4	6	7	8	10	12	15	23	27	31	34			
22.5° VERT. OFFSET	UPPER BEND	6	9	12	14	17	19	23	27	43	49	55	60			
	LOWER BEND	1	2	4	4	4	5	6	7	11	13	15	16			
11.25° VERT. OFFSET	UPPER BEND	3	4	6	7	8	9	11	13	21	24	27	30			
	LOWER BEND	1	1	1	2	2	2	3	3	6	6	7	8			
PLUG (DEAD END)	32	45	59	70	83	107	129	151	214	246	276	304				
IN-LINE VALVE	32	45	45	45	45	56	65	80	110	125	140	155				
TEE (BRANCH RESTRAINT)	4"x Ø	23	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	6"x Ø	21	35	-	-	-	-	-	-	-	-	-	-	-	-	-
	8"x Ø	18	34	47	-	-	-	-	-	-	-	-	-	-	-	-
	10"x Ø	16	32	46	58	-	-	-	-	-	-	-	-	-	-	-
	12"x Ø	13	30	44	57	69	-	-	-	-	-	-	-	-	-	-
	16"x Ø	7	26	41	55	67	90	-	-	-	-	-	-	-	-	-
	20"x Ø	1	21	36	52	65	88	109	-	-	-	-	-	-	-	-
	24"x Ø	1	16	34	49	63	86	108	129	-	-	-	-	-	-	-
	30"x Ø	1	8	28	44	58	83	106	127	208	-	-	-	-	-	-
	36"x Ø	1	1	22	39	54	80	103	124	208	240	-	-	-	-	-
REDUCER (LARGER PIPE RESTRAINT)	42"x Ø	1	1	15	33	49	77	100	122	203	239	278	-	-	-	-
	48"x Ø	1	1	7	27	44	73	97	120	203	238	289	298	-	-	-
	6"x Ø	23	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	8"x Ø	38	25	-	-	-	-	-	-	-	-	-	-	-	-	-
	10"x Ø	57	43	24	-	-	-	-	-	-	-	-	-	-	-	-
	12"x Ø	72	60	44	41	-	-	-	-	-	-	-	-	-	-	-
200psi	16"x Ø	89	80	78	75	45	-	-	-	-	-	-	-	-	-	-
	20"x Ø	123	118	107	105	81	45	-	-	-	-	-	-	-	-	-
	24"x Ø	146	140	132	131	111	82	45	-	-	-	-	-	-	-	-
	30"x Ø	209	204	197	188	177	153	118	75	-	-	-	-	-	-	-
	36"x Ø	243	236	233	226	217	196	168	135	74	-	-	-	-	-	-
	42"x Ø	273	270	265	259	252	234	211	183	133	72	-	-	-	-	-
	48"x Ø	301	298	294	289	283	268	249	226	183	131	71	-	-	-	-
	60"x Ø	330	326	321	314	307	291	270	246	203	151	101	-	-	-	-

- NOTES:
1. THE DATA IN THE ABOVE TABLE ARE BASED UPON THE FOLLOWING INSTALLATION CONDITIONS:
SOL TYPE--SAND TEST PRESSURE--100 PSI/200 PSI DEPTH OF BURY--3"
BEND TYPE--15" SAFETY FACTOR--1.5 VERTICAL OFFSET--3"
 2. THE RESTRAINED PIPE LENGTHS APPLY TO DUCTILE IRON AND PVC PIPE.
 3. ALL JOINTS BETWEEN UPPER AND LOWER BENDS SHALL BE RESTRAINED.
 4. RESTRAINED PIPE LENGTHS APPLY TO PIPE ON BOTH SIDES OF VALVES AND FITTINGS.

RESTRAINED JOINT INFORMATION

ENGINEERING STANDARDS 2022

REVISIONS	ENGINEERING DIVISION	RESTRAINED JOINT INFORMATION
BY DATE	CITY OF POMPANO BEACH	
		DATE: MAY 2022 DWG. NO. 118-3
	SCALE: N.T.S.	



GENERAL NOTES:

1. ALL UTILITY PIPE SHALL BE INSTALLED WITH 4"Ø MARKING BALLS PLACED EVERY 40' AND AT EVERY FITTING, FOR IDENTIFICATION AND WARNING PURPOSES, BURIED ABOVE THE PIPE AT A MAXIMUM DEPTH OF 24 INCHES OR AS APPROVED BY THE OWNER. IT SHALL BE COLOR CODED AND WORDED AS FOLLOWS:

POTABLE WATER:

- A. COLOR: BLUE PER 62-555.320(21)(b)(3) F.A.C.
- B. LETTERING: WATER
- C. FREQUENCY OF MARKER BALLS SHALL BE 145.7 Khz.
- D. THE MARKER BALLS CAN BE BURIED IN ANY ORIENTATION.


THE MARKER BALLS SHALL BE DETECTABLE BY STANDARD METAL DETECTION EQUIPMENT AND SHALL BE MANUFACTURED BY TEMPO OR 3M LOCATOR SYSTEM OR EQUIVALENT (FREQUENCY 145.7 Khz)

2. FOR LARGE DIAMETER PIPE INSTALLED AT DEPTHS BELOW 4'-0" MARKER BALLS SHALL BE PLACED AT A MAXIMUM DEPTH OF 4'-0" BELOW GRADE *.

WATER PIPE IDENTIFICATION

ENGINEERING STANDARDS 2022

REVISIONS	ENGINEERING DIVISION	WATER PIPE IDENTIFICATION
BY DATE	CITY OF POMPANO BEACH	
S.S. 01/12		DATE: JAN. 2022 DWG. NO. 119-1
S.S. 06/16		
	SCALE: N.T.S.	



GENERAL NOTES:

1. ALL NONMETALLIC PIPE SHALL BE INSTALLED WITH 12 THHN SOLID COPPER TRACING WIRE.
2. THE MARKER BALLS MUST BE INSTALLED DIRECTLY ABOVE THE PIPE.
3. MARKER BALLS SHALL BE INSTALLED AT 40' O.C.
4. BALL COLOR CODING:
POTABLE WATER SYSTEM: BLUE PER 62-555.320(21)(b)(3) F.A.C.

UTILITY PIPE AND MARKER BALLS LOCATION

ENGINEERING STANDARDS 2022

REVISIONS	ENGINEERING DIVISION	UTILITY PIPE AND MARKER BALLS LOCATION
BY DATE	CITY OF POMPANO BEACH	
S.S. 01/12		DATE: JAN. 2022 DWG. NO. 120-1
S.S. 06/16		
	SCALE: N.T.S.	



A CIVIL ENGINEERING FIRM

EXPEDITING DEVELOPMENT

801 Brickell Avenue
Suite 800
Miami, Florida 33131

PH: 786.284.8828
FAX: 866.312.8730

FLORIDA CERTIFICATE OF AUTHORIZATION # 27431

PROJECT NUMBER: 23106

DRAWN BY: AH DESIGN BY: AH CHECK BY: LAB

ORIGINAL DRAWING DATE: 01/04/2023

REVISIONS:

△		
△		
△		
△		
△		
△		
△		
△		
△		
△		
△		

PROJECT NAME:

TOWNHOMES
CANAL
DRIVE
POMPANO

LOCATION:

3233 - 3237 CANAL DRIVE
POMPANO BEACH, FL 33062

FOR:

Mr. SERGE MICHAUD

3018 NE 20TH COURT
FT. LAUDERDALE, FL 33305

PLAN STATUS:

SUBMITTAL SET:
FOR AGENCY REVIEW
AND APPROVAL

JANUARY 28, 2025

LUIS A. BETALLELUZ, JR., P.E. FL P.E.# 65892
(NOT VALID WITHOUT SIGNATURE AND PROPER SEAL)

SHEET NAME:

CITY DETAILS

SHEET NUMBER:

C 12.0



Call 811 or visit sunshine811.com two full
business days before digging to have
buried facilities located and marked.

Check positive response codes before you dig!

P223-120-0054

03/05/2025