

AMERICAN EAGLE FIRE PROTECTION, INC.

4711 North Dixie Highway – Boca Raton, FL 33431

Telephone: 561-750-3698 – Fax: 561-750-8496

LIC # 33490800012003


FLOW TEST

STATIC PRESSURE (psi)	RESIDUAL PRESSURE (psi)	PITOT PRESSURE (psi)	PITOT FLOW (gpm)	OUTLET SIZE
78	70	28	885	2"

Address: 1600 Block of NW 6th Avenue, Pompano Beach

Flow Test Date: Monday, May 22 – 8:30 to Tuesday, May 23rd, 2023 8:30 a.m.

Sketch of Test Location



Disclaimer:
This product has been compiled from various source data. However, this product is for reference only and is not to be construed as a legal document or survey instrument. Any reliance on the information contained herein is at the user's own risk. The City of Pompano Beach assumes no responsibility for any use of the information contained herein or any loss resulting therefrom.

Title:
09506.02 Blanche Ely Estates

Checked by: Engineering Division
GIS Department | A.S.



X *Dario Cimetta/ Adam Summers*

Date: 05-24-2023

DRC

PZ23-1200016
07/05/2023