

Estimated Sewage Flows					
Using Florida Administrative Code*					
Type of Establishment	Rate (GPD)	# Units	GPD	**Note Multiplier	Total Flow (GPD)
<b>Wawa:</b>					
-Service Stations Per Water Closet	325	2	650	1	650
-Food Operations - Per 100 S.F. of Floor Space	50	58.12	2906	1	2,906
Total Estimated Sewage Flow					3,556

\*Note: Per Section 64E-6.008 System Size Determinations- Footnotes to Table I: 2 - Systems serving high volume establishments, such as restaurants, convenience stores and service stations located near interstate type highways and similar high-traffic areas, require special sizing consideration due to expected above average sewage volume.

\*\* Note Multiplier: Minimum estimated flows for these facilities shall be 3.0 times the volumes determined from the Table I figures.

Estimated Water Flows					
Using Florida Administrative Code*					
Type of Establishment	Rate (GPD)	# Units	GPD	**Note Multiplier	Total Flow (GPD)
<b>Wawa:</b>					
-Service Stations per Water Closet	325	2	650	1	650
-Food Operations - Per 100 S.F. of Floor Space	50	58.12	2906	1	2,906
Total Estimated Sewage Flow					3,556

\*Note: Per Section 64E-6.008 System Size Determinations- Footnotes to Table I: 2 - Systems serving high volume establishments, such as restaurants, convenience stores and service stations located near interstate type highways and similar high-traffic areas, require special sizing consideration due to expected above average sewage volume.

\*\* Note Multiplier: Minimum estimated flows for these facilities shall be 3.0 times the volumes determined from the Table I figures.

**AAC**

PZ18-12000030  
07/06/2021

**AAC**

PZ18-12000030  
04/02/2019