



FIRE METERS - OS & Y VALVES, GASKETS & METER					
(NEPTUNE MACH 10 Ultrasonic Meter)					
SIZE	VALVES (2)	GASKETS (4)	METER w/ Strainer	TOTAL LENGTH	
3" w/ 4" X 3" Reducer **	16"	1/2"	30" **	46 1/2"	
4"	18"	1/2"	27 1/2"	46"	
6"	21"	1/2"	33"	54 1/2"	
8"	23"	1/2"	30"	53 1/2"	
10"	26"	1/2"	41"	67 1/2"	
FIRE &/or Domestic Water SERVICE METERS - TEES, OS & Y VALVES, GASKETS & METERS					
(NEPTUNE MACH 10 Ultrasonic Meter)					
SIZE	TEES (2)	VALVES (2)	GASKETS (6)	Strainer	TOTAL LENGTH
3" w/ 4" X 3" Reducer **	3" X 3" - 22"	16"	3/4"	30" **	68 3/4"
4"	4" X 3" - 26"	18"	3/4"	27 1/2"	72 1/4"
6"	6" X 4" - 32"	21"	3/4"	33"	86 3/4"
8"	8" X 4" - 36"	23"	3/4"	30"	89 3/4"
10"	10" X 6" - 44"	26"	3/4"	41"	111 3/4"


\*All fittings, valves and meters are flanged & all dimensions are from face of flange to face of flange.

NOTE:  
PLEASE NOTE THAT WATER METERS 3" AND LARGER ARE SUBJECT TO AN APPROXIMATE ORDER LEAD TIME OF 60 TO 75 BUSINESS DAYS AFTER FULL PAYMENT. PLEASE CONTACT CUSTOMER SERVICE AT 954-786-4637 TO ARRANGE FOR METER PROCUREMENT AND INSTALLATION. LARGE METERS MUST BE AT MINIMUM ORDERED PRIOR TO INITIAL INSPECTIONS.


ENGINEERING STANDARDS 2022				
REVISIONS		ENGINEERING DIVISION		METER INSTALL DIMENSION LIST
BY	DATE	CITY OF POMPAÑO BEACH		
T.W.	02-2008			DATE: JAN. 2022
S.S.	11-2016			DWG. NO.
A.S.	01-2022	SCALE: N.T.S.		106-4




ENGINEERING STANDARDS 2022				
REVISIONS		ENGINEERING DIVISION		TYPICAL 1" WATER SERVICE
BY	DATE	CITY OF POMPAÑO BEACH		
T.W.	11-2007			DATE: MAY 2022
S.S.	05-2012			DWG. NO.
S.S.	11-2015	SCALE: N.T.S.		107-1
A.S.	08-2021			




ENGINEERING STANDARDS 2022				
REVISIONS		ENGINEERING DIVISION		TYPICAL 2" WATER SERVICE
BY	DATE	CITY OF POMPAÑO BEACH		
T.W.	05-2001			DATE: APRIL 2022
S.S.	05-2012			DWG. NO.
S.S.	11-2018	SCALE: N.T.S.		107-2
A.S.	08-2021			




ENGINEERING STANDARDS 2022				
REVISIONS		ENGINEERING DIVISION		TYPICAL CONFLICT (WATER)
BY	DATE	CITY OF POMPAÑO BEACH		
T.W.	04-2005			DATE: MAY 2022
S.S.	01-2012			DWG. NO.
		SCALE: N.T.S.		108-1



ENGINEERING STANDARDS 2022				
REVISIONS		ENGINEERING DIVISION		FIRE HYDRANT ASSEMBLY
BY	DATE	CITY OF POMPAÑO BEACH		
T.W.	11-2007			DATE: MAY 2022
T.W.	10-2010			DWG. NO.
S.S.	2-2012	SCALE: N.T.S.		109-1
S.S.	11-2022			



ENGINEERING STANDARDS 2022				
REVISIONS		ENGINEERING DIVISION		RESTRAINED VALVE AT TEE
BY	DATE	CITY OF POMPAÑO BEACH		
T.W.	06-2009			DATE: MAY 2022
S.S.		SCALE: N.T.S.		DWG. NO.
				111-1



ENGINEERING STANDARDS 2022				
REVISIONS		ENGINEERING DIVISION		RESTRAINED JOINT INFORMATION
BY	DATE	CITY OF POMPAÑO BEACH		
				DATE: MAY 2022
		SCALE: N.T.S.		DWG. NO.
				118-1

Bealinda M Pell

Digitally signed by Bealinda M Pell  
DN: c=US,  
o=Unaffiliated,  
dnQualifier=A014  
10C0000018E2E7  
2B6AA0002F1E5,  
cn=Bealinda M Pell  
Date: 2024.10.22  
20:49:44 -04'00'



Know what's below.  
Call before you dig.