



Luminaire Schedule Symbol	Qty	Label	Arrangement	Luminaire Lumens	LLF	Luminaire Watts	Total Watts	Description	[MANUFAC]
	5	S1	Single	6265	0.900	40	200	BS100LED4HTLOWT40120-277V_S	BEGHELLI
	3	W6	Single	6768	0.900	38.14286	114.429	OPF-S-P03-740-T4M	SIGNIFY CANADA LTD
	2	SL9	Single	6768	0.900	38.14286	76.286	OPF-S-P03-740-T4M	SIGNIFY CANADA LTD
	4	W5	Single	4295	0.900	22.53333	22.533	OPF-S-P02-740-T3M	SIGNIFY CANADA LTD
	6	GA	Single	4421	0.900	30	180	BS100LEDPG4HTVLOWT40120-277V_S	BEGHELLI


Calculation Summary									
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min	Point Spacing	Calc. Plane Height
Existing Sidewalk	Illuminance	Fc	2.56	4.3	0.1	25.60	43.00	3	0
First to Mid	Illuminance	Fc	29.08	37.4	21.7	1.34	1.72	2	14.256 to 19.303
Ground to Mid	Illuminance	Fc	23.35	28.1	21.0	1.11	1.24	2	0.357 to 7.394
Mid Landing_Top	Illuminance	Fc	24.24	26.6	21.5	1.13	1.24	2	6.993
Mid to First	Illuminance	Fc	26.13	29.9	23.0	1.14	1.30	2	7.394 to 14.256
Mid to Second	Illuminance	Fc	24.86	30.8	20.2	1.23	1.52	2	19.303 to 24.439
Parking	Illuminance	Fc	3.62	6.5	1.4	2.59	4.64	10	0
Property Line	Illuminance	Fc	0.44	2.0	0.0	N.A.	N.A.	N.A.	N.A.
Second Landing_Top	Illuminance	Fc	0.84	1.1	0.4	2.10	2.75	2	13.986
Second Mid Landing_Top	Illuminance	Fc	19.26	21.1	17.6	1.09	1.20	2	18.995
Third Landing_Top	Illuminance	Fc	29.63	31.7	27.4	1.08	1.16	2	23.99
Trash Staging and Guest Parking	Illuminance	Fc	1.83	2.7	1.0	1.83	2.70	5	0




PHOTOMETRY
Scale: 1 inch= 8 Ft.



PHOTOMETRY
Scale: 1 inch= 4 Ft.



PHOTOMETRY
Scale: 1 inch= 4 Ft.



PHOTOMETRY
Scale: 1 inch= 4 Ft.

