



- RISER KEY NOTES:**
- NEW PANEL D SHALL BE LOCKABLE. BREAKERS FOR EVEN RECEPTACLES SHALL ALSO BE LOCKABLE IN THE OFF POSITION.
  - 208V, 7-DAY EXTERIOR TYPE TIMER WITH INPUT FOR EXTERIOR MOUNTED PHOTOSENSOR.
  - DUAL CIRCUIT, 120V, 7-DAY EXTERIOR TYPE TIMER WITH INPUT FOR EXTERIOR MOUNTED PHOTOSENSOR.

PANEL NAME		LOCATION			MOUNTING			SUPPLIED FROM			VOLTAGE			BUS		MAIN			
MDP		ELEC. PANEL			SURFACE			FPL			208 / 120V 3PH, 4W			600		600			
CKT NO	LOAD DESCRIPTION	VA LOAD			FEED	CODE	CB		BUS		TR	P	CODE	FEED	VA LOAD			LOAD DESCRIPTION	CKT NO
		PH A	PH B	PH C			P	TR	A	B					C	PH A	PH B		
1	PANEL B								*				S	4F08				NEW PANEL D	2
3									*				S						4
5										*			S						6
7																			8
9	SPACE								*	*								PANEL A	10
11										*									12
13	PANEL C								*									CU-1	14
15										*									16
17											*								18
19										*	*								20
21	RTU-3								*									RTU-1	22
23	TEWH1									*									24
25										*									26
27	TEWH2									*								TEWH4	28
29	TEWH3									*								TEWH5	30
31										*								TEWH6	32
33											*								34
35										*	*								36
37	RTU-2								*	*								VAV-1-2	38
39										*	*								40
41										*	*								42
43	RTU-4								*	*								VAV-2	44
45										*	*								46
47										*	*								48
48											*	*							
LOAD DESCRIPTION		CONNECTED (KVA)			D.F.		DEMAND (KVA)		SUBFED LOADS (KVA)			CONNECTED			VA				
LIGHTING					1.00				CONNECTED			PH A							
RECEPT					*				DEMAND			PH B							
EQUIPMENT					0.90							PH C							
TOTAL																			
</																			