



1 ELECTRICAL POWER SITE PLAN
SCALE: 1" = 10'-0"

- GENERAL NOTES:**
- COORDINATE EXACT UNDERGROUND CONDUIT ROUTING ON SITE. CONTRACTOR SHALL ENSURE NO EXISTING OR NEW UNDERGROUND UTILITIES ARE IN CONFLICT WITH ELECTRICAL DUCTBANK.
 - ALL CONDUITS SHALL HAVE PULLSTRINGS INSTALLED.
 - PROVIDE HANDHOLES EVERY 100' AND AS REQUIRED TO MEET NEC REQUIREMENTS.
 - ALL HANDHOLES IN LANDSCAPED AREAS SHALL HAVE AN ANSI TIER 15 RATING. HANDHOLES IN ROADWAYS AND PARKING LOT AREAS SHALL BE TIER 22.
 - ELECTRICAL HANDHOLES SHALL HAVE A LID LABELED AS "ELECTRICAL". COMMUNICATION HANDHOLES SHALL HAVE A LID LABELED AS "COMMUNICATIONS".
 - ALL ABOVE GROUND EXTERIOR CONDUIT UP TO 10' SHALL BE RIGID GALVANIZED STEEL. ALL UNDERGROUND CONDUIT SHALL BE SCHEDULE 40 PVC.
- KEY NOTES:**
- ROUTE NEW CIRCUIT FROM EXISTING DISTRIBUTION BOARD MDP IN EXISTING ELECTRICAL ROOM TO NEW PANEL "D" AS SHOWN.
 - ROUTE EMT CONDUIT ABOVE REFLECTED CEILING. COORDINATE WITH EXISTING UTILITIES. SEAL CONDUIT AT EVERY WALL PENETRATION TO RETAIN EXISTING FIRE RATINGS OF WALLS.
 - PROVIDE AN EXTERIOR RATED WALL MOUNTED STAINLESS STEEL BOX AT 4' A.F.F. TO TRANSITION CONDUIT TO UNDERGROUND.
 - BORE 2" PVC CONDUIT UNDER ROADWAY TO NEW HANDHOLE.
 - PROVIDE HANDHOLE AND PVC CONDUIT IN GRAVEL AREA TO NEW PANEL "D". CONDUIT SHALL BE AT 30" MINIMUM DEPTH.
 - INSTALL NEW PANEL "D" ON WALL OF EXISTING DUMPSTER ENCLOSURE. CONTRACTOR SHALL TRIM EXISTING HEDGES TO PROVIDE CLEARANCE FOR PANEL.
 - ROUTE NEW 2" CONDUIT TO EXISTING TELECOM POLE. STUB CONDUIT 12" ABOVE GROUND. INSTALL MAXCELL FABRIC INNERDUCT IN CONDUIT.
 - ROUTE PVC TELECOM CONDUIT IN EXCAVATED AREA NEXT TO NEW WALKWAY. TELECOM CONDUIT SHALL BE MIN. 24" BELOW GRADE.
 - PROVIDE TELECOM HANDHOLE IN LANDSCAPED AREA.
 - STUB TELECOM CONDUIT INSIDE NEW LIGHTING POLE UP TO INTEGRAL POLE HANDHOLE.
 - INSTALL RECEPTACLE 4' A.F.F.
 - INSTALL RECEPTACLE ON CONCRETE BENCH 18" A.F.F. ABOVE GROUND CONDUIT AND ELBOW TRANSITIONING TO PVC SHALL BE GALVANIZED RIGID STEEL.
 - INSTALL 3-PHASE EVENT RECEPTACLE ON LIGHT POLE. REFER TO DETAIL 1 ON THIS SHEET FOR RECEPTACLE SPECIFICATIONS.
 - PROVIDE 4' POST AND INSTALL 3-PHASE RECEPTACLE AS SHOWN ON DETAIL 1 ON THIS SHEET.

Bildworx Design
Engineering Consulting Services

300 SE 2ND STREET, STE 600
FORT LAUDERDALE, FL 33301
PHONE: (954) 933-8246
www.bildworx.com

RAJI SAYEGH
LICENSEE
No. 78700
STATE OF FLORIDA
PROFESSIONAL ENGINEER

Digitally signed by Raji Sayegh
Date: 2023-08-23 11:48:02

WALTERS ZACKRIA ARCHITECTS

5813 N. ANDREWS WAY
FORT LAUDERDALE, FL 33309
PHONE: (954) 522-4123
FAX: (954) 522-4128
www.wza-architects.com

Abbas H. Zackria, FL AR 91520

CORPORATE NAME: WALTERS ZACKRIA ASSOCIATES, PLLC REGISTERED IN THE STATE OF FLORIDA. WRITTEN DIMENSIONS TAKE PRECEDENCE OVER SCALED DIMENSIONS. THESE DRAWINGS ARE THE PROPERTY OF WALTERS ZACKRIA ASSOCIATES, PLLC, AND SHALL NOT BE REPRODUCED WITHOUT WRITTEN PERMISSION FROM A PRINCIPAL OF THE FIRM OR BE LIABLE FOR THE FULLEST LEGAL RECOURSE. CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND DIMENSIONS AND NOTIFY THE ARCHITECT OF ANY DISCREPANCIES PRIOR TO EXECUTION OF WORK.

**CITY OF POMPANO BEACH
CHARLOTTE BURRIE COMM. CENTER
PLAZA AND PASSIVE PARK**

2601 NE 16TH AVE;
POMPANO BEACH, FL 33064

DRAWN BY: JA
CHECKED BY: AZ
DATE: 08-21-2023
REVISIONS:

△	
△	
△	
△	
△	
△	

2203

E1.10B

ELECTRICAL POWER
SITE PLAN

AAC
PZ23-12000041
02/06/2024