



E-1PH

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
CLUBHOUSE & MAINTENANCE PARKING	illuminance	Fc	3.90	12.2	0.7	5.57	17.43
CLUBHOUSE ACCESS ROAD	illuminance	Fc	4.16	16.4	0.8	5.20	20.50
CLUBHOUSE PARKING	illuminance	Fc	3.04	11.0	0.7	4.34	15.71
PROPERTY LINE	illuminance	Fc	0.03	0.6	0.0	N.A.	N.A.
RESIDENTIAL PARKING & ENTRIES	illuminance	Fc	3.16	12.4	0.7	4.51	17.71
CANOPY AREA	illuminance	Fc	11.66	16.4	3.7	3.15	4.43



DRC Resubmittal #3 10/16/24

THESE PLANS ARE FOR BUILDING DEPARTMENT REVIEW. THEY ARE NOT TO BE CONSTRUED AS FINAL CONSTRUCTION DOCUMENTS UNTIL ALL BUILDING DEPARTMENT APPROVALS ARE OBTAINED AND COMMENTS INCORPORATED INTO THESE DWGS. DUE TO THE VARIATIONS IN INTERPRETATIONS OF THE CODE THAT OCCUR IN DIFFERENT MUNICIPALITIES FINAL APPROVAL AND REVIEW IS NEEDED TO ASSURE COMPLIANCE WITH THE APPLICABLE CODES AND STANDARDS.