



ESTIMATED WATER DEMANDS:
58.96 GPM (AVG.), 155.86 GPM [224,434 GPD] (PEAK)
ESTIMATED REQUIRED FIRE FLOW = 1,500 GPM

ESTIMATED SEWER DEMANDS:
38.96 GPM (AVG.), 155.86 GPD [224,434 GPD] (PEAK)