

DRC

PZ21-12000047
04/17/2024

Department	Comments	Responses
Fire	Provide a Hydrant Flow Test to determine the available water supply to this project. This test must be performed by a qualified company of the builder's choice. In addition, the static pressure at the water main shall be determined by a recorded method (ie. water wheel) for a minimum twenty-four (24) hour period. The actual flow test must be witnessed by, and recorded data sent to City of Pompano Beach Fire Prevention.	Request for Hydrant Flow Test sent in.
	Provide Required Fire Flow Data for each proposed structure: Fire flow calculations are determined from square footage and construction type of structure. Refer to NFPA 1 chapter 18 for required fire flow, number/spacing of fire hydrants. Depending on the hydrant flow test results additional fire protection systems or change in construction type maybe required for project (NFPA 1 2018ed chapter 18). This information must be provided at DRC to evaluate current water supply conditions	Fire Flow Data form will be completed with Hydrant Flow Test.
	The city of Pompano requires a minimum of 2 fire hydrants. The maximum distance to secondary fire hydrant is 400ft of any future building. Distance is measured by fire apparatus travel on access roadways. (COPFL ORD. 95.09 (C)) Complete attached form "Water Supply Fire Flow".	Water Supply Fire Flow form will be completed with Hydrant Flow Test.