

AMERICAN EAGLE FIRE PROTECTION, INC.

4711 North Dixie Highway – Boca Raton, FL 33431

Telephone: 561-750-3698 – Fax: 561-750-8496

LIC # 33490800012003


FLOW TEST

STATIC PRESSURE (psi)	RESIDUAL PRESSURE (psi)	PITOT PRESSURE (psi)	PITOT FLOW (gpm)	OUTLET SIZE
74	70	70	1402	2.5"

Address: 1801 N. Andrews Avenue, Pompano Beach

Flow Test Date: January 9, 2023 – January 10, 2023

Sketch of Test Location



X Adam Summers

American Eagle Field Technician

Date: 1/10/2023

DRC

PZ22-12000052

03/01/2023