

DRC


PZ23 12000009
10/02/2024

METERS - OS & Y VALVES, GASKETS & STRAINERS					1" 2" MIN. TRAVEL	
SIZE	VALVES (2)	GASKETS (2)	METER w/ Strainer	TOTAL LENGTH		
4" X 3" Reducer	16"	1"	30" **	46 1/2"		
4"	16"	1"	27 1/2"	48"		
6"	12"	1"	33"	54 1/2"		
8"	12"	1"	30"	53 1/2"		
10"	12"	1"	30"	67 1/2"		
*For Domestic Water SERVICE METERS - TEES, OS & Y VALVES, GASKETS & METERS						
SIZE	TEES (2)	VALVES (2)	GASKETS (2)	METER w/ Strainer	TOTAL LENGTH	
3/4" X 1/2" Reducer	3/4" X 1/2" - 22"	16"	3/4"	30" **	68 3/4"	
1/2" X 3/4" Reducer	1/2" X 3/4" - 26"	18"	3/4"	27 1/2"	72 1/4"	
3/4" X 1" Reducer	3/4" X 1" - 36"	21"	3/4"	33"	86 3/4"	
1" X 1 1/2" Reducer	1" X 1 1/2" - 44"	25"	3/4"	41"	99 3/4"	


*All fittings, valves and meters are flanged & all dimensions are from face of flange to face of flange.

NOTE: PLEASE NOTE THAT WATER METERS 3" AND LARGER ARE SUBJECT TO AN APPROXIMATE ORDER LEAD TIME OF 60 TO 75 BUSINESS DAYS AFTER FULL PAYMENT. PLEASE CONTACT CUSTOMER SERVICE AT 954-786-4637 TO ARRANGE FOR METER PROCUREMENT AND INSTALLATION. LARGE METERS MUST BE AT MINIMUM ORDERED PRIOR TO INITIAL INSPECTIONS.


ENGINEERING STANDARDS 2022			
REVISIONS	BY	DATE	DATE: JAN. 2022
	T.W.	02-2028	DWG. NO.
	S.S.	11-2016	106-4
	A.S.	01-2022	
ENGINEERING DIVISION CITY OF POMPAÑO BEACH			
METER INSTALL DIMENSION LIST			
SCALE: N.T.S.			




ENGINEERING STANDARDS 2022			
REVISIONS	BY	DATE	DATE: MAY 2022
	T.W.	11-2007	DWG. NO.
	S.S.	05-2012	107-1
	S.S.	11-2015	
	A.S.	05-2021	
ENGINEERING DIVISION CITY OF POMPAÑO BEACH			
TYPICAL 1" WATER SERVICE			
SCALE: N.T.S.			




ENGINEERING STANDARDS 2022			
REVISIONS	BY	DATE	DATE: APRIL 2022
	S.S.	05-2011	DWG. NO.
	S.S.	05-2012	107-2
	S.S.	11-2018	
	A.S.	05-2021	
ENGINEERING DIVISION CITY OF POMPAÑO BEACH			
TYPICAL 2" WATER SERVICE			
SCALE: N.T.S.			



ENGINEERING STANDARDS 2022			
REVISIONS	BY	DATE	DATE: MAY 2022
	S.S.	04-2005	DWG. NO.
	S.S.	01-2012	108-1
ENGINEERING DIVISION CITY OF POMPAÑO BEACH			
TYPICAL CONFLICT (WATER)			
SCALE: N.T.S.			



ENGINEERING STANDARDS 2022			
REVISIONS	BY	DATE	DATE: MAY 2022
	T.W.	11-2007	DWG. NO.
	T.W.	10-2010	109-1
	S.S.	2-2012	
	S.S.	11-2012	
ENGINEERING DIVISION CITY OF POMPAÑO BEACH			
FIRE HYDRANT ASSEMBLY			
SCALE: N.T.S.			



ENGINEERING STANDARDS 2022			
REVISIONS	BY	DATE	DATE: MAY 2022
	S.S.	JUNE 2006	DWG. NO.
			111-1
ENGINEERING DIVISION CITY OF POMPAÑO BEACH			
RESTRAINED VALVE AT TEE			
SCALE: N.T.S.			