




SITE LIGHTING FOOTCANDLE SUMMARY						
Label	Units	Avg	Max	Min	Avg/Min	Max/Min
ALL CALCULATION POINTS	Fc	0.37	10.2	0.0	N.A.	N.A.
GRAVEL EMERGENCY ACCESS DRIVE	Fc	1.72	5.2	0.6	2.87	8.67
PARKING - EAST	Fc	5.33	6.5	3.7	1.44	1.76
PARKING - NORTH	Fc	6.83	7.8	5.4	1.26	1.44
PAVED TWO WAY DRIVE	Fc	4.36	7.1	1.2	3.63	5.92
SIDEWALKS - NORTH	Fc	5.11	10.2	2.2	2.32	4.64

OUTDOOR LIGHT FIXTURE SCHEDULE						
Symbol	Qty	Label	Arrangement	Description	Watts	Total Watts
	10	SL4	SINGLE	DL174468 / LED AREA LIGHT / 4000K / ARM MOUNTED / INTERNAL GLARE SHIELD / INTERNAL MOTION AND PHOTO SENSOR / DL179527 -18" TALL ALUMINUM POLE WITH ANCHOR BOLTS AND BASE COVER	135	1350
	10	W1	Single	DL174465 / WALL MOUNTED LED SCONCE / 14'-20' AFF / 4000K CCT / INTERNAL PHOTO AND MOTION SENSOR	102.2	1022
	1	W2	Single	DL174466 / WALL MOUNTED LED SCONCE /4000K CCT / MOUNT OVER EGRESS DOORS / INTERNAL BATTERY BACKUP / INTERNAL PHOTO AND MOTION SENSOR	26	26

LIGHTING NOTES:

- Footcandle values are calculated 5'-0" A.F.G. per IESNA G-1-2016 Guidelines.
- Footcandle values are based on initial light level at 100% output.
- All pole and wall mounted light fixtures will include a Bluetooth programmable twist-lock sensor. The electrical contractor shall program per owner's schedule. See sheet SL3 for programming guide.
- Light poles are 18' tall mounted on bases 2'-0" A.F.G for a total pole height of 20'-0" A.F.G. Wall light WL1 is mounted 20' AFF.
- Wall light WL2 is mounted directly above egress doors at 10' AFF and includes a battery backup for exterior egress emergency lighting.

SITE LIGHTING PHOTOMETRY

SCALE: 1/32" = 1'-0" (24 x 36 sheet)

All electrical work shall comply with National, State, and Local codes including and not limited to the National Electric Code, NFPA 101 Life Safety Code, ASHREA and /or IECC Energy Codes.

The information contained in this document is proprietary to CBMC Lighting Solutions. This document is prepared for a specific site and incorporates calculations based on data available from the client at this time. By accepting and using this document, the recipient agrees to protect its contents from further dissemination, [other than that within the organization necessary to evaluate such specification] without the written permission of CBMC Lighting Solutions. The contents of this document are not to be reproduced or copied in whole or in part without the written permission of CBMC Lighting Solutions. copyright © 2024 CBMC Lighting Solutions all rights reserved.



5855 KOPETSKY DR. SUITE G. | INDIANAPOLIS, IN 46217
317-780-8350| WWW.CBMCINC.COM



This lighting pattern represents illumination levels calculated from laboratory data taken under controlled conditions in accordance with IESNA approved methods. Actual performance of any manufacturer's luminaire may vary due to variation in electrical voltage, tolerance in lamps and LED lumen package, location adjustments, and other variable field conditions.

Contractor to check and verify all dimensions on site before commencing any work shown.



1600 SOUTH DIXIE HWY., SUITE 400
BOCA RATON, FLORIDA 33432
PHONE 561-391-0081 FAX 561-391-0085
EMAIL mail@rwb-branch.com

National Lighting Program Vendor
For pricing and technical assistance contact:
CBMC INC
317-626-1590
Pete Miller - Program Manager- pmiller@cbmcinc.com
Jennifer Karesh-Project Manager - jkaresh@cbmcinc.com
William Proctor - Project Engineer - wproctor@cbmcinc.com

FLORIDA INDOOR TENNIS Site Lighting Photometry POMPANO BEACH, FLORIDA				
Scale:	NTS	Project No:	CB2348-SL-R3	Revision
Date:	8/19/24	Drawing No:		
Drawn By:	WP			
Checked By:	PM / JK			