

CASE TYPE	DATE ESTBL	STATUS	STATUS DATE
Subd/Block/Lot/Str#/Apt ADDRESS	INSPECTOR	TENANT NAME	TENANT NBR
STRUC ORIG. VIOLATION-STANDARD 8236-05- 7- 11T1000912 912 NE 2 ST POMPANO BEACH FL 33060	4/25/24	ACTIVE	5/01/24
	PUENTES, CARLOS		

1. CASE 24-06007044

CASE DATA: ORIG. CASE CERT. MAIL NUMBER
 TYPE OF SERVICE-THIS CASE
 DAYS TO COMPLY-THIS CASE
 INSPECTION DATE-THIS CASE
 COMPLIED DATE-THIS CASE
 SCHEDUL HEARING DATE-THIS CASE
 FINAL ORDER MEETING DATE
 F.O. COMPLY BY DATE-THIS CASE
 I. OF F. MEET'G DATE-THIS CASE
 COMMENTS
 COMMENTS - FINAL ORDER
 COMMENTS
 COMMENTS
 COMMENTS - IMPOSITION OF FINE
 COMMENTS
 COMMENTS
 COMMENTS - ABATEMENT FINE
 COMMENTS
 CERTIFIED MAIL#-THIS CASE
 COMPLIANCE DATE
 DATE FINAL DUE DATE
 DATE LIEN RECORDED

NARRATIVE: 5/1/2024, 10:59:40 AM PUECAR 5/01/24
 Case originated from plumbing chief. Complaint of 5/01/24
 unpermitted underground plumbing work on new construction of 5/01/24
 single family home. Conducted site visit to investigate. 5/01/24
 Found plumbing work in progress. Posted a Stop Work Order 5/01/24
 and Violation Notice. BP23-8681 Foundation Permit does not 5/01/24
 include a plumbing scope of work. Plumbing scope under 5/01/24
 BP22-11540 which is currently in plan review. 5/01/24

NOTICE NAMES: HODGSON, PATRICIA & ENVOY OWNER
 2500 SE 1 CT

VIOLATIONS:	DATE	DESCRIPTION	QTY	CODE	STATUS	DATE RESOLVED
(1)	5/01/24	PERMITS REQ; PLUMB CONST.	1	FBC 105.3.1.4.4	ACTIVE	

CASE TYPE	DATE ESTBL	STATUS	STATUS DATE
Subd/Block/Lot/Str#/Apt ADDRESS	INSPECTOR	TENANT NAME	TENANT NBR
STRUC ORIG. VIOLATION-STANDARD 8236-05- 7- 11T1000912 912 NE 2 ST POMPANO BEACH FL 33060	4/25/24 PUENTES, CARLOS	ACTIVE	5/01/24

1. CASE 24-06007044

VIOLATIONS:	DATE	DESCRIPTION	QTY	CODE	STATUS	DATE RESOLVED
(1)	5/01/24	PERMITS REQ; PLUMB CONST. FLORIDA BUILDING CODE - BROWARD COUNTY AMENDMENTS CH. 1 SECTION 105 PERMITS	1	FBC 105.3.1.4.4	ACTIVE	
<p>105.3.1.4 Permits shall be required for the following operations:</p> <p>105.3.1.4.4 The installation, alteration or repair of any sanitary plumbing, water supply, lawn sprinkler or gas supply system, as provided in the FBC, Plumbing, and/or FBC Fuel Gas.</p>						
NARRATIVE:	5/1/2024, 11:05:54 AM	PUECAR				5/01/24
		Plumbing work was performed without permits. Plumbing rough				5/01/24
		under ground floor slab has been installed without a permit.				5/01/24
		No permits found on record. A plumbing permit is required				5/01/24
		for, but not limited to, alterations performed.				5/01/24