



ON-SITE CONCRETE SIDEWALK



1. ALL SIDEWALKS WITHIN THE PROJECT SITE OUTSIDE OF VEHICULAR PATHWAYS SHALL BE 4" THICK CONCRETE WITH BROOM FINISH.
2. ALL SIDEWALKS WITHIN VEHICULAR PATHWAYS SHALL BE 6" THICK CONCRETE WITH BROOM FINISH.
3. CONTRACTOR SHALL REFER TO LANDSCAPE PLANS FOR LIMITS OF CONCRETE COLORING AND STAMPING.

ON-SITE CONCRETE SIDEWALK




- ①
- ②
- ③

HEAVY DUTY CONCRETE PAVEMENT

1. 6" 4,000 PSI CONCRETE REINFORCED WITH #3 BAR @16" ON-CENTER EACH WAY AND WITH SYNTHETIC MICROFIBERS @ 7.5 LBS/CY
2. 8" LIMEROCK BASE MIN. LBR 100, COMPACTED 98% MAX. DENSITY PER AASHTO T-180
3. 12" STABILIZED SUBGRADE MIN. LBR 40, COMPACTED TO 58% MAX. DENSITY PER AASHTO T-180

HEAVY DUTY CONCRETE PAVEMENT




- ①
- ②
- ③

LIGHT DUTY ASPHALT

1. 1.5" FC-9.5 OR FC-12.5 SURFACE COURSE
2. 6" LIMEROCK BASE MIN. LBR 100, COMPACTED 98% MAX. DENSITY PER AASHTO T-180
3. 12" STABILIZED SUBGRADE MIN. LBR 40, COMPACTED TO 98% MAX. DENSITY PER AASHTO T-180

LIGHT DUTY ASPHALT PAVEMENT




- ①
- ②
- ③

HEAVY DUTY ASPHALT

1. 2" FC-9.5 OR FC-12.5 SURFACE COURSE
2. 8" LIMEROCK BASE MIN. LBR 100, COMPACTED 98% MAX. DENSITY PER AASHTO T-180
3. 12" STABILIZED SUBGRADE MIN. LBR 40, COMPACTED TO 98% MAX. DENSITY PER AASHTO T-180

HEAVY DUTY ASPHALT PAVEMENT


EXISTING ASPHALT TO BE MILLED AND RESURFACED



PROPOSED R/W PAVEMENT RESTORATION

1. CONTRACTOR SHALL MATCH EXISTING PAVEMENT PER FDOT STANDARDS SPECIFICATIONS.

PROPOSED R/W PAVEMENT




- ①
- ②
- ③
- ④

PROPOSED PAVERS

1. 4" TRAFFIC RATED PAVERS
2. 1" BEDDING SAND
3. 8" LIMEROCK BASE MIN. LBR 100, COMPACTED 98% MAX. DENSITY PER AASHTO T-180
4. 12" STABILIZED SUBGRADE MIN. LBR 40, COMPACTED TO 98% MAX. DENSITY PER AASHTO T-180

PROPOSED TRAFFIC RATED PAVERS



NOTES:
1. ALL IMPROVEMENTS BEING PROPOSED WITHIN THE COUNTY R/W SHALL COMPLY WITH THE BROWARD COUNTY MINIMUM STANDARDS.

Date	Description	No.
Revisions		

This form has been digitally signed and sealed by Michael Carr, P.E. on the date indicated in the seal. Signature must be verified on any electronic copies.

MICHAEL P. CARR
LICENSE
No. 72424
STATE OF
FLORIDA
PROFESSIONAL ENGINEER

SIGNATURE: MICHAEL CARR
DATE SIGNED: []
PROFESSIONAL ENGINEER FL LIC. No. 72424

LANGAN
Langan Engineering and Environmental Services, LLC.
110 East Broward Boulevard, Suite 1500
Fort Lauderdale, FL 33301
T: 954.320.2100 F: 954.320.2101 www.langan.com
FBPE REGISTRY NO. 65011LB172LB189

Project: **FESTIVAL SOUTH**
NW 33RD ST
POMPAHO BEACH
BROWARD COUNTY FLORIDA
Drawing Title: **PAVEMENT PLAN**

Project No. 330134202 Drawing No. **C-3.0**
Date: MARCH 2026
Drawn: PZ25-12000043
Checked By: 03/27/2026
MPC