

DESIGNED	DRAWN	CHECKED
NH	NH	JY

EGRESS LEGEND

- 105'-6" TRAVEL DISTANCE
EGRESS PATH OF TRAVEL
COMMON PATH DISTANCE
105'-6" COMMON PATH OF TRAVEL
- LED EXIT SIGN WITH BATTERY PACK, WALL MOUNT
LED EXIT SIGN WITH BATTERY PACK, CEILING MOUNT
EXIT SIGN DIRECTIONAL ARROWS
EXIT SIGN LIGHT DIRECTION

FEC
SURFACE MOUNTED TYPE ABC FIRE EXTINGUISHER
& CABINET EXTINGUISHERS SHALL BE CURRENTLY
DATED AND TAGGED BY LICENSED FIRE
EQUIPMENT COMPANY, AND LOCATED NOT
FURTHER THAN 75 FEET OF TRAVEL DISTANCE TO
AN EXTINGUISHER

FE
SURFACE MOUNTED TYPE ABC FIRE
EXTINGUISHER INSTALLED ON SUPPLIED
BRACKET. EXTINGUISHERS SHALL BE
CURRENTLY DATED AND TAGGED BY LICENSED
FIRE EQUIPMENT COMPANY, AND LOCATED
NOT FURTHER THAN 75 FEET OF TRAVEL
DISTANCE TO AN EXTINGUISHER

EGRESS NOTES

- COORDINATE FIRE ALARM DEVICES AND PANELS WITH ELECTRICAL DRAWINGS
- REFER TO FIRE PROTECTION DRAWINGS FOR SPRINKLER HEAD LOCATIONS
- REFER TO ELECTRICAL DRAWINGS FOR FIRE ALARM DEVICE LOCATIONS
- REFER TO ELECTRICAL DRAWINGS FOR EMERGENCY LIGHT LOCATIONS
- ORDINARY HAZARD OF CONTENTS (NFPA 38.1.5.1)
- A FACTOR OF 0.2 INCHES OF WIDTH PER OCCUPANT HAS BEEN USED TO CALCULATE MINIMUM DOOR AND CORRIDOR EGRESS CAPACITY
- A FACTOR OF 3 INCHES OF WIDTH PER OCCUPANT HAS BEEN USED TO CALCULATE MINIMUM CLEAR WIDTH OF STAIRWAY EGRESS CAPACITY

AUTOMATIC EXTERNAL DEFIBRILLATORS (AED) AND STOP THE BLEED KITS (SBK) SHALL BE INSTALLED AS DEFINED IN NFPA 101, LIFE SAFETY CODE. ON EVERY OTHER FLOOR BEGINNING ON THE FIRST FLOOR, THE AED AND SBK SHALL BE PLACED NEAR THE ELEVATOR(S) BEGINNING IN THE FIRST-FLOOR LOBBY (FIRST FLOOR, THIRD FLOOR, FIFTH FLOOR, ETC.) REFER TO BROWARD FIRE CODE AMENDMENTS SECTION F-121 FOR ADDITIONAL INFORMATION FOR LOCATION, MOUNTING, INVENTORY, TRAINING, AND INSPECTION OF REQUIRED EQUIPMENT.

POOLDECK FLOOR OCCUPANT LOADS

POOL + TUB	857 SF @ 50 SF/OCC = 18 OCCUPANTS
POOLDECK	
(FBC)	2,660 SF @ 15 SF/OCC = 178 OCCUPANTS
(NFPA)	2,660 SF @ 30 SF/OCC = 89 OCCUPANTS
BAR	2,070 SF @ 15 SF/OCC = 138 OCCUPANTS
TERRACE	854 SF @ 15 SF/OCC = 57 OCCUPANTS
ELEV. LOBBY	945 SF @ 150 SF/OCC = 6 OCCUPANTS
OFFICES	827 SF @ 150 SF/OCC = 4 OCCUPANTS
BOH	348 SF @ 300 SF/OCC = 2 OCCUPANTS
TOTAL	(NFPA) 314 OCCUPANTS
	(FBC) 403 OCCUPANTS
	(NFPA) 314 * 0.3 = 94.2" / 2 = (2) STAIRS @ 47.1" CLR WIDTH REQ'
	(FBC) 403 * 0.2 = 80.6" / 2 = (2) STAIRS @ 40.3" CLR WIDTH REQ'
	(2) STAIRS @ 50" CLR WIDTH PROVIDED


1 LEVEL 15 - POOLDECK
AR-106 Scale: 3/32" = 1'-0"

R E V I S I O N S

DATE: 04.05.2024
COMM: 23008

POMPANO HOTEL

101 S. OCEAN BLVD
POMPANO BEACH, FL 33062



Digitally signed
by Jiro Yates
Date:
2024.04.05
10:40:46-04'00'

POOLDECK LEVEL

PROJECT

AR-106

PZ23-12000042

05/22/2024