



3RD FLOOR LIFE SAFETY PLAN

1/4" = 1'-0"

LIFE SAFETY PLAN LEGEND

- DIRECTION OF EGRESS TRAVEL
- POINT OF EXIT DISCHARGE
- STARTING POINT OF TRAVEL DISTANCE
- TRAVEL DISTANCE TO REACH AN EXIT
200'-0" MAX TRAVEL DISTANCE

FIRE EXTINGUISHERS

BUSINESS AREAS:

CLASS A
ORDINARY (MODERATE) HAZARD

MAX. 3,000 S.F. OF AREA TO BE
PROTECTED
MAX. 75'-0" OF TRAVEL DISTANCE



FIRE EXTINGUISHER:

MULTIPURPOSE DRY CHEMICAL
TYPE :
MP5, 5 LBS, UL 2A-10B:C ON
STANDARD
WALL HUNG MOUNTING BRACKET



FIRE EXTINGUISHER NOTE

FIRE EXTINGUISHERS SHALL HAVE A MINIMUM
RATING OF 2A:10BC AND SHALL BE TAGGED BY A
LICENSED FIRE EXTINGUISHER COMPANY. TRAVEL
DISTANCE SHALL NOT EXCEED 75'-0" FEET

REVISIONS:

DATE 06/27/2023

DRAWN : REVIEW :

SCALE :

DRAWING TITLE:

**THIRD FLOOR
LIFE SAFETY PLAN**

SHEET No:

LS-3