

From: [Jay Olsen](#)
To: [Gino Desantis](#); [Abbas Zackria](#); [Jon Shambo](#); [John DiPompeo](#); [Bruce Byrnes](#)
Subject: FW: Emailing: 212 NW 16 Street
Date: Thursday, February 18, 2021 8:17:59 AM
Attachments: [212 NW 16 Street.jpg](#)

Please see below and attached.

From: Horacio Danovich
Sent: Wednesday, February 17, 2021 8:24 PM
To: Jay Olsen <Jay.Olsen@copbfl.com>
Subject: FW: Emailing: 212 NW 16 Street

Please communicate this information with Gino, Abbas, and DiPompeo.

Sent from my T-Mobile 5G Device

----- Original message -----

From: Jim Galloway <Jim.Galloway@copbfl.com>
Date: 2/17/21 5:35 PM (GMT-05:00)
To: Horacio Danovich <Horacio.Danovich@copbfl.com>
Cc: PBFR Prevention <PBFR.Prevention@copbfl.com>
Subject: Emailing: 212 NW 16 Street

Hey Horacio,

I spoke with Jim and we are ok with you moving forward without adding the additional water supply. See attached and let me know if you have any question on how to proceed.

Pete

Your message is ready to be sent with the following file or link attachments:

212 NW 16 Street

Note: To protect against computer viruses, e-mail programs may prevent sending or receiving certain types of file attachments. Check your e-mail security settings to determine how attachments are handled.

DRC

PZ23-12000010
04/19/2023



DRC

PZ23-12000010



It appears you have three existing hydrants that provide sufficient coverage. PBFR does not object to proceeding with existing hydrants and eliminating the new water main.

DRC