



ROOF LEGEND	
<div> <div></div> <div></div> </div> <p>ANCHOR TIEBACK</p> <div> <div></div> <div></div> </div> <p>ROOF OVERFLOW DRAIN</p>	<ol style="list-style-type: none"> EXTERIOR ASSEMBLY EXT-R1: WEE ROOFING SYSTEM OVER COVERBOARD AND MIN. R20 INSULATION PORCELAIN PAVEN MORTAR SET TO TAPERED CEMENTATIONIS SHREDDED TIRE AND GRAVEL SYSTEM WITH SBS MODIFIED BITUMEN ROOFING MEMBRANE (RS-0) PORCELAIN PAVEN ON STRUCTURALLY GROUTED CEMENTATIONIS SHREDDED TIRE PEDESTAL SYSTEM OVER SBS MODIFIED BITUMEN ROOFING MEMBRANE (RS-0) PREFABRICATED ROOFTOP EQUIPMENT PAD
ROOF NOTES	
<ol style="list-style-type: none"> ALL ROOF CRICKETS & SADDLES SHALL BE TAPERED INSULATION PROVIDING A MINIMUM FINISHED SLOPE OF 1/4" PER FT. GC TO COORDINATE ROOF PENETRATIONS W/ MEP ALL ROOF MIN. INSULATION THICKNESS TO BE 5" MIN U.O.N. PROVIDE MINIMUM 8" SPACING BETWEEN PILE PENETRATIONS AND ADJACENT WALLS. 	

