

Summary of required Fire Flow

## 1. Site Data

Structure	<u>Bldg Area</u>	<u>Fire Flow Area</u>
Building 1	380,160. SF	

Type of Construction - II(222) - from NFPA 220; Fire Resistive, Non-combustible

2. Determine Required Fire Flow per Florida Fire Prevention Code (NFPA 1 as amended)  
(Unsprinkled Building)

Required Fire Flow (RFF) = 6,000 gpm @ 20 PSI per NFPA 1 Ch 18 table 18.4.5.1.2

3. Determine Required Fire Flow per Florida Fire Prevention Code (NFPA 1 as amended)  
(For NFPA compliant Automatic Sprinkled Building)

Sprinkled Bldg Required Fire Flow reduce RFF by 75% =	1500 gpm @ 20 PSI
Minimum Required Flow for Sprinkled Bldg =	1000 gpm @ 20 PSI USE 1500 gpm

## 4. Determine Available Flow from Flow Test

Static = 79 psi  
Residual = 73 psi  
Flow = 1250 gpm

$$1250 (79 - 20 / 79 - 73)^{0.54} = 4,295.052 \text{ gpm @ 20 PSI}$$

Total Flow at 20 psi using test data Residual Pressure  
FH 4,295 gpm

# DRC

PZ21-12000040

2/16/2022

# WATER FLOW TEST SUMMARY SHEET

Hyd. No.	Outlet I.D. inches	Pitot Press. psi	Flow gpm	Residual psi	Date: 12/01/21 Time: 24 HOURS Job #: 21EB-0365
1	2.5"	—	1,250	73	Job Name: HIDDEN HARBOUR, LLC.
2	—	—	—	—	Address: 2315 N.E. 15 STREET
3	—	—	—	—	Test Done By: PHILLIPS FIRE SPRINKLERS, INC.
Total Flow			1,250	73	Static Press: 79 psi Flow @ 20 psi >2,000 gpm



**DRC**

PZ21-12000040