

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
ALL CALC POINTS	Illuminance	Fc	1.74	15.2	0.0	N.A.	N.A.
INSIDE PARKING	Illuminance	Fc	4.20	10.3	0.7	6.00	14.71



Luminaire Schedule								
Symbol	Qty	Label	Arrangement	Description	Mounting Height	LLD	LLF	Arr. Lum. Lumens
	3	A	Single	MRS-LED-18L-SIL-FT-50-70CRI-SINGLE	14' POLE+2' BASE	1.000	1.000	16890
	1	B	Single	MRS-LED-18L-SIL-5W-50-70CRI-SINGLE	14' POLE+2' BASE	1.000	1.000	16846
	11	C	Single	LADB--LED-25L-40-FL-TR8R-SF-HAZ		1.000	1.000	2508
								Arr. Watts
								135
								135
								22.4

PHOTOMETRIC EVALUATION  
NOT FOR CONSTRUCTION

Based on the information provided, all dimensions and luminaire locations shown represent recommended positions. The engineer and/or architect must determine the applicability of the layout to existing or future field conditions.

This lighting plan represents illumination levels calculated from laboratory data taken under controlled conditions in accordance with The Illuminating Engineering Society (IES) approved methods. Actual performance of any manufacturer's luminaires may vary due to changes in electrical voltage, tolerance in lamps/LED's and other variable field conditions. Calculations do not include obstructions such as buildings, curbs, landscaping, or any other architectural elements unless noted. Fixture nomenclature noted does not include mounting hardware or poles. This drawing is for photometric evaluation purposes only and should not be used as a construction document or as a final document for ordering product.

Total Project Watts  
Total Watts = 786.4003



3000 ALLIANCE RD. CINCINNATI, OHIO 45242 USA  
(513) 753-3200 • FAX (513) 753-6823

**PROPOSAL** LO-160849-1

PERMIT PETROLEUM HQ  
2024-08-14  
PLANNING GENERAL

BY MWE DATE 08-14-24 REV 08-19-24 SHEET 1 OF 1

**PZ22-12000026**

0 20