

# DRC

PZ22-12000034  
04/05/2023

# DRC

PZ22-12000034  
02/15/2023

**AMERICAN EAGLE FIRE PROTECTION, INC.**

4711 North Dixie Highway – Boca Raton, FL 33431  
Telephone: 561-750-3698 – Fax: 561-750-8496  
LIC # 33490800012003


## FLOW TEST

STATIC PRESSURE (psi)	RESIDUAL PRESSURE (psi)	PITOT PRESSURE (psi)	PITOT FLOW (gpm)	OUTLET SIZE
74	73	32	948	2.5"

**Address:** 1207 E. Atlantic Boulevard, Pompano Beach, FL

**Flow Test Date:** Monday, October 3<sup>rd</sup>, 2022 at 8:00 a.m. – Tuesday, October 4<sup>th</sup>, 2022 at 8:00 a.m.

### Sketch of Test Location



*Adam Summers*

10-4-2022

Signature AEFP Representative

Date

# DRC

PZ22-12000034  
04/05/2023

1207E. Atlantic Boulevard, Pompano Beach, FL – Flow Test 10/3/2022 – 10/04/2022

# DRC

PZ22-12000034  
02/15/2023

