

### GENERAL NOTES

- PROPOSED SANITARY SEWER LATERAL PER BROWARD COUNTY BUILDING DEPARTMENT AND DERM REQUIREMENTS.

### WS KEY NOTES

- PROP 6" FIRE LINE. SEE FIRE PROTECTION SHEETS FOR CONTINUATION / DETAILS.
- CUT IN TO EXISTING 8" DIP WM WITH 8"x6" TEE AND 6" GATE VALVE AND BOX.
- PROP 2" RESILIENT SEATED GATE VALVE. PROP 2" WATER METER. PROP 2" BACKFLOW PREVENTOR.


### LEGEND

- PROPERTY LINE / ROW
- EXISTING BUILDING / WALL
- EXISTING UTILITY EASEMENT
- EXISTING UTILITY POLE
- EXISTING LIGHT POLE
- EXISTING ELECTRIC CABLE
- EXISTING CATCH BASIN
- EXISTING WATER METER
- EXISTING DRAINAGE WELL
- EXISTING SAN SEWER MANHOLE
- STORM SEWER MANHOLE
- EXISTING ELEVATION
- EXISTING FIRE HYDRANT
- PROPOSED VALVE & BOX
- PROPOSED WATER METER
- BACKFLOW PREVENTOR
- PROPOSED TEE
- PAVEMENT RESTORATION
- PROPOSED 45° BEND
- PROPOSED 22.5° BEND
- PROPOSED FDC

CONCURRENCY TABLE					
PUBLIC FACILITY	USE	OCCUPANCY	UNIT	TOTAL	UNIT
Water	Warehouse @ 0.10 GPD/Square Foot	20,930	sq. ft.	2093.0000	gpd
Sewer	Warehouse @ 0.10 GPD/Square Foot	20,930	sq. ft.	2093.0000	gpd

FOR REVIEW ONLY		DATE
NO.	REVISION	

**FIBERBUILT UMBRELLA**  
2201 WEST ATLANTIC BOULEVARD, POMPANO BEACH, FL, 33069  
FOR: FIBERBUILT UMBRELLA



06/12/2024  
THIS DOCUMENT HAS BEEN DIGITALLY SIGNED AND SEALED BY ROSAMIA D. CORDOVA, P.E. ON THE DATE ADJACENT TO THE SEAL. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.



06/12/2024  
THIS DOCUMENT HAS BEEN DIGITALLY SIGNED AND SEALED BY ROSAMIA D. CORDOVA, P.E. ON THE DATE ADJACENT TO THE SEAL. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

DESIGN: OG | CHECKED: RDC

SCALE: 1" = 30'

DATE: 07/30/2024

PROJECT NO. 23.236-01

SHT 08 OF 13

DWG NO. C301