



**011**  
**LSP**

1. EGRESS REQUIREMENTS SHALL COMPLY WITH NFPA 101 CHAPTER 7 SECTION 7-2.1. & 38-22.2
2. ALL HARDWARE SHALL COMPLY WITH 101-7.2.1.5 REQUIREMENTS.
3. ALL DOORS IN THE MEANS OF EGRESS SHALL BE SINGLE ACTION RELEASE NOT REQUIRED THE USE OF A KEY, TOOL, OR SPECIAL KNOWLEDGE TO OPEN FROM EGRESS SIDE

1. PORTABLE FIRE EXTINGUISHERS SHALL BE IN EVERY BUSINESS OCCUPANCY