

AMERICAN EAGLE FIRE PROTECTION, INC.

4711 North Dixie Highway – Boca Raton, FL 33431

Telephone: 561-750-3698 – Fax: 561-750-8496

LIC # 33490800012003

FLOW TEST

STATIC PRESSURE (psi)	RESIDUAL PRESSURE (psi)	PITOT PRESSURE (psi)	PITOT FLOW (gpm)	OUTLET SIZE
78	70	28	885	2"

Address: 1600 Block of NW 6th Avenue, Pompano Beach

Flow Test Date: Monday, May 22 – 8:30 to Tuesday, May 23rd, 2023 8:30 a.m.

Sketch of Test Location



DRC

Barrio Conetta/Adam Summers

Date: 05-24-2023

DRC

PZ23-12000016
08/16/2023

PZ23-12000016
07/05/2023