


1 LEVEL 18 - BALLROOM FLOORPLAN
Scale: 3/32" = 1'-0"



EGRESS LEGEND

- 105'-6" TRAVEL DISTANCE
- EGRESS PATH OF TRAVEL
- LED EXIT SIGN WITH BATTERY PACK, WALL MOUNT
- LED EXIT SIGN WITH BATTERY PACK, CEILING MOUNT
- EXIT SIGN DIRECTIONAL ARROWS
- EXIT SIGN LIGHT DIRECTION
- FEC SURFACE MOUNTED TYPE ABC FIRE EXTINGUISHER & CABINET. EXTINGUISHERS SHALL BE CURRENTLY DATED AND TAGGED BY LICENSED FIRE EQUIPMENT COMPANY, AND LOCATED NOT FURTHER THAN 75 FEET OF TRAVEL DISTANCE TO AN EXTINGUISHER
- FE SURFACE MOUNTED TYPE ABC FIRE EXTINGUISHER INSTALLED ON SUPPLIED BRACKET. EXTINGUISHERS SHALL BE CURRENTLY DATED AND TAGGED BY LICENSED FIRE EQUIPMENT COMPANY, AND LOCATED NOT FURTHER THAN 75 FEET OF TRAVEL DISTANCE TO AN EXTINGUISHER

EGRESS NOTES

- COORDINATE FIRE ALARM DEVICES AND PANELS WITH ELECTRICAL DRAWINGS
- REFER TO FIRE PROTECTION DRAWINGS FOR SPRINKLER HEAD LOCATIONS
- REFER TO ELECTRICAL DRAWINGS FOR FIRE ALARM DEVICE LOCATIONS
- REFER TO ELECTRICAL DRAWINGS FOR EMERGENCY LIGHT LOCATIONS
- ORDINARY HAZARD OF CONTENTS (NFPA 38.1.5.1)
- A FACTOR OF 0.2 INCHES OF WIDTH PER OCCUPANT HAS BEEN USED TO CALCULATE MINIMUM DOOR AND CORRIDOR EGRESS CAPACITY
- A FACTOR OF .3 INCHES OF WIDTH PER OCCUPANT HAS BEEN USED TO CALCULATE MINIMUM CLEAR WIDTH OF STAIRWAY EGRESS CAPACITY

AUTOMATIC EXTERNAL DEFIBRILLATORS (AED) AND STOP THE BLEED KITS (SBK) SHALL BE INSTALLED AS DEFINED IN NFPA 101, LIFE SAFETY CODE, ON EVERY OTHER FLOOR BEGINNING ON THE FIRST FLOOR. THE AED AND SBK SHALL BE PLACED NEAR THE ELEVATOR(S) BEGINNING IN THE FIRST-FLOOR LOBBY (FIRST FLOOR, THIRD FLOOR, FIFTH FLOOR, ETC.) REFER TO BROWARD FIRE CODE AMENDMENTS SECTION F-121 FOR ADDITIONAL INFORMATION FOR LOCATION, MOUNTING, INVENTORY, TRAINING, AND INSPECTION OF REQUIRED EQUIPMENT.

BALLROOM FLOOR OCCUPANT LOADS

PANTRY	2 OCCUPANTS
PRE-FUNCTION	134 OCCUPANTS
ELEV. LOBBY	2 OCCUPANTS
BALLROOM	202 OCCUPANTS
BALCONY	136 OCCUPANTS
TOTAL	476 OCCUPANTS

888 SOUTH ANDREWS AVE. SUITE 300
FORT LAUDERDALE, FLORIDA 33316
PH: (954) 764-6575 FAX: (954) 764-8622

JEFF FALKANGER, DOUG SNYDER
LARRY MARTINEAU, JIRO YATES

COPYRIGHT 2021

FALKANGER, SNYDER, MARTINEAU, & YATES ALL RIGHTS
RESERVED. THIS DOCUMENT OR PARTS THEREOF MAY NOT
BE REPRODUCED IN ANY FORM WITHOUT PERMISSION.

CA # AAC000447


DESIGNED	DRAWN	CHECKED
NH	NH	JY

R E V I S I O N S

DATE: 9.27.2023
COMM: 23008

POMPANO HOTEL

101 S. OCEAN BLVD
POMPANO BEACH, FL 33062



Digitally signed
by Joshua D
Bailey
Date:
2023.12.15
14:49:44-05'00'

BALL ROOM LEVEL

DRC SET

AR-107

12/15/2023 2:13:41 PM