

TO THE BEST OF OUR KNOWLEDGE
AND BELIEF, THE INFORMATION
CONTAINED ON THESE DRAWINGS
CONFORMS TO THE STANDARDS
SET IN THE FLORIDA BUILDING
CODE. THE CONTRACTOR SHALL BE
RESPONSIBLE FOR VERIFYING ALL
DIMENSIONS AND FIELD
CONDITIONS PRIOR TO THE START
OF THE WORK, AND NOTIFYING THE
ARCHITECT AT ONCE OF ANY AND
ALL ERRORS, DISCREPANCIES,
IRREGULARITIES, OR OMISSIONS
PERTAINING TO THE SUCCESSFUL
COMPLETION OF THE PROJECT
INDICATED.

**DRC SUBMITTAL
FEBRUARY 26, 2025**

[illegible]

—

04/02/2025




ENGINEERING DIVISION


FILE NO.	DWG. NO.
107-NTS	107-

ENGINEERING DIVISION

<div style="display: flex; justify-content: space-between;"> <div> <p>DATE: NTS</p> </div> <div> <p>DWG. NO.</p> <p>106-4</p> </div> </div>

ENGINEERING DIVISION | RESTRAINED JOINT INFORMATION

DATE: MAY 202
DWG. NO.

ENGINEERING STANDARDS 2025

FILE: NTS	DWG. NO. 106-
-----------	------------------



1. THE BACKFLOW PREVENTOR FOR THE BY-PASS SHALL BE DDCV OR RPZ.
2. PLEASE NOTE THAT WATER METERS 3" AND LARGER ARE SUBJECT TO AN APPROXIMATE ORDER LEAD TIME OF 60 TO 75 DAYS AFTER FULL PAYMENT. PLEASE CONTACT CUSTOMER SERVICE AT 954-786-4637 TO ARRANGE FOR METER PROCUREMENT AND INSTALLATION.
3. USE MEGALUGS AT ALL PIPE JOINTS
4. PLEASE SEE METER INSTALLATION DIMENSION LIST ON STANDARD NO. 105-1

ENGINEERING STANDARDS 2025

FILE: NTS	DWG. NO. 106-
-----------	------------------



USE MEGALUGS AT ALL PIPE JOINTS	ALL D.I.P. TO BE PAINTED BLUE ON THE TOP HALF OF PIPE.
---------------------------------	---

ENGINEERING DIVISION

DATE: MAY 20 DWG. NO.	OF TOMB AND BEACH
	(Empty space)



HYDRANT GUARDS TO BE 6" DIAMETER GALVANIZED STEEL PIPE PAINTED YELLOW
FILLED WITH CONCRETE. OMIT GUARDS IN LOCATIONS WHERE SIDEWALKS EXIST.

**USE 2-3/4" S.S. TIE RODS WHEN DISTANCE BETWEEN MAIN AND HYDRANT < 10'. TIE RODS WILL BE USED W/RESTRAINED JOINTS OR USE MEGALUGS AT ALL PIPE JOINTS

HYDRANTS INSTALLED ON EXISTING WATER MAINS MUST USE A MUELLER MJ DI TAPPING SLEEVE, H-615 OR APPROVED EQUAL.

HYDRANTS CONNECTED TO NEW MAINS SHALL BE CONNECTED USING A HYDRANT TEE.

ALL POMPANO BEACH HYDRANTS SHALL BE PAINTED RED.

TYPICAL FIRE HYDRANT ASSEMBLY

ENGINEERING DIVISION


DATE: MAY 20
DWG. NO.



USE MEGALUGS AT ALL PIPE JOINTS	ALL D.I.P. TO BE PAINTED BLUE ON THE TOP HALF OF PIPE.
---------------------------------	---

ENGINEERING DIVISION

DATE: MAY 20 DWG. NO.	OF TOMB AND BEACH
	(Empty space)

ENGINEERING DIVISION | RESTRAINED JOINT INFORMATION

DATE: MAY 202
DWG. NO.